

MONTERREY, Mexico

WMO: 763930

Lat: 25.6825N

Lon: 100.2717W

Elev: 1690

StdP: 13.82

Time Zone: -6.00 (MEX)

Period: 94-17

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	39.6	42.9	25.5	20.8	55.7	29.5	25.1	56.8	15.2	60.1	11.4	59.8	3.3	0	0.301

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.2	100.8	74.6	98.9	74.6	97.2	74.7	80.9	94.3	79.2	92.6	78.0	91.0	6.1	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
77.2	150.9	90.2	75.6	142.5	87.4	74.4	137.0	85.1	46.1	94.3	44.3	93.0	42.8	91.1	91.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.6	11.5	9.6	35.7	107.0	3.5	3.5	33.2	109.6	31.1	111.6	29.2	113.6	26.6	116.2		
(5)			33.2	85.3	3.4	2.3	30.7	87.0	28.8	88.3	26.9	89.6	24.4	91.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	74.2	61.2	64.6	69.8	76.0	81.1	84.1	84.8	84.5	80.3	74.4	67.8	60.9	(6)
(7)		DBStd	10.82	8.64	8.64	8.01	7.08	5.37	3.40	3.38	3.37	4.41	6.21	6.84	8.35	(7)
(8)		HDD50	43	19	7	1	0	0	0	0	0	0	1	1	14	(8)
(9)		HDD65	575	172	104	49	10	1	0	0	0	0	10	50	179	(9)
(10)		CDD50	8864	366	415	615	779	965	1024	1077	1069	909	758	535	352	(10)
(11)		CDD65	3919	53	92	198	338	501	574	612	604	459	302	134	52	(11)
(12)		CDH74	42199	451	846	1848	3554	5653	6917	7589	7289	4567	2323	797	365	(12)
(13)		CDH80	20540	123	308	751	1740	2910	3647	4137	3841	1995	787	211	90	(13)
(14)	Wind	WSAvg	3.9	3.3	3.6	4.3	4.3	4.4	4.8	4.9	4.2	3.6	3.5	3.2	2.9	(14)
(15)	Precipitation	PrecAvg	25.4	0.7	0.7	0.9	1.4	2.2	2.6	2.0	3.4	7.4	2.7	1.1	0.7	(15)
(16)		PrecMax	47.6	4.5	4.7	3.8	7.2	9.7	15.4	14.4	19.2	17.7	6.7	4.2	3.3	(16)
(17)		PrecMin	14.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.5	0.0	0.0	0.0	(17)
(18)		PrecStd	7.0	0.9	0.9	0.9	1.5	1.9	2.6	3.0	3.5	4.6	1.9	1.1	0.8	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	88.6	94.4	97.4	102.3	105.3	103.0	102.0	101.3	99.2	94.0	91.0	87.2	(19)
(20)			MCWB	63.7	65.1	66.5	71.9	74.1	76.8	74.4	76.1	72.9	73.2	68.3	65.0	(20)
(21)		2%	DB	83.3	88.0	92.8	97.4	99.5	99.3	99.5	99.3	95.4	89.9	85.1	81.9	(21)
(22)			MCWB	64.0	65.2	67.7	70.6	74.9	75.7	75.0	75.2	73.3	73.2	68.8	65.0	(22)
(23)		5%	DB	79.0	83.5	88.5	93.5	96.2	97.0	97.7	97.2	92.5	87.2	81.5	77.9	(23)
(24)			MCWB	63.1	64.7	68.0	71.5	74.9	75.7	75.6	75.2	73.9	72.5	67.5	64.7	(24)
(25)		10%	DB	74.7	79.3	84.2	89.6	93.0	94.6	95.7	95.1	89.8	84.5	78.3	73.6	(25)
(26)			MCWB	60.7	64.0	67.0	70.5	75.0	75.2	75.4	75.2	74.3	71.7	66.5	62.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	68.8	70.9	76.2	79.0	82.2	83.1	82.7	81.7	79.7	78.2	73.7	70.7	(27)
(28)			MCDWB	80.6	84.2	87.8	92.9	96.9	95.4	96.5	95.6	90.6	88.2	83.2	80.2	(28)
(29)		2%	WB	66.2	68.3	72.5	75.5	79.7	80.7	79.7	78.8	77.9	76.2	71.5	67.9	(29)
(30)			MCDWB	77.6	80.2	84.9	89.5	93.0	93.8	94.2	93.3	88.6	85.1	79.0	76.5	(30)
(31)		5%	WB	64.5	66.8	70.7	73.8	77.8	78.9	78.0	77.4	76.5	74.7	70.0	66.4	(31)
(32)			MCDWB	75.2	78.2	82.3	87.3	90.2	91.9	92.4	91.6	86.9	82.9	76.6	74.5	(32)
(33)		10%	WB	62.5	65.3	69.1	72.4	76.3	77.2	76.7	76.5	75.5	73.4	68.7	64.6	(33)
(34)			MCDWB	71.8	76.1	79.6	84.4	87.9	89.5	90.8	90.0	85.6	81.0	75.7	72.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	19.3	19.7	20.0	20.9	19.6	19.5	20.2	19.2	16.7	16.0	17.0	18.4	(35)
(36)			MCDBR	27.1	28.5	28.8	28.0	26.1	23.3	23.6	22.9	21.3	20.0	22.7	25.3	(36)
(37)			MCWBR	12.1	11.6	10.1	9.1	8.6	6.7	6.7	6.4	6.2	7.4	9.6	11.8	(37)
(38)		5% WB	MCDBR	23.7	22.9	21.8	23.6	21.9	20.6	21.6	20.3	17.6	16.3	17.5	20.7	(38)
(39)			MCWBR	12.3	10.6	10.3	9.6	9.9	8.9	7.8	7.2	6.7	7.5	8.5	11.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.329	0.350	0.387	0.410	0.442	0.409	0.402	0.393	0.409	0.378	0.362	0.336	(40)	
(41)		taud	2.503	2.428	2.333	2.292	2.243	2.393	2.439	2.466	2.395	2.463	2.441	2.489	(41)	
(42)		Ebn at Noon	294	295	288	283	272	279	281	284	278	282	280	287	(42)	
(43)		Edh at Noon	30	35	40	43	45	38	36	36	37	33	32	29	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1202	1476	1758	1972	2023	2136	2073	2040	1673	1527	1277	1131	(44)	
(45)		RadStd	119	182	170	148	104	128	159	110	158	149	144	114	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (4 neighbors)		N/A	N/A	N/A	N/A	-1.78	-1.01	N/A	N/A	N/A	N/A	

Nomenclature: See separate page