

MAZATLAN INTL, Mexico

WMO: 764593

Lat: 23.161N

Lon: 106.266W

Elev: 12

StdP: 101.19

Time Zone: -7.00 (MEC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.7	9.9	3.2	4.8	13.5	5.0	5.4	13.4	20.9	15.9	8.1	23.9	2.5	10	0.358

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.7	33.9	25.3	33.1	25.2	32.8	25.2	27.8	31.3	27.2	30.8	26.8	30.4	4.6	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.0	22.7	30.1	26.2	21.6	29.5	26.0	21.3	29.4	89.3	31.4	86.5	31.0	84.5	30.7	30.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.1	7.1	6.2	DB	6.9	35.3	1.9	1.3	5.5	36.2	4.4	36.9	3.3	37.7	1.9	38.6	
			WB	5.2	29.2	1.9	0.6	3.8	29.6	2.6	30.0	1.5	30.3	0.1	30.8	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	24.0	19.5	19.7	20.0	21.6	24.5	27.8	28.3	28.1	27.7	26.7	23.8	20.5	
	DBStd	3.84	2.09	2.03	1.75	1.56	1.88	1.48	1.26	1.16	1.18	1.55	1.93	2.11	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	
	HDD18.3	31	12	8	5	0	0	0	0	0	0	0	0	6	
	CDD10.0	5123	296	271	311	349	448	534	567	561	531	519	413	325	
	CDD18.3	2113	49	46	58	99	190	284	308	302	281	261	163	72	
	CDH23.3	22326	521	501	728	1074	1998	3183	3584	3404	2968	2446	1311	608	
CDH26.7	8279	93	88	141	282	780	1327	1517	1392	1091	968	473	127		
Wind	WSAvg	2.6	2.6	2.7	2.9	2.9	3.1	3.2	2.8	2.5	2.3	2.2	2.4	2.3	
Precipitation	PrecAvg	855	16	13	3	1	1	44	171	234	246	68	36	13	
	PrecMax	1209	290	122	35	29	2	174	375	529	487	224	231	84	
	PrecMin	445	0	0	0	0	0	0	37	64	74	1	0	2	
	PrecStd	197	56	25	7	5	1	50	84	109	115	59	51	19	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.8	30.8	31.1	31.9	33.1	34.1	34.2	34.1	33.8	33.8	33.1	31.1	
		MCWB	20.3	19.8	18.6	19.2	21.5	24.5	25.7	26.1	27.2	26.6	23.7	21.3	
	2%	DB	28.9	28.9	29.1	30.2	32.1	33.2	33.8	33.1	32.9	32.8	31.9	29.1	
		MCWB	19.6	19.4	18.7	19.4	21.7	24.2	25.6	26.1	26.6	26.2	23.4	20.7	
	5%	DB	27.8	27.8	28.1	29.1	31.2	32.9	33.0	32.8	32.0	32.0	30.9	28.0	
		MCWB	19.4	19.2	18.8	19.3	22.0	24.1	25.4	26.1	26.4	25.5	23.2	20.4	
	10%	DB	26.2	26.8	27.1	28.2	30.8	32.0	32.1	31.9	31.2	31.1	29.2	27.0	
		MCWB	18.7	18.7	18.7	19.5	22.0	24.1	25.2	25.9	26.2	25.1	22.2	20.0	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.2	22.3	22.0	22.6	24.9	26.6	28.0	28.6	28.4	28.1	26.2	23.6
			MCDB	27.6	27.6	27.5	27.9	30.2	31.3	32.0	32.0	31.9	31.9	30.9	28.3
2%		WB	21.0	21.1	20.9	21.7	24.1	25.9	27.1	27.8	27.7	27.2	24.9	22.4	
		MCDB	26.8	26.6	26.8	27.4	29.7	30.6	31.1	31.1	31.1	30.9	29.8	27.4	
5%		WB	20.2	20.2	20.1	21.1	23.5	25.2	26.6	27.2	27.1	26.5	24.0	21.4	
		MCDB	26.2	26.0	26.3	27.1	29.0	30.5	30.7	30.6	30.4	30.3	28.9	26.5	
10%		WB	19.3	19.3	19.3	20.5	22.7	24.7	26.1	26.6	26.6	25.9	23.2	20.5	
		MCDB	25.3	25.2	25.6	26.6	28.3	30.1	30.4	30.2	29.9	29.8	28.0	25.7	
Mean Daily Temperature Range		5% DB	MDBR	14.7	14.4	14.8	14.1	12.2	8.2	7.7	7.6	7.0	9.1	12.1	13.6
			MCDBR	15.6	15.4	16.0	15.4	12.5	8.8	8.6	8.3	8.0	9.6	12.9	14.3
	MCWBR		8.4	8.2	8.4	7.9	6.0	3.7	3.8	4.1	4.1	4.5	6.4	7.6	
	5% WB	MCDBR	13.9	13.6	14.0	13.1	10.5	7.9	7.8	7.7	7.3	8.5	11.4	12.9	
		MCWBR	8.0	7.8	7.9	7.0	5.1	3.5	3.9	4.3	4.2	4.3	6.1	7.3	
Clear-Sky Solar Irradiance	taub	0.318	0.331	0.316	0.353	0.400	0.426	0.437	0.413	0.419	0.368	0.328	0.317		
	taud	2.603	2.534	2.588	2.442	2.370	2.370	2.380	2.457	2.400	2.577	2.652	2.640		
	Ebn at Noon	954	959	987	947	894	864	854	879	871	909	937	943		
	Edh at Noon	88	100	99	117	125	124	122	113	118	95	83	82		
All-Sky Solar Radiation	RadAvg	4.47	5.44	6.67	7.44	7.72	6.88	6.23	6.03	5.37	5.40	4.80	4.22		
	RadStd	0.35	0.47	0.22	0.38	0.26	0.31	0.32	0.22	0.26	0.26	0.28	0.24		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	+0.64	N/A	N/A	N/A	N/A
(47)	Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	+0.64	N/A	N/A	N/A	N/A

Nomenclature: See separate page