

SAN LUIS POTOSI, Mexico

WMO: 765390

Lat: 22.1758N

Lon: 100.9875W

Elev: 1883

StdP: 80.66

Time Zone: -6.00 (MEX)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.8	2.2	-16.0	1.2	23.0	-12.2	1.6	20.1	10.3	19.6	9.4	18.3	0.4	0	0.412

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	16.3	32.2	14.0	31.0	14.2	29.8	14.2	18.7	24.7	18.1	24.0	17.6	23.4	3.8	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.2	15.5	19.3	16.9	15.2	19.0	16.1	14.4	18.7	61.3	24.6	59.1	23.5	57.2	22.8	21.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.4	8.1	6.9	-2.0	34.6	2.1	1.6	-3.5	35.7	-4.8	36.6	-6.0	37.5	-7.5	38.6
			-3.9	20.4	1.6	0.8	-5.0	21.0	-6.0	21.4	-6.9	21.8	-8.0	22.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	17.8	12.9	15.0	17.2	20.0	21.5	21.2	20.1	20.2	19.3	17.6	15.1	13.4
	DBStd	3.71	2.80	3.00	2.67	2.39	2.16	1.74	1.30	1.21	1.56	2.39	2.69	2.72
	HDD10.0	19	8	3	1	0	0	0	0	0	0	0	2	6
	HDD18.3	639	170	96	51	12	3	1	2	1	8	42	100	153
	CDD10.0	2864	97	144	224	299	355	335	314	317	279	234	154	112
	CDD18.3	443	1	4	17	61	100	86	57	59	38	18	2	1
	CDH23.3	5112	56	209	491	987	1208	731	427	429	214	206	99	57
	CDH26.7	1405	2	31	116	368	487	217	67	64	20	26	6	2
(14) Wind	WSAvg	2.4	2.1	2.5	2.7	2.8	2.6	2.8	2.8	2.7	2.3	2.0	1.9	1.9
(15) Precipitation	PrecAvg	398	13	11	10	12	42	51	73	54	73	35	14	8
	PrecMax	656	107	71	54	83	139	168	226	165	149	153	71	43
	PrecMin	224	0	0	0	0	0	1	7	17	7	0	2	0
	PrecStd	108	20	17	14	19	33	37	49	34	39	36	18	11
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.3	29.2	31.1	33.2	34.9	33.0	30.0	30.0	28.8	29.0	27.2	26.5
		MCWB	10.7	12.6	12.7	14.1	15.2	15.8	15.3	16.1	15.5	14.1	13.1	11.8
	2%	DB	25.0	27.4	29.2	31.8	32.9	30.9	28.2	28.2	27.0	27.1	26.0	25.0
		MCWB	10.5	11.1	12.0	13.4	14.4	15.6	15.3	15.5	15.7	14.4	12.5	11.3
	5%	DB	23.2	26.0	28.0	30.2	31.1	29.1	27.1	27.1	25.8	25.9	24.2	23.4
		MCWB	9.9	11.1	11.5	12.7	14.3	15.7	15.2	15.4	15.6	14.3	12.7	10.9
	10%	DB	21.8	24.2	26.2	29.0	29.8	27.6	25.9	26.0	24.3	24.0	22.9	21.9
		MCWB	9.8	10.7	11.4	12.1	14.6	15.7	15.3	15.6	15.7	14.3	12.6	10.6
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.7	15.9	16.6	17.1	19.0	19.4	19.4	19.0	19.1	18.1	16.8	15.0
		MCDB	21.9	24.3	25.3	26.6	26.5	25.5	24.5	25.3	24.0	24.0	22.9	22.5
	2%	WB	12.9	14.1	15.0	16.0	18.1	18.4	18.2	18.0	18.1	17.0	15.7	13.7
		MCDB	19.8	22.9	23.4	24.9	25.6	24.9	22.6	24.2	23.0	22.7	21.0	21.0
	5%	WB	11.8	13.1	13.9	15.2	17.2	17.7	17.5	17.3	17.5	16.3	14.9	12.7
		MCDB	19.1	21.8	22.7	24.0	24.9	24.0	21.9	23.1	22.0	21.6	20.2	20.4
	10%	WB	10.9	12.1	13.1	14.5	16.7	17.1	16.9	16.8	17.0	15.7	14.0	11.8
		MCDB	18.0	20.6	21.6	23.2	24.4	23.1	21.6	22.5	21.3	20.8	19.3	19.3
(35) Mean Daily Temperature Range	5% DB	MDBR	16.3	17.2	17.6	17.6	16.3	13.3	12.3	12.5	11.2	13.4	15.1	16.5
		MCDBR	19.7	20.4	20.3	20.0	19.0	16.3	14.8	14.7	13.4	16.7	18.0	19.4
	5% WB	MCWBR	9.2	8.6	7.8	7.6	6.4	5.6	5.5	5.2	5.0	6.8	7.6	8.9
		MCWBR	16.0	17.2	17.6	17.5	16.3	13.8	11.6	12.8	11.0	13.0	13.6	16.2
(40) Clear-Sky Solar Irradiance	taub		0.294	0.307	0.318	0.341	0.392	0.374	0.364	0.355	0.358	0.335	0.305	0.298
		taud	2.498	2.445	2.423	2.361	2.261	2.343	2.396	2.436	2.421	2.473	2.510	2.516
	Ebn at Noon		983	987	985	959	901	910	920	934	931	944	963	966
		Edh at Noon	97	109	117	127	139	127	121	116	116	105	95	92
(44) All-Sky Solar Radiation	RadAvg		4.48	5.47	6.50	7.07	7.03	6.58	6.41	6.35	5.40	5.22	4.65	4.30
	RadStd		0.34	0.52	0.41	0.37	0.31	0.36	0.53	0.32	0.39	0.38	0.43	0.32

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.51	N/A	N/A	N/A	N/A	N/A	-112	+198	N/A
(47) Regional (5 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	-112	+198	N/A

Nomenclature: See separate page