

TAMPICO INTL, Mexico

WMO: 765493

Lat: 22.296N

Lon: 97.866W

Elev: 80

StdP: 14.65

Time Zone: -6.00 (MEX)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	50.0	53.4	35.7	30.7	59.0	40.7	37.5	59.3	30.4	62.6	28.1	63.5	9.2	0	0.380

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	13.7	94.3	80.6	92.8	80.1	91.4	79.7	82.9	90.3	81.8	88.8	81.0	87.6	9.9	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.9	161.2	86.7	80.2	157.1	85.7	79.2	151.8	84.5	46.9	90.5	45.6	89.6	44.8	88.2	92.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.5	22.1	19.2	DB	46.2	100.8	4.6	4.3	42.9	103.9	40.2	106.4	37.6	108.8	34.2	112.0	(4)
(5)			WB	41.2	86.5	3.6	2.2	38.6	88.1	36.4	89.3	34.4	90.5	31.8	92.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	77.6	66.9	70.3	73.8	78.5	83.0	84.7	84.3	84.9	82.9	79.3	74.0	68.8
	DBStd	7.83	6.37	6.27	5.44	4.30	3.24	2.59	2.55	2.52	2.93	4.34	5.33	6.33
	HDD50	2	1	0	0	0	0	0	0	0	0	0	0	1
	HDD65	137	56	26	8	1	0	0	0	0	0	1	8	37
	CDD50	10092	526	567	737	855	1022	1040	1065	1082	986	909	719	584
	CDD65	4753	115	173	280	407	557	590	600	617	536	445	277	156
	CDH74	44038	301	612	1336	2954	5709	6887	7005	7324	5864	3942	1559	545
	CDH80	15841	29	85	271	796	1990	2873	2908	3153	2203	1190	280	63
Wind	WSAvg	8.0	7.6	8.3	9.4	9.5	9.7	8.5	7.2	6.9	6.6	7.5	7.4	7.4
Precipitation	PrecAvg	44.1	1.3	0.8	0.8	0.9	1.7	6.5	6.4	6.6	10.9	5.0	1.8	1.1
	PrecMax	67.0	9.4	3.1	4.7	4.5	5.5	19.7	21.0	14.6	24.3	13.3	7.2	3.9
	PrecMin	29.7	0.0	0.1	0.0	0.1	0.1	1.6	1.0	0.3	2.3	0.0	0.0	0.0
	PrecStd	9.7	1.7	0.9	0.9	1.0	1.3	4.5	5.3	3.8	5.3	3.3	1.5	1.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	82.8	86.0	89.3	93.1	95.0	95.4	95.2	96.2	94.5	91.8	87.8	84.6
		MCWB	72.1	73.1	76.1	78.4	81.6	81.1	82.0	81.8	80.4	79.8	77.4	74.3
	2%	DB	79.2	82.4	85.2	88.8	91.6	93.2	92.9	93.4	91.8	89.7	84.9	81.8
		MCWB	70.6	72.6	74.5	77.4	80.0	80.4	80.3	80.2	79.9	78.8	75.3	73.0
	5%	DB	77.2	80.3	82.6	86.4	89.8	91.5	91.3	91.7	90.0	87.8	82.9	79.1
		MCWB	69.5	71.7	73.4	76.5	79.0	79.7	79.7	79.9	79.1	77.9	74.2	71.8
	10%	DB	75.1	77.7	80.7	84.5	88.0	89.8	89.7	90.1	88.8	85.9	81.0	77.1
		MCWB	68.2	70.3	72.2	75.4	78.5	79.2	79.1	79.3	78.8	77.0	73.1	71.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	74.0	75.8	78.0	81.0	83.6	84.4	84.2	84.3	83.5	82.3	79.0	76.3
		MCDB	79.5	82.6	85.6	88.7	91.8	92.2	92.1	92.7	89.9	88.4	84.4	81.6
	2%	WB	72.3	74.1	76.0	79.0	81.5	82.2	81.9	82.2	81.7	80.6	77.3	74.8
		MCDB	77.0	79.4	82.5	86.2	88.5	89.1	89.8	89.4	88.0	86.1	82.2	78.8
	5%	WB	71.1	72.9	74.7	77.7	80.4	81.1	80.8	81.1	80.6	79.4	76.1	73.5
		MCDB	75.4	77.4	80.4	84.1	86.2	87.8	87.8	87.9	86.8	84.7	80.9	77.6
	10%	WB	69.9	72.0	73.7	76.6	79.6	80.4	80.0	80.4	79.8	78.5	74.9	72.2
		MCDB	73.8	76.2	78.6	82.2	85.0	86.7	86.6	86.9	85.8	83.8	79.7	76.1
Mean Daily Temperature Range	5% DB	MDBR	13.7	14.2	13.9	14.2	13.2	13.2	13.1	13.7	12.6	13.6	13.7	13.7
		MCDBR	16.2	16.1	15.6	15.5	14.1	14.3	14.2	14.8	14.2	14.8	14.9	16.0
		MCWBR	9.1	8.0	7.9	7.8	6.4	6.1	6.2	5.9	6.3	6.8	7.7	9.0
	5% WB	MCDBR	14.8	14.5	14.8	14.5	13.3	13.4	13.6	14.1	13.3	13.3	13.5	14.2
	MCWBR	9.1	7.8	8.1	7.9	6.7	6.5	6.5	6.3	6.6	7.4	8.4	9.2	
Clear-Sky Solar Irradiance	taub	0.400	0.414	0.438	0.493	0.527	0.462	0.458	0.446	0.445	0.420	0.410	0.398	
	taud	2.391	2.349	2.284	2.144	2.065	2.291	2.317	2.350	2.338	2.406	2.389	2.403	
	Ebn at Noon	274	278	275	261	250	264	266	270	269	272	269	270	
	Edh at Noon	35	38	43	50	54	43	41	40	40	36	35	33	
All-Sky Solar Radiation	RadAvg	1033	1279	1558	1802	1889	1922	1849	1853	1594	1437	1170	1009	
	RadStd	117	140	148	120	91	118	163	87	128	120	127	106	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	+0.86	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	+0.86	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page