

TAMPICO INTL, Mexico

WMO: 765493

Lat: 22.296N

Lon: 97.866W

Elev: 24

StdP: 101.03

Time Zone: -6.00 (MEX)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.0	11.9	2.0	4.4	15.0	4.8	5.4	15.2	13.6	17.0	12.6	17.5	4.1	0	0.380

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.6	34.6	27.0	33.8	26.7	33.0	26.5	28.3	32.4	27.7	31.6	27.2	30.9	4.4	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.2	23.0	30.4	26.8	22.4	29.8	26.2	21.7	29.2	91.3	32.5	88.3	32.0	86.3	31.2	33.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.0	9.9	8.6	DB	7.9	38.2	2.6	2.4	6.0	40.0	4.5	41.3	3.1	42.7	1.2	44.4	
			WB	5.1	30.3	2.0	1.2	3.6	31.1	2.5	31.8	1.3	32.5	-0.1	33.4	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	25.4	19.4	21.3	23.2	25.8	28.3	29.3	29.1	29.4	28.3	26.3	23.3	20.5
	DBStd	4.35	3.54	3.49	3.02	2.39	1.80	1.44	1.42	1.40	1.63	2.41	2.96	3.51
	HDD10.0	1	1	0	0	0	0	0	0	0	0	0	0	1
	HDD18.3	76	31	14	4	1	0	0	0	0	0	1	4	21
	CDD10.0	5607	292	315	409	475	568	578	592	601	548	505	399	324
	CDD18.3	2641	64	96	156	226	309	328	333	343	298	247	154	87
	CDH23.3	24466	167	340	742	1641	3172	3826	3892	4069	3258	2190	866	303
	CDH26.7	8801	16	47	151	442	1106	1596	1616	1752	1224	661	156	35
Wind	WSAvg	3.6	3.4	3.7	4.2	4.3	4.4	3.8	3.2	3.1	3.0	3.4	3.3	3.3
Precipitation	PrecAvg	1120	34	21	21	23	42	165	162	167	278	127	45	28
	PrecMax	1702	240	80	119	114	139	500	534	372	617	338	183	100
	PrecMin	755	0	2	0	2	3	40	25	7	59	0	0	0
	PrecStd	247	44	24	24	26	33	114	134	97	135	85	38	25
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.2	30.0	31.8	34.0	35.0	35.2	35.1	35.7	34.7	33.2	31.0	29.2
		MCWB	22.3	22.8	24.5	25.8	27.6	27.3	27.8	27.7	26.9	26.6	25.2	23.5
	2%	DB	26.2	28.0	29.6	31.5	33.1	34.0	33.9	34.1	33.2	32.1	29.4	27.6
		MCWB	21.4	22.6	23.6	25.2	26.7	26.9	26.8	26.8	26.6	26.0	24.1	22.8
	5%	DB	25.1	26.8	28.1	30.2	32.1	33.1	32.9	33.1	32.2	31.0	28.3	26.2
		MCWB	20.8	22.1	23.0	24.7	26.1	26.5	26.5	26.6	26.2	25.5	23.4	22.1
	10%	DB	24.0	25.4	27.0	29.1	31.1	32.1	32.1	32.3	31.6	30.0	27.2	25.0
		MCWB	20.1	21.3	22.3	24.1	25.8	26.2	26.1	26.3	26.0	25.0	22.8	21.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.3	24.4	25.5	27.2	28.7	29.1	29.0	29.0	28.6	27.9	26.1	24.6
		MCDB	26.4	28.1	29.8	31.5	33.2	33.4	33.4	33.7	32.2	31.3	29.1	27.6
	2%	WB	22.4	23.4	24.4	26.1	27.5	27.9	27.7	27.9	27.6	27.0	25.2	23.8
		MCDB	25.0	26.3	28.0	30.1	31.4	31.7	32.1	31.9	31.1	30.1	27.9	26.0
	5%	WB	21.7	22.7	23.7	25.4	26.9	27.3	27.1	27.3	27.0	26.3	24.5	23.1
		MCDB	24.1	25.2	26.9	28.9	30.1	31.0	31.0	31.1	30.5	29.3	27.2	25.3
	10%	WB	21.1	22.2	23.2	24.8	26.4	26.9	26.7	26.9	26.5	25.8	23.8	22.4
		MCDB	23.2	24.5	25.9	27.9	29.4	30.4	30.3	30.5	29.9	28.8	26.5	24.5
Mean Daily Temperature Range	5% DB	MDBR	7.6	7.9	7.7	7.9	7.4	7.3	7.3	7.6	7.0	7.6	7.6	7.6
		MCDBR	9.0	8.9	8.6	8.6	7.8	7.9	7.9	8.2	7.9	8.2	8.3	8.9
		MCWBR	5.0	4.4	4.4	4.3	3.6	3.4	3.5	3.3	3.5	3.8	4.3	5.0
	5% WB	MCDBR	8.2	8.1	8.2	8.1	7.4	7.4	7.5	7.8	7.4	7.4	7.5	7.9
		MCWBR	5.1	4.4	4.5	4.4	3.7	3.6	3.6	3.5	3.7	4.1	4.7	5.1
Clear-Sky Solar Irradiance	taub	0.400	0.414	0.438	0.493	0.527	0.462	0.458	0.446	0.445	0.420	0.410	0.398	
	taud	2.391	2.349	2.284	2.144	2.065	2.291	2.317	2.350	2.338	2.406	2.389	2.403	
	Ebn at Noon	864	875	868	822	788	833	838	851	849	858	847	851	
	Edh at Noon	110	121	135	157	169	134	130	126	126	113	109	105	
All-Sky Solar Radiation	RadAvg	3.26	4.03	4.91	5.68	5.96	6.06	5.83	5.84	5.03	4.53	3.69	3.18	
	RadStd	0.37	0.44	0.47	0.38	0.29	0.37	0.51	0.28	0.40	0.38	0.40	0.33	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	+0.48	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (1 neighbor)	N/A	N/A	N/A	+0.48	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page