

TEPIC, Mexico

WMO: 765560

Lat: 21.5189N

Lon: 104.8839W

Elev: 3002

StdP: 13.17

Time Zone: -7.00 (MEC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	39.6	43.0	34.3	32.3	55.2	37.7	37.1	57.1	16.6	73.6	14.3	74.6	0.2	200	0.277

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	22.3	91.6	69.5	90.0	69.7	89.2	69.7	78.0	85.4	76.8	84.4	75.7	83.0	8.3	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
75.9	151.6	82.6	74.8	146.1	81.4	73.7	140.6	79.8	44.0	85.5	42.9	84.6	41.7	82.8	85.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
14.5	12.6	11.3	33.8	95.4	3.2	1.5	31.5	96.5	29.6	97.4	27.8	98.2	25.5	99.3		
			33.1	82.1	2.9	1.6	31.0	83.2	29.3	84.1	27.6	85.0	25.5	86.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	70.6	62.7	64.1	65.3	68.6	72.4	76.6	76.5	76.7	76.2	74.7	68.9	63.8
	DBStd	6.14	3.65	3.34	3.25	2.95	3.19	2.43	1.90	1.77	1.92	2.97	3.79	3.71
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	256	90	49	35	5	0	0	0	0	0	0	11	66
	CDD50	7511	393	396	475	559	693	799	821	827	787	767	566	428
	CDD65	2293	18	25	45	114	228	349	356	362	337	302	127	30
	CDH74	23452	877	1187	1896	2766	3478	2734	2228	2177	1808	2008	1416	877
	CDH80	8265	154	320	684	1253	1677	1087	728	665	514	622	398	163
Wind	WSAvg	4.2	4.0	4.3	4.7	5.0	5.2	4.8	3.9	3.7	3.8	3.7	3.8	3.6
Precipitation	PrecAvg	49.5	0.9	0.7	0.2	0.0	0.2	6.3	14.3	12.5	9.1	3.0	0.7	1.1
	PrecMax	98.7	4.0	5.4	3.5	1.8	3.1	16.7	29.4	29.5	25.2	11.3	5.6	5.4
	PrecMin	26.6	0.0	0.0	0.0	0.0	0.0	1.0	4.3	5.2	1.8	0.0	0.0	0.0
	PrecStd	17.0	1.2	1.3	0.6	0.3	0.6	3.6	5.6	5.0	4.5	2.6	1.2	1.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	86.1	88.4	90.6	92.8	93.5	93.1	91.1	89.8	89.5	89.9	88.2	86.0
		MCWB	64.3	65.3	66.4	66.7	68.4	73.5	74.2	75.3	74.4	72.3	68.8	66.6
	2%	DB	83.9	86.0	88.0	91.0	91.6	90.7	88.1	87.7	86.9	87.8	86.3	83.9
		MCWB	63.7	64.6	65.6	66.4	68.7	73.1	74.7	75.1	74.1	71.8	67.9	65.4
	5%	DB	82.0	84.1	86.2	89.3	90.0	88.5	86.2	86.0	85.6	85.9	84.5	82.0
		MCWB	63.2	64.2	64.9	66.1	68.8	73.1	73.9	74.4	74.1	71.8	67.5	64.4
	10%	DB	79.5	82.1	84.2	87.5	88.5	86.3	84.4	84.2	83.2	83.9	82.4	79.4
		MCWB	62.9	63.8	64.6	66.1	68.9	72.7	73.7	74.3	74.0	72.1	67.5	64.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.4	71.1	72.6	73.9	77.0	79.3	79.0	79.2	78.8	78.3	75.0	71.9
		MCDB	78.9	81.6	84.5	86.2	87.1	86.9	86.4	86.4	85.5	84.9	82.9	80.2
	2%	WB	68.3	68.8	70.3	71.5	74.6	77.0	77.1	77.3	77.0	76.5	72.9	69.4
		MCDB	77.8	80.5	82.8	85.0	86.5	86.1	85.0	84.4	83.7	83.0	80.7	78.4
	5%	WB	66.4	67.0	68.4	69.7	72.9	75.5	75.6	76.0	75.6	75.1	71.4	67.8
		MCDB	76.7	79.0	81.4	83.9	85.0	84.5	82.8	82.8	81.9	81.2	78.8	77.1
	10%	WB	64.9	65.5	66.5	68.2	71.4	74.3	74.5	74.9	74.6	73.9	69.9	66.0
		MCDB	75.1	77.4	79.4	83.2	83.1	82.7	81.4	81.3	80.5	79.6	77.0	75.0
Mean Daily Temperature Range	5% DB	MDBR	35.5	37.1	39.5	39.8	35.1	22.3	19.1	18.3	17.2	20.9	29.3	33.4
		MCDBR	39.4	40.6	43.0	41.9	37.0	25.9	21.1	19.9	19.4	23.1	31.9	37.1
		MCWBR	24.2	23.8	25.2	23.4	20.7	13.8	11.3	10.9	10.5	12.4	18.5	23.0
	5% WB	MCDBR	35.4	38.1	39.5	39.2	33.4	22.4	19.9	18.8	18.2	20.6	28.5	33.9
		MCWBR	23.4	23.8	24.6	23.8	20.0	12.6	11.3	10.7	10.3	11.9	17.7	22.1
Clear-Sky Solar Irradiance	taub	0.305	0.315	0.306	0.326	0.399	0.427	0.411	0.409	0.402	0.356	0.315	0.312	
	taud	2.582	2.532	2.551	2.470	2.313	2.295	2.377	2.377	2.390	2.525	2.614	2.587	
	Ebn at Noon	309	311	317	309	284	274	279	280	282	293	304	303	
	Edh at Noon	29	32	33	36	42	42	39	39	38	32	28	28	
All-Sky Solar Radiation	RadAvg	1471	1772	2136	2353	2392	2109	1988	1944	1729	1711	1567	1400	
	RadStd	121	150	80	100	81	101	118	77	102	105	97	79	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-4	+252	+157

Nomenclature: See separate page