

TEPIC, Mexico

WMO: 765560

Lat: 21.5189N

Lon: 104.8839W

Elev: 915

StdP: 90.81

Time Zone: -7.00 (MEC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 4.2	(c) 6.1	(d) 1.3	(e) 4.6	(f) 12.9	(g) 3.2	(h) 5.3	(i) 14.0	(j) 7.4	(k) 23.1	(l) 6.4	(m) 23.7	(n) 0.1	(o) 200	(p) 0.277

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 6	(b) 12.4	(c) 33.1	(d) 20.8	(e) 32.2	(f) 20.9	(g) 31.8	(h) 21.0	(i) 25.6	(j) 29.7	(k) 24.9	(l) 29.1	(m) 24.3	(n) 28.3	(o) 3.7	(p) 0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.4	21.7	28.1	23.8	20.9	27.4	23.2	20.1	26.6	84.4	29.7	81.8	29.2	79.1	28.2	29.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.5	5.6	5.0	1.0	35.2	1.8	0.8	-0.3	35.8	-1.3	36.3	-2.3	36.8	-3.6	37.4		
			0.6	27.8	1.6	0.9	-0.6	28.4	-1.5	28.9	-2.4	29.4	-3.6	30.1		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	21.4	17.0	17.9	18.5	20.3	22.4	24.8	24.7	24.8	24.6	23.7	20.5	17.7
	DBStd	3.41	2.03	1.85	1.80	1.64	1.77	1.35	1.06	0.98	1.07	1.65	2.10	2.06
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	142	50	27	19	3	0	0	0	0	0	0	6	37
	CDD10.0	4173	218	220	264	311	385	444	456	459	437	426	314	238
	CDD18.3	1274	10	14	25	63	127	194	198	201	187	168	71	17
	CDH23.3	13029	487	659	1053	1537	1932	1519	1238	1209	1004	1116	787	487
CDH26.7	4592	86	178	380	696	932	604	404	369	286	346	221	91	
Wind	WSAvg	1.9	1.8	1.9	2.1	2.2	2.3	2.1	1.7	1.7	1.7	1.6	1.7	1.6
Precipitation	PrecAvg	1257	22	18	4	1	5	160	362	317	231	76	18	28
	PrecMax	2506	102	138	88	46	80	425	746	750	639	287	143	138
	PrecMin	675	0	0	0	0	0	26	108	133	45	0	0	0
	PrecStd	432	31	34	16	7	16	91	143	128	114	67	31	40
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.1	31.3	32.5	33.8	34.2	34.0	32.8	32.1	31.9	32.2	31.2	30.0
		MCWB	17.9	18.5	19.1	19.3	20.2	23.1	23.5	24.0	23.6	22.4	20.4	19.2
	2%	DB	28.8	30.0	31.1	32.8	33.1	32.6	31.1	31.0	30.5	31.0	30.2	28.8
		MCWB	17.6	18.1	18.7	19.1	20.4	22.9	23.7	23.9	23.4	22.1	20.0	18.5
	5%	DB	27.8	28.9	30.1	31.9	32.2	31.4	30.1	30.0	29.8	30.0	29.2	27.8
		MCWB	17.3	17.9	18.3	18.9	20.4	22.8	23.3	23.6	23.4	22.1	19.7	18.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	10%	DB	26.4	27.8	29.0	30.8	31.4	30.2	29.1	29.0	28.4	28.9	28.0	26.4
		MCWB	17.2	17.7	18.1	18.9	20.5	22.6	23.2	23.5	23.3	22.3	19.7	17.9
	0.4%	WB	21.9	21.7	22.6	23.3	25.0	26.3	26.1	26.2	26.0	25.7	23.9	22.1
		MCDB	26.1	27.6	29.1	30.1	30.6	30.5	30.2	30.2	29.7	29.4	28.3	26.8
	2%	WB	20.2	20.4	21.3	22.0	23.7	25.0	25.0	25.2	25.0	24.7	22.7	20.8
		MCDB	25.5	26.9	28.2	29.5	30.3	30.1	29.4	29.1	28.7	28.3	27.1	25.8
Mean Daily Temperature Range	5% DB	WB	19.1	19.5	20.2	20.9	22.7	24.2	24.2	24.5	24.2	23.9	21.9	19.9
		MCDB	24.9	26.1	27.4	28.8	29.5	29.2	28.2	28.2	27.7	27.4	26.0	25.0
	5% WB	WB	18.3	18.6	19.2	20.1	21.9	23.5	23.6	23.9	23.7	23.3	21.1	18.9
		MCDB	24.0	25.2	26.4	28.5	28.4	28.1	27.4	27.4	27.0	26.5	25.0	23.9
	Clear-Sky Solar Irradiance	taub	0.305	0.315	0.306	0.326	0.399	0.427	0.411	0.409	0.402	0.356	0.315	0.312
		taud	2.582	2.532	2.551	2.470	2.313	2.295	2.377	2.377	2.390	2.525	2.614	2.587
Ebn at Noon		975	981	999	975	896	863	878	884	890	925	957	955	
Edh at Noon		90	101	103	114	132	133	123	123	120	100	87	87	
All-Sky Solar Radiation	RadAvg	4.64	5.58	6.73	7.42	7.54	6.65	6.27	6.13	5.45	5.39	4.94	4.41	
	RadStd	0.38	0.47	0.25	0.32	0.25	0.32	0.37	0.24	0.32	0.33	0.31	0.25	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-2	+140	+87

Nomenclature: See separate page