

GUANAJUATO, Mexico

WMO: 765770

Lat: 21.014N

Lon: 101.266W

Elev: 6558

StdP: 11.53

Time Zone: -6.00 (MEX)

Period: 94-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	42.5	44.9	27.5	27.3	57.4	30.8	31.9	57.0	17.9	62.2	14.2	66.0	0.3	0	0.305

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	25.3	89.9	69.1	87.6	68.0	85.6	67.0	76.4	84.5	74.5	82.9	72.4	80.9	4.2	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
74.3	164.9	82.9	72.1	152.5	81.1	70.0	141.5	79.2	45.6	84.5	43.3	82.8	41.1	81.1	84.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
13.7	11.3	9.3	DB	36.6	93.7	2.7	1.5	34.7	94.7	33.2	95.6	31.7	96.4	29.8	97.5	(4)
			WB	32.0	75.6	3.0	4.1	29.8	78.5	28.1	80.9	26.4	83.2	24.2	86.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	66.8	59.4	62.7	66.3	70.7	73.1	71.9	69.7	69.8	68.7	66.4	63.1	60.1	(6)
		DBStd	5.48	3.26	3.74	3.89	3.57	3.34	3.43	2.55	2.40	2.35	3.43	3.33	3.26	(7)
		HDD50	2	1	0	0	0	0	0	0	0	0	0	0	1	(8)
		HDD65	541	175	78	29	3	0	2	1	3	25	72	153		(9)
		CDD50	6152	292	357	505	621	717	658	611	613	561	510	393	314	(10)
		CDD65	1217	1	14	69	175	253	208	148	149	114	70	15	1	(11)
		CDH74	9907	43	300	897	1849	2370	1574	855	837	521	452	155	54	(12)
(13)		CDH80	2644	0	23	165	636	908	531	148	133	52	44	4	0	(13)
(14)	Wind	WSAvg	2.5	2.1	2.6	2.7	2.6	2.5	2.7	2.7	2.8	2.7	2.5	2.3	1.8	(14)
(15)	Precipitation	PrecAvg	27.4	0.7	0.4	0.3	0.4	1.4	5.2	6.4	6.0	5.2	1.9	0.4	0.4	(15)
(16)		PrecMax	49.1	6.4	2.6	2.0	3.1	5.1	22.1	21.3	19.3	12.6	5.8	2.7	1.6	(16)
(17)		PrecMin	11.6	0.0	0.0	0.0	0.0	0.0	0.4	1.2	0.8	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	10.1	1.2	0.5	0.4	0.6	1.2	4.1	3.8	3.5	3.0	1.6	0.6	0.4	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	DB	77.7	82.8	86.6	91.4	93.2	92.0	86.3	86.0	84.0	83.9	80.3	77.9		(19)
(20)		MCWB	62.0	62.6	66.9	67.9	71.5	73.1	68.0	70.2	67.3	67.2	64.8	61.5		(20)
(21)		DB	75.0	80.1	84.0	88.7	90.2	88.9	83.6	83.2	81.6	81.2	77.8	75.4		(21)
(22)		MCWB	59.4	61.5	64.7	67.4	69.4	69.9	68.2	69.1	67.2	66.2	63.5	61.2		(22)
(23)		DB	72.8	77.8	81.7	86.3	87.9	86.0	81.5	81.2	79.6	79.0	75.7	73.3		(23)
(24)		MCWB	57.8	60.7	64.1	65.5	67.9	69.5	67.5	68.4	66.9	65.5	62.4	60.5		(24)
(25)		DB	70.6	75.5	79.3	84.0	85.4	82.9	79.1	79.1	77.3	76.6	73.5	71.0		(25)
(26)		MCWB	56.8	59.6	62.1	65.3	66.7	67.7	67.2	67.5	66.1	64.0	61.2	58.8		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	WB	69.9	71.5	76.1	76.8	78.5	79.5	77.1	76.4	75.1	73.8	71.4	68.9		(27)
(28)		MCDB	74.8	77.1	83.9	86.1	88.2	87.5	82.4	82.0	80.0	79.1	75.9	74.5		(28)
(29)		WB	64.2	67.5	71.9	73.8	75.0	75.8	73.7	73.4	71.7	70.0	67.6	65.5		(29)
(30)		MCDB	71.0	75.4	79.5	84.2	86.4	85.1	79.9	79.9	77.4	78.0	74.4	71.9		(30)
(31)		WB	60.9	64.0	67.6	70.7	72.1	73.1	70.6	70.8	69.2	67.4	65.2	62.7		(31)
(32)		MCDB	68.9	74.0	76.6	82.4	84.2	82.7	77.9	78.5	76.5	76.4	73.2	70.3		(32)
(33)		WB	58.1	60.9	64.0	67.4	69.3	69.8	68.2	68.3	67.0	65.3	62.6	59.8		(33)
(34)		MCDB	67.7	72.8	76.2	80.5	81.8	79.1	76.0	76.6	75.1	74.3	71.3	69.0		(34)
(35)	Mean Daily Temperature Range	MDBR	23.6	25.5	26.2	26.7	25.3	21.7	20.0	19.7	18.2	21.1	23.3	24.0		(35)
(36)		5% DB	26.8	28.2	29.2	29.6	28.3	26.9	23.5	23.1	22.2	25.2	25.6	26.7		(36)
(37)		MCWBR	15.8	16.4	17.0	15.5	14.5	14.0	12.2	13.1	12.1	14.2	14.8	16.0		(37)
(38)		5% WB	25.1	26.5	27.8	28.0	26.5	24.9	21.5	21.8	19.4	22.5	23.4	25.5		(38)
(39)		MCWBR	19.1	19.7	21.1	19.4	17.6	17.3	15.6	15.7	13.6	14.8	16.9	18.8		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.304	0.315	0.314	0.347	0.405	0.379	0.373	0.360	0.360	0.342	0.309	0.305		(40)
(41)		taud	2.463	2.427	2.428	2.331	2.218	2.323	2.363	2.402	2.404	2.445	2.489	2.489		(41)
(42)		Ebn at Noon	309	311	314	303	283	287	289	295	295	298	305	305		(42)
(43)		Edh at Noon	32	36	37	42	46	41	40	38	37	35	31	30		(43)
(44)	All-Sky Solar Radiation	RadAvg	1520	1811	2126	2282	2213	2030	1974	1979	1742	1711	1575	1462		(44)
(45)		RadStd	104	166	120	98	101	114	141	102	115	108	125	89		(45)

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (6 neighbors)	N/A	N/A	N/A	N/A	-1.01	N/A	N/A	-202	+356	N/A	(47)

Nomenclature: See separate page