

GUANAJUATO INTL, Mexico

WMO: 765773

Lat: 20.983N

Lon: 101.483W

Elev: 5956

StdP: 11.80

Time Zone: -6.00 (MEX)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	39.2	42.5	10.1	11.5	69.5	14.2	14.1	67.6	22.7	65.3	20.8	64.5	3.4	30	0.381

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	31.2	93.3	58.4	91.3	58.3	89.3	58.2	67.1	78.8	66.3	77.3	65.5	76.6	7.9	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.6	114.2	67.2	63.2	108.7	67.1	62.7	106.7	67.1	35.3	78.2	34.6	77.5	33.8	77.2	75.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
20.7	17.9	15.0	DB	32.8	97.3	2.3	2.9	31.2	99.4	29.8	101.1	28.5	102.7	26.9	104.8	(4)
			WB	27.4	69.5	2.8	1.6	25.4	70.7	23.8	71.6	22.2	72.5	20.2	73.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	67.4	59.7	63.1	66.7	71.3	74.2	73.3	70.5	70.3	69.3	67.3	63.1	60.3
	DBStd	5.67	3.43	3.57	3.79	3.49	3.08	3.26	2.27	2.08	2.24	3.22	3.60	3.38
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	502	166	70	25	1	0	0	0	0	1	16	75	148
	CDD50	6364	301	367	517	638	750	698	636	628	580	536	394	319
	CDD65	1389	1	17	77	188	285	248	171	163	131	87	19	2
	CDH74	16214	281	738	1632	2867	3444	2237	1101	1156	862	976	597	323
	CDH80	5501	21	168	545	1292	1640	905	231	224	142	220	87	26
Wind	WSAvg	5.5	5.3	5.7	6.2	6.0	6.0	6.2	5.4	5.1	5.0	5.2	5.2	4.8
Precipitation	PrecAvg	28.5	0.7	0.2	0.3	0.3	1.5	4.7	7.2	6.0	5.1	1.8	0.4	0.2
	PrecMax	40.4	5.2	0.9	1.5	1.6	3.4	8.1	14.4	9.3	8.9	4.2	1.7	0.8
	PrecMin	16.6	0.0	0.0	0.0	0.0	0.0	1.3	3.8	3.6	1.8	0.1	0.0	0.0
	PrecStd	6.5	1.3	0.3	0.5	0.4	1.1	1.8	3.0	1.8	2.0	1.2	0.4	0.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	82.4	87.9	91.1	96.4	98.2	96.5	88.1	87.7	86.4	88.0	84.5	82.6
		MCWB	54.2	55.6	56.4	58.6	60.1	59.7	62.3	62.6	62.9	60.4	57.8	55.4
	2%	DB	80.2	84.3	88.1	92.8	93.5	91.7	84.4	84.3	83.8	84.4	82.5	80.3
		MCWB	54.3	54.9	55.9	57.3	58.7	59.4	62.6	63.5	63.9	61.0	57.2	55.4
	5%	DB	77.1	82.1	85.8	89.9	91.4	88.3	82.4	82.4	81.0	82.5	80.4	78.4
		MCWB	54.6	54.9	55.6	56.9	58.9	60.6	62.7	63.6	63.6	60.8	57.6	55.0
	10%	DB	74.8	78.9	82.7	87.9	89.3	84.6	80.4	80.6	79.1	80.3	77.5	75.1
		MCWB	54.0	54.6	54.9	56.5	58.9	61.3	63.5	63.8	63.4	60.8	57.0	53.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	61.2	63.9	64.3	64.5	67.7	68.0	67.8	67.9	67.8	66.5	63.0	60.8
		MCDB	73.9	75.9	81.6	86.5	85.6	81.0	77.6	79.9	79.6	79.5	76.9	77.0
	2%	WB	57.7	59.2	59.8	61.7	64.5	66.1	66.4	66.5	66.6	64.9	61.4	58.5
		MCDB	73.2	76.8	80.2	83.2	83.0	77.5	76.2	77.8	77.2	77.5	75.7	74.6
	5%	WB	56.2	57.5	58.0	59.6	62.9	64.8	65.5	65.7	65.7	64.0	60.0	56.8
		MCDB	72.5	75.9	79.2	82.2	81.4	76.7	75.6	76.7	75.8	76.1	75.0	73.1
	10%	WB	54.7	55.8	56.5	58.2	61.7	64.1	64.6	64.8	64.7	62.7	58.6	55.3
		MCDB	71.6	74.9	78.3	81.7	80.3	76.1	75.1	75.8	74.6	74.2	73.6	72.2
Mean Daily Temperature Range	5% DB	MDBR	31.1	32.3	33.8	34.3	31.2	25.0	21.8	22.5	22.5	27.2	31.1	31.6
		MCDBR	35.1	37.1	37.6	36.7	34.6	30.9	25.3	25.6	25.5	31.2	34.3	35.0
		MCWBR	15.8	15.4	14.7	13.4	12.0	9.7	8.7	9.7	10.2	12.3	14.1	15.3
	5% WB	MCDBR	30.0	31.1	32.8	32.5	28.2	22.2	20.8	21.9	21.5	24.8	28.7	30.0
		MCWBR	15.4	15.6	14.4	13.0	10.8	8.2	8.8	9.0	9.0	10.0	12.5	14.2
Clear-Sky Solar Irradiance	taub	0.310	0.324	0.319	0.356	0.417	0.392	0.387	0.374	0.372	0.350	0.316	0.313	
	taud	2.455	2.410	2.421	2.310	2.194	2.297	2.337	2.373	2.384	2.436	2.478	2.472	
	Ebn at Noon	307	308	313	300	279	284	285	291	292	296	303	302	
	Edh at Noon	33	36	37	43	47	42	41	39	38	35	32	31	
All-Sky Solar Radiation	RadAvg	1530	1819	2137	2294	2223	2038	1978	1983	1755	1726	1591	1469	
	RadStd	104	166	119	98	99	115	136	104	115	106	124	88	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	-1.01	N/A	N/A	N/A	N/A	N/A
Regional (7 neighbors)		+0.85	+2.00	-2.97	N/A	-0.54	N/A	N/A	-198	+394	+216

Nomenclature: See separate page