

CANCUN INTL, Mexico

WMO: 765950

Lat: 21.0289N

Lon: 86.8522W

Elev: 30

StdP: 14.68

Time Zone: -5.00 (W05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	55.7	58.8	51.9	57.3	61.4	53.9	61.8	64.0	20.5	80.5	18.8	79.9	2.7	300	0.371

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.1	93.2	80.6	91.7	80.1	91.1	79.9	82.7	89.8	81.9	88.7	81.1	87.5	11.9	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.9	160.5	86.3	80.4	158.2	86.1	79.2	151.5	85.0	46.5	89.6	45.6	90.4	44.9	88.0	91.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.7	17.9	16.1	51.2	94.3	3.5	3.1	48.7	96.5	46.7	98.4	44.7	100.1	42.2	102.3		
(5)			50.5	84.4	3.1	2.1	48.3	85.9	46.5	87.1	44.8	88.2	42.5	89.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	79.0	73.5	75.1	76.4	79.1	81.8	82.7	83.0	83.0	82.1	80.1	76.4	75.0		
	DBStd	4.92	4.69	4.47	4.62	3.86	2.94	2.42	2.03	2.07	2.35	3.23	3.90	4.44		
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD65	5	2	1	1	0	0	0	0	0	0	0	0	1		
	CDD50	10595	729	702	818	874	984	981	1022	1022	964	932	793	774		
	CDD65	5125	266	283	354	424	519	531	557	557	514	467	343	310		
	CDH74	51449	1761	2149	3010	4237	5832	6079	6722	6575	5544	4521	2767	2252		
	CDH80	18093	310	456	754	1304	2170	2372	2921	2893	2247	1540	674	452		
(14) Wind	WSAvg	7.5	7.3	7.9	9.2	9.7	9.2	8.3	6.7	6.2	5.8	6.3	6.4	6.7		
(15) Precipitation	PrecAvg	41.1	2.4	1.5	1.5	1.9	2.9	5.7	3.0	4.2	6.3	6.1	3.5	2.2		
	PrecMax	54.2	6.7	6.2	3.5	6.1	8.7	10.2	5.5	7.3	13.7	14.6	9.3	4.6		
	PrecMin	28.1	0.4	0.3	0.4	0.3	0.6	1.1	0.8	1.2	2.7	1.3	0.7	0.7		
	PrecStd	7.6	1.3	1.1	0.8	1.2	1.9	2.6	1.3	1.6	2.7	3.0	2.1	1.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	86.4	88.0	89.6	91.2	93.1	91.8	94.5	94.8	93.5	91.6	89.7	88.0		
		MCWB	76.8	76.6	77.6	77.8	78.8	80.1	79.4	80.7	81.1	81.3	80.1	78.9		
	2%	DB	84.5	86.1	87.7	89.4	91.3	91.3	92.8	93.1	91.7	89.8	87.6	85.8		
		MCWB	75.4	76.3	76.5	77.2	78.6	80.0	80.2	81.0	80.8	80.0	78.4	77.2		
	5%	DB	82.8	84.3	85.9	87.8	89.7	89.8	91.3	91.5	91.0	88.2	85.8	84.2		
		MCWB	74.3	75.2	76.0	77.1	78.3	79.6	80.0	80.3	80.5	79.4	77.3	75.9		
	10%	DB	82.1	82.7	84.2	86.1	88.0	88.2	89.7	89.8	89.4	86.4	84.0	82.5		
		MCWB	73.8	73.9	74.6	76.5	77.9	79.2	79.5	79.5	79.8	78.4	75.8	74.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.0	79.1	79.8	80.7	81.6	82.7	83.2	83.6	83.7	83.0	81.4	80.3		
		MCDB	84.9	85.9	86.5	86.7	88.3	89.4	90.2	91.6	89.7	89.3	87.5	86.0		
	2%	WB	77.2	77.4	78.1	79.5	80.4	81.6	81.9	82.5	82.4	81.4	79.7	78.5		
		MCDB	83.2	84.1	84.9	85.8	86.9	88.0	88.9	89.8	89.7	87.3	85.0	83.4		
	5%	WB	75.9	76.4	77.0	78.5	79.7	80.8	81.0	81.5	81.3	80.4	78.7	77.4		
		MCDB	81.6	82.7	83.8	85.0	86.3	86.8	87.5	88.3	87.9	86.0	83.6	82.3		
	10%	WB	74.8	75.3	75.9	77.4	79.0	80.0	80.3	80.6	80.4	79.6	77.4	76.3		
		MCDB	80.1	81.1	82.1	83.9	85.7	85.8	86.6	86.9	86.4	84.8	82.1	81.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	15.0	15.1	14.9	14.3	13.1	11.8	14.1	14.8	14.3	13.5	14.6	14.5		
		MCDBR	14.8	15.5	15.5	15.9	15.1	13.6	16.8	16.9	16.7	14.4	15.0	14.3		
	5% WB	MCWBR	8.1	7.9	7.6	7.4	6.1	5.7	7.0	7.2	7.5	7.0	7.7	7.7		
		MCWBR	12.9	13.3	12.8	11.5	12.2	11.6	14.2	15.2	14.9	13.0	12.7	12.0		
(40) Clear-Sky Solar Irradiance	taub	taub	0.368	0.379	0.391	0.431	0.449	0.467	0.481	0.445	0.426	0.422	0.389	0.384		
		taud	2.552	2.513	2.462	2.339	2.334	2.308	2.247	2.385	2.441	2.442	2.502	2.514		
	Ebn at Noon	Ebn at Noon	288	291	290	278	270	263	259	271	276	273	278	278		
		Edh at Noon	30	33	36	41	41	42	44	39	36	35	31	30		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1272	1550	1836	2011	2014	1821	1996	1934	1714	1504	1331	1227		
	RadStd	RadStd	83	91	66	95	127	115	107	94	106	109	64	69		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	-1.17	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page