

CANCUN INTL, Mexico

WMO: 765950

Lat: 21.0289N

Lon: 86.8522W

Elev: 9

StdP: 101.22

Time Zone: -5.00 (W05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.2	14.9	11.0	8.2	16.4	12.1	8.8	17.8	9.2	27.0	8.4	26.6	1.2	300	0.371

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.8	34.0	27.0	33.2	26.7	32.9	26.6	28.2	32.1	27.7	31.5	27.3	30.9	5.3	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.1	22.9	30.2	26.9	22.6	30.0	26.2	21.6	29.4	90.4	32.0	88.3	32.4	86.6	31.1	32.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.8	8.0	7.2	10.7	34.6	1.9	1.7	9.3	35.9	8.2	36.9	7.1	37.8	5.7	39.1		
(5)			10.3	29.1	1.7	1.1	9.0	29.9	8.0	30.6	7.1	31.2	5.9	32.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	26.1	23.1	23.9	24.7	26.2	27.6	28.2	28.3	28.3	27.9	26.7	24.7	23.9
	DBStd	2.73	2.61	2.49	2.57	2.14	1.63	1.35	1.13	1.15	1.31	1.80	2.17	2.47
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	3	1	1	1	0	0	0	0	0	0	0	0	1
	CDD10.0	5886	405	390	454	486	547	545	568	536	518	441	430	
	CDD18.3	2847	148	157	197	236	288	295	309	309	286	259	191	172
	CDH23.3	28583	978	1194	1672	2354	3240	3377	3734	3653	3080	2512	1537	1251
	CDH26.7	10052	172	253	419	724	1206	1318	1623	1607	1248	856	374	251
Wind	WSAvg	3.3	3.2	3.6	4.1	4.3	4.1	3.7	3.0	2.8	2.6	2.8	2.9	3.0
Precipitation	PrecAvg	1045	60	38	38	49	73	146	76	106	159	154	89	56
	PrecMax	1376	171	158	89	155	221	259	140	185	348	370	235	116
	PrecMin	714	11	7	9	8	14	29	20	30	68	34	18	18
	PrecStd	194	34	28	21	31	47	66	34	40	68	77	54	29
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.2	31.1	32.0	32.9	33.9	33.2	34.7	34.9	34.2	33.1	32.0	31.1
		MCWB	24.9	24.8	25.3	25.4	26.0	26.7	26.3	27.1	27.3	27.4	26.7	26.1
	2%	DB	29.2	30.0	31.0	31.9	33.0	33.0	33.8	33.9	33.2	32.1	30.9	29.9
		MCWB	24.1	24.6	24.7	25.1	25.9	26.7	26.8	27.2	27.1	26.7	25.8	25.1
	5%	DB	28.2	29.1	29.9	31.0	32.1	32.1	33.0	33.0	32.8	31.2	29.9	29.0
		MCWB	23.5	24.0	24.5	25.0	25.7	26.5	26.7	26.8	26.9	26.3	25.2	24.4
	10%	DB	27.8	28.1	29.0	30.1	31.1	31.2	32.1	32.1	31.9	30.2	28.9	28.1
		MCWB	23.2	23.3	23.7	24.7	25.5	26.2	26.4	26.4	26.6	25.8	24.3	23.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.1	26.1	26.5	27.0	27.6	28.2	28.4	28.7	28.7	28.3	27.4	26.8
		MCDB	29.4	29.9	30.3	30.4	31.3	31.9	32.3	33.1	32.1	31.8	30.9	30.0
	2%	WB	25.1	25.2	25.6	26.4	26.9	27.6	27.7	28.0	28.0	27.5	26.5	25.9
		MCDB	28.4	29.0	29.4	29.9	30.5	31.1	31.6	32.1	32.1	30.7	29.5	28.6
	5%	WB	24.4	24.7	25.0	25.9	26.5	27.1	27.2	27.5	27.4	26.9	25.9	25.2
		MCDB	27.5	28.2	28.8	29.4	30.2	30.5	30.8	31.3	31.1	30.0	28.7	27.9
	10%	WB	23.8	24.1	24.4	25.2	26.1	26.7	26.8	27.0	26.9	26.5	25.2	24.6
		MCDB	26.7	27.3	27.9	28.8	29.8	29.9	30.3	30.5	30.2	29.4	27.8	27.3
Mean Daily Temperature Range	5% DB	MDBR	8.3	8.4	8.3	7.9	7.3	6.5	7.8	8.2	7.9	7.5	8.1	8.1
		MCDBR	8.2	8.6	8.6	8.8	8.4	7.5	9.3	9.4	9.3	8.0	8.3	8.0
		MCWBR	4.5	4.4	4.2	4.1	3.4	3.2	3.9	4.0	4.1	3.9	4.3	4.3
	5% WB	MCDBR	7.2	7.4	7.1	6.4	6.8	6.4	7.9	8.5	8.3	7.2	7.0	6.7
		MCWBR	4.2	4.1	3.8	3.5	3.3	3.1	3.6	4.0	4.2	3.8	4.0	4.0
Clear-Sky Solar Irradiance	taub		0.368	0.379	0.391	0.431	0.449	0.467	0.481	0.445	0.426	0.422	0.389	0.384
	taud		2.552	2.513	2.462	2.339	2.334	2.308	2.247	2.385	2.441	2.442	2.502	2.514
	Ebn at Noon		907	916	914	877	852	829	818	853	869	861	876	876
	Edh at Noon		95	104	113	130	129	132	140	122	114	110	99	96
All-Sky Solar Radiation	RadAvg		4.01	4.89	5.79	6.34	6.35	5.74	6.29	6.10	5.40	4.74	4.20	3.87
	RadStd		0.26	0.29	0.21	0.30	0.40	0.36	0.34	0.30	0.33	0.34	0.20	0.22

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	-0.65	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page