

GUADALAJARA INTL, Mexico

WMO: 766133

Lat: 20.522N

Lon: 103.311W

Elev: 5016

StdP: 12.22

Time Zone: -6.00 (MEX)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	35.4	37.7	15.4	14.4	72.0	19.3	17.5	68.1	18.9	72.2	16.5	71.9	0.5	210	0.343

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	31.7	91.6	59.4	89.9	58.8	88.1	58.3	67.9	79.5	67.2	78.3	66.5	77.2	10.1	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.5	109.7	72.5	63.0	104.1	71.0	62.8	103.3	70.7	35.4	79.3	34.7	78.5	34.0	77.8	75.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.7	16.0	12.7	DB	31.4	95.3	3.1	2.5	29.1	97.1	27.3	98.5	25.5	99.9	23.2	101.7	(4)
(5)			WB	27.9	70.4	3.2	2.0	25.6	71.8	23.7	73.0	21.9	74.1	19.5	75.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	66.9	58.5	62.0	65.4	69.6	73.6	73.5	70.6	70.4	69.9	67.5	62.5	59.1
	DBStd	5.88	3.13	3.41	3.45	3.16	2.78	2.75	1.79	1.75	1.92	3.35	3.90	3.40
	HDD50	1	0	0	0	0	0	0	0	0	0	0	0	1
	HDD65	627	201	91	37	4	0	0	0	0	1	16	92	185
	CDD50	6171	265	336	477	587	732	706	638	633	598	542	376	281
	CDD65	1319	0	7	48	140	267	256	173	168	148	93	18	1
	CDH74	14985	299	790	1689	2810	3548	2028	807	758	663	753	537	303
	CDH80	4635	14	133	512	1214	1667	745	90	64	50	85	47	14
Wind	WSAvg	3.9	2.9	3.7	4.7	5.5	5.7	5.1	3.6	3.3	3.3	3.1	2.7	2.6
Precipitation	PrecAvg	35.5	0.7	0.4	0.2	0.2	0.9	6.8	9.1	7.3	6.1	2.0	0.4	0.2
	PrecMax	48.7	10.4	3.2	2.2	2.8	3.2	13.0	15.2	11.1	12.0	5.1	2.2	2.3
	PrecMin	23.1	0.0	0.0	0.0	0.0	0.0	2.2	4.6	2.9	2.5	0.0	0.0	0.0
	PrecStd	5.8	2.0	0.7	0.5	0.6	0.8	2.5	2.9	2.2	2.2	1.3	0.6	0.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	82.0	86.0	89.6	93.0	94.8	93.2	84.4	83.8	82.8	84.4	83.9	81.9
		MCWB	55.3	56.7	56.5	58.7	60.7	61.2	64.4	64.9	65.3	63.2	62.2	58.0
	2%	DB	79.2	82.8	87.6	91.1	91.8	90.0	82.4	82.0	81.0	82.4	80.9	79.1
		MCWB	54.7	55.6	56.1	58.0	59.5	61.5	64.7	65.2	64.9	62.7	59.8	56.3
	5%	DB	77.3	82.0	84.6	89.4	91.0	87.8	80.6	80.5	80.3	80.6	79.2	77.3
		MCWB	54.0	55.4	55.5	57.2	59.3	61.9	64.9	65.4	64.8	62.6	58.8	56.0
	10%	DB	75.2	79.2	82.7	87.6	89.3	84.3	78.9	78.8	78.6	78.8	77.3	75.2
		MCWB	53.5	54.7	55.1	56.6	58.9	63.1	64.8	65.2	64.7	62.3	58.4	55.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.4	60.8	61.0	62.7	67.0	68.7	68.4	69.1	68.6	67.8	65.2	62.4
		MCDB	75.0	79.3	82.2	84.6	85.0	81.8	79.7	79.7	79.4	79.9	79.5	76.7
	2%	WB	57.8	58.8	59.1	60.7	64.6	67.3	67.3	67.5	67.4	66.2	63.2	59.7
		MCDB	73.7	77.4	80.2	83.2	82.3	80.3	78.2	78.0	77.7	77.2	76.3	74.3
	5%	WB	56.5	57.4	57.6	59.2	63.2	66.2	66.4	66.8	66.6	65.0	61.8	57.9
		MCDB	72.4	76.7	79.6	82.9	80.6	78.7	76.8	76.7	76.4	75.5	74.5	73.1
	10%	WB	55.1	55.8	56.3	57.9	61.9	65.3	65.5	65.9	65.7	64.1	60.3	56.4
		MCDB	71.1	74.6	78.5	82.5	79.5	77.1	75.4	75.4	74.9	74.2	72.3	71.7
Mean Daily Temperature Range	5% DB	MDBR	34.5	35.2	36.1	35.9	31.7	22.2	18.4	18.4	18.6	24.1	31.4	34.0
		MCDBR	38.4	38.7	38.6	37.9	34.4	28.4	20.7	20.5	20.8	26.3	33.3	36.8
		MCWBR	17.5	16.1	15.2	14.2	11.6	8.8	8.1	8.3	8.4	10.9	15.1	17.3
	5% WB	MCDBR	32.2	33.7	34.7	34.4	28.5	21.1	18.5	18.4	18.3	21.8	27.7	32.4
		MCWBR	15.9	15.3	14.5	14.0	10.1	8.0	8.3	8.4	8.1	9.5	12.9	16.3
Clear-Sky Solar Irradiance	taub	0.306	0.318	0.305	0.339	0.416	0.422	0.413	0.408	0.395	0.354	0.313	0.312	
	taud	2.513	2.473	2.497	2.367	2.237	2.263	2.308	2.306	2.366	2.464	2.547	2.534	
	Ebn at Noon	309	311	318	305	279	275	278	281	285	295	305	304	
	Edh at Noon	31	34	35	40	45	44	42	42	39	34	30	30	
All-Sky Solar Radiation	RadAvg	1527	1829	2166	2351	2274	2040	1893	1883	1707	1703	1603	1465	
	RadStd	118	164	128	101	108	119	114	106	110	107	121	84	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.97	+2.54	-3.29	N/A	N/A	N/A	-193	+410	+234
(47) Regional (4 neighbors)		+0.81	+2.23	-2.97	N/A	-0.54	N/A	-193	+410	+234

Nomenclature: See separate page