

TULANCINGO, Mexico

WMO: 766340

Lat: 20.0842N

Lon: 98.3575W

Elev: 7264

StdP: 11.23

Time Zone: -6.00 (MEX)

Period: 90-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	37.0	39.3	19.1	18.8	57.8	23.3	23.1	59.5	19.1	64.1	16.8	64.2	1.5	150	0.408

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	24.4	83.9	58.5	81.4	58.0	79.1	57.8	64.6	74.9	63.4	73.6	62.5	72.6	8.0	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
61.2	106.3	68.9	60.2	102.4	67.4	59.2	99.0	66.0	33.9	75.2	32.8	73.7	32.0	72.5	71.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
19.5	16.3	13.5	30.5	87.4	3.5	1.8	28.0	88.7	25.9	89.7	23.9	90.7	21.3	92.0		
			28.1	68.8	3.0	2.2	26.0	70.3	24.3	71.6	22.6	72.8	20.4	74.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	60.9	55.9	58.8	61.0	64.6	65.7	64.5	62.6	62.5	61.8	59.6	57.8	56.3	(6)
(7)		DBStd	5.18	4.56	5.35	5.79	4.97	4.19	2.74	2.22	2.37	3.12	4.18	4.54	3.59	(7)
(8)		HDD50	29	9	5	4	0	0	0	0	0	1	5	5		(8)
(9)		HDD65	1682	282	182	146	68	42	41	79	83	100	170	218	271	(9)
(10)		CDD50	4019	192	251	346	437	488	434	392	388	355	299	238	199	(10)
(11)		CDD65	198	0	7	22	55	65	26	6	7	6	3	1	0	(11)
(12)		CDH74	2399	37	178	377	622	669	235	59	60	35	58	42	27	(12)
(13)		CDH80	352	1	13	56	123	132	24	2	0	0	0	1	0	(13)
(14)	Wind	WSAvg	4.1	3.8	4.2	4.5	4.4	4.3	4.2	4.4	4.6	4.1	3.8	3.7	3.3	(14)
(15)	Precipitation	PrecAvg	15.3	0.3	0.5	0.5	0.9	0.9	1.8	1.8	1.7	2.4	1.8	0.5	0.3	(15)
(16)		PrecMax	32.0	2.3	2.1	3.2	3.2	3.9	6.0	5.5	5.1	12.0	8.5	1.7	1.0	(16)
(17)		PrecMin	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	11.2	0.5	0.6	0.8	0.8	1.1	1.9	1.8	1.7	3.0	2.2	0.6	0.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	77.4	82.0	84.6	87.3	86.3	82.6	78.3	78.3	77.4	78.6	77.5	76.9	(19)
(20)		MCWB	52.9	55.0	57.9	57.5	59.7	60.1	59.5	61.4	59.8	59.1	58.3	54.6		(20)
(21)		2%	DB	74.9	78.7	81.5	83.7	83.8	79.3	75.8	75.6	74.8	75.5	75.1	73.8	(21)
(22)		MCWB	52.7	53.9	56.8	57.6	59.6	60.7	59.8	60.2	60.3	58.9	57.6	54.3		(22)
(23)		5%	DB	72.2	76.1	78.6	80.8	80.8	76.8	73.5	73.7	72.4	73.2	72.7	72.0	(23)
(24)		MCWB	52.3	53.8	55.8	57.4	58.9	60.2	59.9	60.2	60.3	58.2	56.7	54.4		(24)
(25)		10%	DB	69.6	73.2	75.4	77.8	78.0	74.0	71.3	71.6	70.0	70.2	69.6	69.8	(25)
(26)		MCWB	51.4	53.6	55.1	57.0	58.8	60.1	59.5	59.9	59.8	57.7	55.8	53.7		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	58.7	61.3	63.0	63.6	66.0	66.1	64.2	65.6	64.7	64.0	62.9	60.0	(27)
(28)		MCDWB	69.9	75.8	76.7	76.9	78.2	76.5	73.4	74.7	72.8	73.3	74.0	70.6		(28)
(29)		2%	WB	56.1	58.6	60.3	61.6	63.6	63.9	62.8	63.8	63.1	62.0	60.5	57.5	(29)
(30)		MCDWB	69.5	72.2	75.0	75.1	76.5	74.2	72.2	73.1	71.0	71.0	71.2	69.3		(30)
(31)		5%	WB	54.4	57.0	58.6	60.0	62.1	62.6	61.6	62.4	62.0	60.6	58.8	55.8	(31)
(32)		MCDWB	67.5	70.2	73.1	74.0	75.0	72.4	70.4	71.1	69.3	68.9	68.6	68.3		(32)
(33)		10%	WB	53.0	55.3	56.9	58.7	60.7	61.3	60.5	61.0	60.8	59.3	57.1	54.4	(33)
(34)		MCDWB	65.5	68.1	70.7	73.3	72.9	69.8	68.5	69.1	67.3	66.9	65.9	66.8		(34)
(35)	Mean Daily Temperature Range	MDBR	26.4	26.8	26.3	25.6	24.4	20.2	19.0	19.8	17.3	20.3	22.6	27.2		(35)
(36)		5% DB	MCDBR	30.6	30.9	30.3	28.7	27.9	25.0	22.3	22.8	21.3	25.5	27.4	30.8	(36)
(37)		MCWBR	15.5	14.8	14.6	13.5	13.4	12.2	10.5	11.1	10.4	13.3	14.1	17.2	(37)	
(38)		5% WB	MCDBR	27.4	27.2	27.7	25.7	24.8	21.0	19.7	20.3	18.0	21.3	24.4	28.3	(38)
(39)		MCWBR	16.0	15.5	15.4	14.2	13.4	11.6	10.9	11.6	9.7	12.1	14.3	17.0	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.363	0.374	0.391	0.439	0.422	0.425	0.406	0.397	0.355	0.387	0.341	0.350	(40)	
(41)		taud	2.285	2.258	2.219	2.106	2.182	2.186	2.269	2.295	2.424	2.285	2.399	2.329	(41)	
(42)		Ebn at Noon	288	292	290	276	278	274	280	284	297	284	294	288	(42)	
(43)		Edh at Noon	39	43	46	52	48	47	43	43	37	41	35	36	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1361	1599	1817	1938	1886	1748	1741	1742	1505	1491	1392	1342	(44)	
(45)		RadStd	111	147	139	117	123	117	149	93	133	108	117	89	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (7 neighbors)	+0.67	+1.89	-3.15	N/A	N/A	N/A	-4	-229	+297	+5	

Nomenclature: See separate page