

TUXPAN, Mexico

WMO: 766400

Lat: 20.9600N

Lon: 97.4172W

Elev: 10

StdP: 101.20

Time Zone: -6.00 (MEX)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.1	12.5	8.8	7.0	12.2	10.7	8.0	13.7	7.5	17.4	6.0	17.2	2.0	320	0.255

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	7.2	34.4	29.3	33.6	28.9	32.9	28.5	30.5	33.4	29.8	32.6	29.2	31.9	2.2	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
29.7	26.8	33.0	29.1	25.8	32.2	28.5	24.9	31.4	102.1	33.5	98.7	32.7	95.7	32.0	34.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.2	4.2	3.5	8.7	37.5	1.7	2.3	7.5	39.2	6.5	40.5	5.5	41.8	4.3	43.5		
(5)			7.9	31.3	1.5	1.5	6.8	32.4	6.0	33.2	5.1	34.1	4.1	35.2	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	25.0	19.6	21.1	23.5	26.0	27.9	28.7	28.4	28.8	27.4	25.6	22.7	20.2	(6)
(7)		DBStd	4.08	3.22	3.26	2.82	2.38	2.01	1.36	1.35	1.28	1.45	2.45	2.81	3.02	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	64	26	12	3	0	0	0	0	0	0	1	5	18	(9)
(10)		CDD10.0	5476	297	310	417	479	555	562	570	582	522	484	382	316	(10)
(11)		CDD18.3	2498	64	88	162	229	297	312	312	323	272	227	137	75	(11)
(12)		CDH23.3	23044	177	345	904	1898	3199	3689	3572	3781	2705	1863	688	222	(12)
(13)		CDH26.7	8171	12	41	181	591	1232	1559	1434	1601	886	531	94	9	(13)
(14)	Wind	WSAvg	1.4	1.5	1.6	1.6	1.6	1.5	1.5	1.3	1.3	1.3	1.4	1.4	1.5	(14)
(15)	Precipitation	PrecAvg	1518	51	45	36	49	62	188	190	178	323	254	106	28	(15)
(16)		PrecMax	2122	85	172	96	124	148	379	621	490	667	630	264	97	(16)
(17)		PrecMin	1126	17	18	8	8	4	29	29	32	152	17	48	0	(17)
(18)		PrecStd	253	20	35	25	35	41	110	145	111	146	144	55	28	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.0	29.2	31.5	34.6	35.2	35.7	34.7	35.0	33.4	32.4	29.8	27.7	(19)
(20)			MCWB	24.6	25.1	26.4	28.4	29.1	29.8	29.4	30.7	29.0	28.4	26.3	24.7	(20)
(21)		2%	DB	26.3	28.0	29.7	32.5	33.7	34.1	33.5	34.0	32.4	31.2	28.8	26.6	(21)
(22)			MCWB	23.2	24.6	25.8	27.5	28.9	29.0	28.8	29.6	28.4	27.6	25.6	24.0	(22)
(23)		5%	DB	25.2	26.9	28.6	31.1	32.7	33.2	32.7	33.2	31.6	30.4	27.8	25.6	(23)
(24)			MCWB	22.4	23.9	25.1	26.8	28.3	28.7	28.4	28.8	28.0	27.1	25.0	23.3	(24)
(25)		10%	DB	24.0	25.7	27.5	29.9	31.7	32.3	31.9	32.4	30.8	29.5	26.8	24.5	(25)
(26)			MCWB	21.7	23.1	24.5	26.2	27.8	28.2	28.0	28.3	27.6	26.7	24.4	22.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.2	26.0	27.5	29.6	30.9	31.0	30.7	31.4	30.1	29.4	27.4	25.5	(27)
(28)			MCDWB	27.2	28.1	30.1	33.1	34.1	34.2	33.4	34.3	32.5	31.4	29.2	26.9	(28)
(29)		2%	WB	23.6	25.0	26.3	28.1	29.7	30.0	29.7	30.5	29.3	28.4	26.2	24.5	(29)
(30)			MCDWB	25.6	27.3	28.9	31.5	32.6	33.1	32.5	33.3	31.6	30.5	28.1	26.0	(30)
(31)		5%	WB	22.8	24.2	25.5	27.2	28.9	29.3	29.0	29.7	28.6	27.6	25.4	23.7	(31)
(32)			MCDWB	24.7	26.3	28.0	30.4	31.6	32.3	31.8	32.3	30.8	29.6	27.2	25.2	(32)
(33)		10%	WB	22.0	23.4	24.7	26.4	28.1	28.6	28.3	28.9	27.9	27.0	24.7	22.8	(33)
(34)			MCDWB	23.8	25.2	27.0	29.2	30.9	31.5	31.0	31.3	30.1	28.9	26.3	24.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.8	6.7	6.8	7.6	7.5	7.2	7.1	7.4	6.2	6.5	6.4	6.4	(35)
(36)			MCDBR	8.0	7.7	7.8	8.9	8.3	8.3	8.0	8.2	7.5	7.2	7.0	7.4	(36)
(37)			MCWBR	5.1	4.6	4.4	4.7	4.3	4.2	4.1	4.2	4.1	4.2	4.2	5.0	(37)
(38)		5% WB	MCDWB	7.6	7.4	7.4	8.5	7.8	8.0	7.6	8.0	7.2	6.9	6.5	6.8	(38)
(39)			MCWBR	5.2	4.8	4.6	4.8	4.6	4.8	4.6	5.0	4.6	4.4	4.4	4.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.420	0.433	0.470	0.506	0.530	0.475	0.465	0.451	0.449	0.440	0.427	0.421	(40)	
(41)		taud	2.325	2.291	2.187	2.112	2.057	2.239	2.284	2.322	2.312	2.332	2.328	2.319	(41)	
(42)		Ebn at Noon	847	860	841	813	786	823	832	847	848	842	834	832	(42)	
(43)		Edh at Noon	119	130	149	163	171	141	135	130	130	123	117	116	(43)	
(44)	All-Sky Solar Radiation	RadAvg	3.13	3.79	4.62	5.35	5.68	5.73	5.53	5.55	4.75	4.32	3.58	3.11	(44)	
(45)		RadStd	0.41	0.45	0.47	0.45	0.33	0.34	0.40	0.27	0.40	0.31	0.37	0.31	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)		N/A	N/A	N/A	+0.48	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page