

MEXICO CITY INTL, MexicoWMO: **766793**Lat: **19.436N**Lon: **99.072W**Elev: **2230**StdP: **77.25**Time Zone: **-6.00 (MEX)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	3.1	4.9	-10.9	1.9	19.4	-8.2	2.5	19.7	9.8	18.2	8.7	18.0	2.2	50	0.415

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	13.4	29.1	12.3	28.0	12.1	27.0	12.0	15.9	22.0	15.6	21.6	15.2	21.1	4.6	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.1	13.3	17.1	13.9	13.0	16.9	13.2	12.4	16.8	53.1	22.6	51.6	21.7	50.5	21.1	19.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.4	8.2	7.2	0.3	31.2	1.7	1.2	-0.9	32.0	-1.8	32.7	-2.8	33.4	-4.0	34.2
			-2.2	17.2	1.4	1.0	-3.2	17.9	-4.1	18.5	-4.9	19.1	-5.9	19.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	17.4	13.9	15.8	17.5	19.5	20.1	19.5	18.5	18.6	18.2	17.1	15.4	14.3
	DBStd	2.66	1.88	2.08	2.06	1.91	1.92	1.53	1.08	1.09	1.28	1.93	2.09	1.94
	HDD10.0	2	1	0	0	0	0	0	0	0	0	0	1	1
	HDD18.3	568	137	73	41	11	6	6	11	10	17	45	89	124
	CDD10.0	2691	122	162	232	284	313	284	264	266	246	221	163	134
	CDD18.3	216	0	2	14	44	61	39	17	18	13	7	1	0
	CDH23.3	2026	18	104	287	507	547	257	73	71	45	63	34	19
(13)	CDH26.7	299	0	4	30	96	123	44	1	1	0	1	0	0
(14)	Wind	WSAvg	2.9	2.6	2.9	3.1	3.1	3.2	3.0	3.0	3.0	3.0	2.7	2.5
(15) Precipitation	PrecAvg	800	8	9	13	24	62	137	159	164	147	59	13	5
	PrecMax	1238	39	66	41	57	169	308	240	267	274	166	58	57
	PrecMin	615	1	0	1	6	6	54	100	55	35	0	0	0
	PrecStd	118	9	13	11	14	35	53	34	45	59	39	17	11
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.0	27.1	28.9	30.8	31.1	29.9	26.2	26.1	25.9	26.2	25.2	25.1
		MCWB	10.2	10.6	11.8	12.3	12.7	12.9	13.6	13.8	13.5	12.8	12.0	11.0
	2%	DB	23.8	26.0	27.2	28.9	29.2	28.0	25.1	25.0	24.2	25.0	24.2	23.9
		MCWB	9.9	10.4	11.2	11.9	12.5	12.9	13.8	14.0	14.0	12.9	11.7	10.7
	5%	DB	22.8	24.8	26.2	27.9	28.0	26.2	24.0	24.0	23.8	23.9	23.1	22.8
		MCWB	9.8	10.4	10.9	11.8	12.5	13.2	13.8	13.9	14.1	13.0	11.6	10.4
	10%	DB	21.2	23.2	25.0	26.8	26.8	24.2	23.0	23.0	22.2	22.8	22.1	21.3
		MCWB	9.6	10.2	10.7	11.7	12.5	13.5	14.1	14.2	14.2	13.1	11.4	10.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.2	12.8	13.6	14.6	16.0	16.2	16.0	16.2	16.2	16.0	14.7	13.1
		MCDB	21.3	22.6	23.9	24.3	24.7	22.6	22.0	22.0	22.1	21.9	22.1	21.7
	2%	WB	11.5	12.1	12.8	13.7	15.1	15.6	15.5	15.6	15.7	15.3	13.8	12.3
		MCDB	20.5	21.9	23.2	23.5	23.5	21.8	21.3	21.4	21.3	21.1	20.3	20.6
	5%	WB	10.8	11.6	12.2	13.2	14.5	15.1	15.0	15.2	15.3	14.7	13.2	11.7
		MCDB	19.6	21.4	22.7	22.9	22.7	21.1	20.8	20.9	20.7	20.3	19.7	19.9
	10%	WB	10.3	11.0	11.7	12.7	13.9	14.7	14.6	14.7	14.8	14.2	12.7	11.1
		MCDB	19.0	20.8	22.0	22.5	21.9	20.5	20.2	20.3	19.8	19.7	19.1	19.3
(35) Mean Daily Temperature Range	5% DB	MDBR	15.2	15.6	15.5	14.5	13.4	11.1	10.3	10.2	9.6	11.5	13.9	14.9
		MCDBR	17.0	17.3	16.9	15.9	15.2	13.8	11.6	11.5	11.2	13.6	15.3	16.2
		MCWBR	6.8	6.4	6.0	5.3	4.7	4.0	3.6	3.7	3.8	4.8	5.8	6.4
	5% WB	MCDBR	14.8	14.8	14.9	14.1	12.8	10.5	10.1	10.0	9.3	10.5	12.3	14.2
		MCWBR	6.1	5.8	5.4	4.7	4.0	3.5	3.4	3.6	3.4	3.9	4.8	5.9
(40) Clear-Sky Solar Irradiance	taub		0.415	0.433	0.446	0.519	0.448	0.516	0.494	0.476	0.359	0.449	0.357	0.403
	taud		2.088	2.038	2.024	1.870	2.117	1.899	1.980	2.037	2.448	2.070	2.366	2.119
	Ebn at Noon		853	861	864	803	852	789	808	828	934	835	912	850
	Edh at Noon		151	168	176	208	161	198	183	174	114	160	113	142
(44) All-Sky Solar Radiation	RadAvg		4.93	5.73	6.38	6.53	6.08	5.55	5.54	5.53	4.90	5.09	4.96	4.84
	RadStd		0.33	0.47	0.39	0.27	0.40	0.40	0.49	0.31	0.39	0.38	0.38	0.27

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days		
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.47	+1.34	-1.57	N/A	N/A	N/A	N/A	-140	+248
(47) Regional (5 neighbors)		+0.37	+1.05	-1.75	N/A	N/A	N/A	-2	-127	+165

Nomenclature: See separate page