

TLAXCALA, Mexico

WMO: 766830

Lat: 19.3250N

Lon: 98.2472W

Elev: 2248

StdP: 77.08

Time Zone: -6.00 (MEX)

Period: 88-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 2.3	(c) 3.7	(d) -3.6	(e) 3.7	(f) 10.5	(g) -1.5	(h) 4.4	(i) 10.5	(j) 6.0	(k) 10.8	(l) 4.4	(m) 11.1	(n) 0.3	(o) 60	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	14.6	28.2	15.4	27.0	15.4	26.0	15.3	18.5	24.1	17.8	23.6	17.3	22.9	2.2	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.7	15.7	21.5	16.0	15.0	20.8	15.4	14.4	20.0	62.4	24.3	59.9	23.5	57.9	23.0	21.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 4.4	(b) 3.8	(c) 3.3	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
(a) 4.4	(b) 3.8	(c) 3.3	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.0	12.6	14.3	15.5	17.4	18.5	17.8	17.3	17.5	17.5	16.3	15.0	12.9
	DBStd	2.55	1.80	2.04	2.06	1.67	1.75	1.44	1.18	1.20	1.21	1.77	1.85	2.13
	HDD10.0	7	3	1	0	0	0	0	0	0	0	0	0	3
	HDD18.3	893	178	113	88	38	19	26	37	30	29	66	101	168
	CDD10.0	2214	83	122	172	221	262	235	225	233	225	194	149	93
	CDD18.3	59	0	0	2	9	23	11	3	4	4	2	1	0
	CDH23.3	1147	3	34	139	279	330	112	61	66	31	53	33	6
CDH26.7	123	0	1	17	37	53	10	2	1	1	1	1	0	
Wind	WSAvg	1.2	1.2	1.3	1.5	1.3	1.4	1.2	1.3	1.3	1.3	1.1	1.1	1.0
Precipitation	PrecAvg	789	7	5	6	28	76	144	154	167	122	62	11	7
	PrecMax	1216	49	23	26	71	203	296	268	311	238	222	32	47
	PrecMin	562	0	0	0	0	13	51	54	49	45	3	0	0
	PrecStd	163	13	8	9	22	48	68	66	70	48	56	9	11
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.7	26.0	28.5	29.5	30.0	28.4	26.6	26.4	25.6	26.3	26.1	24.1
		MCWB	12.3	14.8	16.1	15.4	15.0	17.0	15.4	16.9	15.5	15.2	14.3	12.8
	2%	DB	22.0	24.6	26.4	27.9	28.2	26.4	25.1	25.0	24.3	24.8	24.3	22.6
		MCWB	12.4	13.7	15.0	15.5	15.1	16.0	15.5	16.4	15.7	15.4	14.6	12.6
	5%	DB	20.7	23.4	25.0	26.8	26.9	24.9	23.9	24.0	23.3	23.5	22.9	21.4
		MCWB	12.2	13.4	14.5	15.2	15.4	16.0	15.6	16.1	15.8	15.3	14.6	12.4
	10%	DB	19.3	22.0	23.5	25.4	25.6	23.4	22.7	22.7	22.1	22.1	21.6	20.0
		MCWB	12.0	13.3	14.1	14.7	15.4	15.8	15.4	16.0	15.8	15.2	14.0	11.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.2	17.1	18.4	18.6	19.3	19.0	18.3	19.1	18.2	18.1	17.6	15.5
		MCDB	20.4	23.5	26.7	26.0	25.1	24.1	23.6	23.7	22.9	22.8	23.4	20.1
	2%	WB	14.1	15.9	16.7	17.5	18.1	17.8	17.4	18.0	17.3	17.2	16.5	14.5
		MCDB	19.5	22.2	24.0	25.0	24.4	23.7	22.7	22.7	22.1	21.9	22.1	19.6
	5%	WB	13.3	14.9	15.9	16.5	17.2	17.1	16.6	17.1	16.7	16.6	15.6	13.7
		MCDB	18.8	21.0	22.9	23.9	23.7	22.7	21.8	22.0	21.3	21.2	21.2	19.2
	10%	WB	12.5	14.0	14.9	15.6	16.3	16.4	15.9	16.4	16.2	15.9	14.7	12.9
		MCDB	18.0	20.1	21.9	23.3	23.0	21.6	21.0	21.2	20.7	20.5	20.2	18.4
Mean Daily Temperature Range	5% DB	MDBR	14.8	15.6	16.2	16.0	14.6	11.1	11.5	11.5	10.1	12.6	14.9	15.1
		MCDBR	16.7	17.8	19.4	18.9	17.3	14.4	14.0	13.7	12.4	15.4	16.9	17.0
		MCWBR	8.8	9.1	10.2	8.8	7.0	6.3	5.9	6.3	5.4	7.5	8.7	8.1
	5% WB	MCDBR	15.7	16.3	18.2	16.3	14.9	11.7	11.8	12.0	10.4	12.5	14.7	14.8
		MCWBR	10.2	10.0	11.3	9.7	7.8	6.2	6.3	6.8	5.2	7.3	8.6	9.0
Clear-Sky Solar Irradiance	taub	0.390	0.390	0.416	0.462	0.425	0.453	0.424	0.420	0.349	0.401	0.345	0.370	
	taud	2.155	2.175	2.115	2.029	2.178	2.096	2.205	2.217	2.465	2.234	2.376	2.224	
	Ebn at Noon	880	904	892	850	872	840	866	875	944	882	925	889	
	Edh at Noon	141	146	161	177	151	163	146	145	112	136	112	128	
All-Sky Solar Radiation	RadAvg	4.84	5.62	6.24	6.43	6.08	5.61	5.66	5.58	4.91	5.07	4.89	4.76	
	RadStd	0.34	0.42	0.40	0.29	0.39	0.36	0.49	0.30	0.41	0.33	0.35	0.25	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (6 neighbors)		+0.37	+1.05	-1.75	N/A	N/A	N/A	-2	-127	+165	+3	

Nomenclature: See separate page