

PUEBLA, Mexico

WMO: 766850

Lat: 19.0550N

Lon: 98.1633W

Elev: 7149

StdP: 11.28

Time Zone: -6.00 (MEX)

Period: 94-17

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	37.5	39.9	17.3	17.2	60.3	22.0	21.6	58.6	24.9	62.4	22.2	61.4	6.1	320	0.404

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	27.5	82.9	58.1	80.9	57.1	79.0	57.0	63.1	73.9	62.1	72.9	61.1	71.6	6.8	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.4	102.8	65.9	59.0	97.5	64.5	57.7	93.0	63.5	32.6	73.4	31.6	73.0	30.9	71.9	72.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
20.9	17.6	14.7	DB	31.5	87.1	2.2	2.1	29.9	88.6	28.5	89.8	27.3	91.0	25.6	92.5	(4)
			WB	26.3	67.8	2.3	2.0	24.6	69.2	23.2	70.3	21.9	71.5	20.2	72.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	61.7	55.6	58.8	61.4	65.5	66.4	65.0	63.6	63.8	63.4	61.4	58.6	56.6
	DBStd	4.33	2.91	2.88	3.25	2.75	2.79	2.53	1.94	1.99	2.06	2.69	2.96	2.81
	HDD50	2	1	0	0	0	0	0	0	0	0	0	0	1
	HDD65	1368	290	173	116	26	16	29	50	47	56	114	191	260
	CDD50	4271	176	247	355	465	510	450	422	428	401	353	259	205
	CDD65	162	0	0	5	41	61	29	7	10	7	2	0	0
	CDH74	2559	17	102	307	730	722	271	114	116	52	69	32	27
	CDH80	305	0	2	21	115	134	27	3	1	1	0	0	0
Wind	WSAvg	5.5	5.9	5.9	6.4	6.2	5.5	5.0	4.7	4.6	4.8	5.7	5.6	5.6
Precipitation	PrecAvg	32.0	0.3	0.2	0.4	1.2	3.2	6.6	5.7	5.9	6.3	2.8	0.7	0.2
	PrecMax	40.2	2.1	1.4	1.9	4.0	8.1	13.0	9.9	18.9	24.5	8.6	6.5	1.8
	PrecMin	24.9	0.0	0.0	0.0	0.0	0.8	2.4	0.6	1.3	2.6	0.0	0.0	0.0
	PrecStd	4.9	0.5	0.4	0.5	1.0	1.6	2.9	2.6	3.5	3.6	2.0	1.1	0.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.9	79.5	82.5	86.0	86.4	82.8	79.2	79.1	77.9	78.6	77.3	77.0
		MCWB	52.1	54.3	56.6	58.7	58.7	60.3	58.3	58.5	60.0	56.3	55.2	54.3
	2%	DB	73.3	77.0	79.3	82.8	83.6	79.9	77.0	77.0	75.4	75.6	74.9	73.7
		MCWB	52.1	52.9	54.8	57.4	58.9	59.3	58.0	58.3	59.0	57.4	55.2	53.2
	5%	DB	71.0	74.9	77.3	80.8	80.8	77.2	75.1	75.1	73.5	73.6	73.0	71.7
		MCWB	51.6	52.7	54.3	56.3	57.9	58.8	58.0	58.6	59.2	57.1	54.8	52.5
	10%	DB	68.4	72.5	75.2	78.7	78.4	74.8	73.2	73.1	71.7	71.7	70.3	69.5
		MCWB	51.2	52.4	53.7	56.2	57.9	58.5	58.0	58.4	58.7	56.8	54.5	52.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	56.4	58.4	60.3	63.0	63.9	64.5	63.0	63.5	65.3	63.2	60.0	57.6
		MCDB	70.2	74.1	76.1	79.2	78.5	75.7	72.9	72.5	72.8	72.2	71.5	70.7
	2%	WB	54.7	56.3	58.0	60.7	62.1	62.5	61.2	61.8	62.6	61.2	58.3	56.0
		MCDB	68.9	72.0	74.5	77.3	76.0	74.1	71.5	71.4	70.4	69.6	69.8	69.5
	5%	WB	53.4	54.9	56.3	59.2	60.7	61.0	60.2	60.6	61.1	60.1	56.9	54.6
		MCDB	67.5	71.2	73.1	75.9	74.8	71.7	70.3	69.8	69.1	68.5	68.3	68.2
	10%	WB	52.0	53.5	54.9	57.7	59.5	60.0	59.2	59.7	60.1	58.9	55.7	53.4
		MCDB	66.0	69.4	71.5	73.7	73.3	69.9	69.0	68.7	67.8	67.5	67.0	66.6
Mean Daily Temperature Range	5% DB	MDBR	29.5	31.0	30.7	30.0	27.5	21.9	22.2	21.6	19.7	23.9	27.6	29.5
		MCDBR	32.5	33.8	33.5	32.5	30.5	25.8	25.0	24.2	22.5	27.2	29.9	32.0
		MCWBR	16.8	16.8	16.0	14.9	13.6	11.9	11.4	10.9	10.9	13.2	15.0	16.2
	5% WB	MCDBR	29.6	30.4	30.7	30.2	27.2	21.6	21.8	21.2	19.5	22.1	26.1	29.0
		MCWBR	16.5	16.4	15.8	15.0	13.3	11.1	11.3	11.1	10.4	12.1	14.2	15.7
Clear-Sky Solar Irradiance	taub	0.371	0.367	0.399	0.438	0.429	0.432	0.403	0.400	0.353	0.382	0.339	0.353	
	taud	2.236	2.273	2.182	2.111	2.177	2.182	2.285	2.292	2.454	2.321	2.405	2.307	
	Ebn at Noon	286	295	288	277	276	272	280	283	298	286	296	289	
	Edh at Noon	41	42	48	52	48	47	43	43	36	40	35	37	
All-Sky Solar Radiation	RadAvg	1547	1800	2009	2084	1967	1831	1863	1826	1616	1642	1575	1518	
	RadStd	106	126	119	87	112	105	150	97	126	97	102	75	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (6 neighbors)	+0.67	+1.89	-3.15	N/A	N/A	N/A	-4	-229	+297	+5	

Nomenclature: See separate page