

CAMPECHE INTL, Mexico

WMO: 766950

Lat: 19.8364N

Lon: 90.5075W

Elev: 16

StdP: 14.69

Time Zone: -6.00 (MEX)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	58.3	61.1	53.3	60.5	68.4	55.4	65.4	68.2	23.1	75.3	21.4	76.2	1.7	90	0.342

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	19.7	98.9	78.4	96.9	78.2	95.1	78.7	85.1	92.7	83.4	90.7	82.2	89.5	8.8	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
83.1	173.0	91.1	81.4	163.6	89.0	80.4	157.6	87.6	49.3	92.4	47.4	90.9	46.1	90.1	93.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
21.4	18.8	17.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	80.8	74.5	77.2	80.0	83.5	84.9	84.2	84.0	83.8	82.7	80.6	77.2	76.7
	DBStd	4.99	4.62	4.78	4.41	4.52	3.94	2.42	1.96	1.86	1.87	3.07	3.97	4.01
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	1	0	1	0	0	0	0	0	0	0	0	0	0
	CDD50	11237	759	762	931	1005	1082	1025	1055	1047	980	948	815	828
	CDD65	5764	294	344	466	555	617	575	590	582	530	483	365	363
	CDH74	54968	1788	2727	4266	6095	7153	6171	6205	5869	5025	4306	2823	2540
	CDH80	23405	533	1050	1736	2885	3518	2848	2995	2659	2088	1515	817	761
Wind	WSAvg	7.7	7.4	8.1	9.1	9.7	9.4	7.8	7.2	6.9	6.0	6.5	6.9	7.0
Precipitation	PrecAvg	48.3	1.2	0.9	0.6	0.8	2.5	7.9	7.2	8.9	9.2	6.0	1.9	1.3
	PrecMax	76.1	3.7	3.1	2.7	2.9	7.8	16.1	14.2	14.6	27.9	21.1	6.5	3.8
	PrecMin	33.3	0.0	0.0	0.0	0.0	0.6	3.0	2.6	4.8	3.9	1.8	0.2	0.0
	PrecStd	8.2	0.9	0.9	0.6	0.8	1.6	3.1	2.7	2.3	5.0	3.9	1.5	0.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	92.2	95.4	98.7	102.3	102.2	98.7	98.5	97.0	95.0	93.4	91.2	91.7
		MCWB	76.1	77.0	78.0	80.0	80.1	80.7	79.1	81.6	82.1	82.3	80.4	79.2
	2%	DB	89.5	92.9	95.2	98.7	99.0	96.5	95.3	94.9	93.1	91.1	88.9	89.5
		MCWB	75.4	75.3	76.4	77.4	77.8	79.8	79.4	81.0	81.5	80.6	78.3	77.0
	5%	DB	86.1	89.8	92.8	96.4	96.6	94.5	93.4	93.2	91.4	89.3	86.8	87.5
		MCWB	74.7	75.2	75.6	76.3	77.9	79.4	79.7	81.0	80.7	79.9	77.4	76.7
	10%	DB	82.5	86.4	89.2	92.2	93.2	91.7	91.6	91.2	89.5	87.4	84.5	84.5
		MCWB	74.3	74.4	75.0	76.3	77.8	79.3	79.7	80.4	80.2	79.2	76.3	75.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.3	81.6	82.5	84.5	85.1	86.5	85.5	86.7	86.0	84.5	82.1	81.9
		MCDB	88.1	90.7	93.0	95.6	95.1	95.1	92.6	94.2	91.8	90.3	88.3	88.7
	2%	WB	77.2	79.0	79.7	81.6	82.8	83.3	83.4	84.0	83.3	82.1	80.3	79.7
		MCDB	84.2	87.8	89.4	91.3	91.3	90.6	90.2	90.6	89.7	88.8	86.0	85.9
	5%	WB	76.0	77.0	78.1	80.0	81.2	81.7	81.7	82.3	81.7	80.7	78.9	78.1
		MCDB	82.5	84.2	87.2	89.4	89.6	89.1	88.9	89.2	88.2	86.5	84.7	84.0
	10%	WB	74.9	75.6	77.0	78.8	80.0	80.5	80.7	81.1	80.7	79.7	77.6	76.8
		MCDB	80.8	83.2	85.4	88.3	88.9	88.3	88.6	88.1	87.5	85.5	83.0	82.4
Mean Daily Temperature Range	5% DB	MDBR	17.4	21.0	21.1	21.1	19.7	17.9	19.7	18.3	16.8	16.1	17.2	17.3
		MCDBR	21.6	24.2	24.8	24.9	22.7	20.9	20.8	20.0	18.5	17.2	18.2	19.6
		MCWBR	11.0	11.7	10.8	10.3	9.6	9.7	9.7	10.1	9.7	8.8	9.7	10.2
	5% WB	MCDBR	19.1	22.0	22.2	21.7	20.7	18.6	19.8	19.0	17.5	16.1	16.1	17.4
		MCWBR	10.9	11.6	10.9	10.5	10.0	9.9	10.3	10.4	9.8	9.1	9.3	10.4
Clear-Sky Solar Irradiance	taub	0.361	0.380	0.415	0.459	0.475	0.446	0.464	0.437	0.413	0.393	0.374	0.377	
	taud	2.570	2.510	2.380	2.242	2.237	2.373	2.315	2.398	2.448	2.515	2.534	2.522	
	Ebn at Noon	292	291	284	271	263	268	264	273	280	283	285	282	
	Edh at Noon	30	33	39	45	45	39	42	38	36	33	30	30	
All-Sky Solar Radiation	RadAvg	1362	1606	1879	2063	2058	1924	2068	2028	1853	1661	1471	1323	
	RadStd	98	120	85	82	124	111	79	72	113	79	71	87	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	+1.58	+1.91	N/A	N/A	N/A	N/A

Nomenclature: See separate page