

COATZACOALCOS, Mexico

WMO: 767410

Lat: 18.1403N

Lon: 94.5108W

Elev: 16

StdP: 101.13

Time Zone: -6.00 (MEX)

Period: 82-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	16.4	17.5	13.2	9.5	18.5	14.4	10.3	19.3	19.9	19.3	17.5	20.6	3.1	0	0.344

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	6.9	35.9	26.8	34.2	26.6	32.9	26.6	28.7	32.2	28.1	31.5	27.7	30.9	4.4	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.7	23.8	31.0	27.2	23.0	30.4	26.8	22.4	30.0	93.3	32.5	90.5	31.7	88.4	31.0	34.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
21.2	13.5	10.2	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	26.1	22.4	23.5	25.2	27.2	28.7	28.3	28.0	28.0	27.6	26.3	24.8	23.0	
	DBStd	2.92	2.20	2.37	2.60	2.75	2.02	1.36	1.26	1.28	1.26	1.76	1.87	2.31	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	
	HDD18.3	1	1	0	0	0	0	0	0	0	0	0	0	1	
	CDD10.0	5874	384	378	471	517	578	549	558	559	527	504	444	403	
	CDD18.3	2834	127	145	213	267	320	299	299	301	277	246	194	146	
	CDH23.3	27100	433	716	1561	2772	3782	3540	3531	3533	2990	2267	1328	647	
	CDH26.7	9213	68	147	451	1033	1552	1378	1303	1368	1013	591	213	95	
Wind	WSAvg	3.7	4.5	4.4	4.2	3.8	4.3	4.1	3.5	2.7	2.3	3.2	3.8	3.7	
Precipitation	PrecAvg	2282	80	37	22	18	79	227	268	360	469	342	226	111	
	PrecMax	3208	265	118	80	140	354	520	571	675	1263	723	571	232	
	PrecMin	1402	0	0	0	0	0	59	87	136	198	124	0	0	
	PrecStd	403	61	34	22	31	92	117	114	139	224	177	139	49	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.1	33.7	35.6	38.3	37.5	35.7	33.1	33.8	33.8	33.2	31.8	31.9	
		MCWB	24.6	24.3	26.0	26.4	26.9	28.3	27.7	28.1	27.4	27.9	25.7	24.6	
	2%	DB	28.2	30.6	33.7	36.2	35.6	33.7	32.1	32.6	32.5	31.8	30.0	29.1	
		MCWB	23.8	24.5	25.0	26.8	26.6	27.3	27.3	27.5	27.1	26.5	25.1	24.0	
	5%	DB	26.7	28.4	30.9	34.0	33.7	32.2	31.3	31.8	31.5	30.5	28.9	27.2	
		MCWB	23.3	24.3	24.6	26.3	26.8	27.2	27.0	27.3	26.9	26.3	24.9	23.9	
	10%	DB	25.4	26.9	28.9	31.1	31.9	31.2	30.6	31.0	30.6	29.6	27.9	26.1	
		MCWB	22.7	23.6	24.5	25.6	26.6	26.9	26.6	27.0	26.5	25.9	24.7	23.4	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.8	26.2	27.9	29.7	29.4	29.2	28.5	29.0	28.6	28.5	26.8	25.5
			MCDB	29.3	30.4	32.7	34.8	33.1	32.8	31.6	32.2	31.9	31.5	29.8	28.6
2%		WB	24.3	25.1	26.1	27.8	28.2	28.3	27.8	28.2	27.9	27.5	26.0	24.9	
		MCDB	26.8	28.7	30.3	31.3	31.9	31.7	30.8	31.3	30.9	30.2	28.2	27.5	
5%		WB	23.6	24.5	25.3	26.9	27.6	27.7	27.3	27.7	27.4	26.8	25.4	24.4	
		MCDB	25.9	27.4	29.0	30.3	31.3	31.0	30.2	30.7	30.3	29.4	27.8	26.7	
10%		WB	23.1	23.8	24.7	26.1	27.1	27.2	27.0	27.2	26.9	26.2	25.0	23.8	
		MCDB	25.3	26.2	28.0	29.4	30.7	30.3	29.7	30.1	29.7	28.7	27.4	25.8	
Mean Daily Temperature Range	5% DB	MDBR	5.4	5.8	6.7	7.6	6.9	6.3	5.5	6.1	6.3	5.7	5.6	5.6	
		MCDBR	8.0	9.0	11.1	12.3	9.9	8.0	6.2	6.9	7.5	7.1	7.1	7.8	
		MCWBR	4.5	4.9	5.5	5.3	4.5	3.8	3.3	3.4	3.7	3.6	4.0	4.0	
	5% WB	MCDBR	6.8	7.3	8.2	8.8	7.7	6.9	5.7	6.3	6.8	6.1	6.2	7.0	
		MCWBR	4.3	4.3	4.8	4.9	4.3	4.0	3.4	3.6	3.8	3.6	3.9	3.9	
Clear-Sky Solar Irradiance	taub	0.380	0.394	0.440	0.494	0.541	0.460	0.468	0.457	0.445	0.418	0.396	0.388		
	taud	2.487	2.442	2.293	2.152	2.044	2.312	2.296	2.323	2.343	2.433	2.462	2.474		
	Ebn at Noon	904	907	873	824	776	834	829	844	857	873	880	883		
	Edh at Noon	103	113	135	157	173	131	133	131	127	113	105	102		
All-Sky Solar Radiation	RadAvg	3.23	4.10	5.16	5.75	5.76	5.56	5.68	5.38	4.70	4.14	3.61	3.23		
	RadStd	0.43	0.51	0.43	0.33	0.38	0.34	0.33	0.29	0.34	0.36	0.37	0.32		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page