

OAXACA INTL, Mexico

WMO: 767750

Lat: 17.002N

Lon: 96.721W

Elev: 1518

StdP: 84.37

Time Zone: -6.00 (MEX)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.9	8.3	-4.9	3.0	23.6	-2.1	3.8	24.5	10.4	20.8	8.6	20.9	1.8	0	0.312

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	14.8	33.1	17.4	32.0	16.8	31.0	16.8	23.9	28.4	22.0	27.1	20.6	26.2	2.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.6	20.9	27.4	20.4	18.2	25.4	18.9	16.5	23.1	81.1	28.4	72.6	27.0	66.5	26.0	31.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.9	6.6	5.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	21.0	18.0	20.2	21.4	23.1	23.8	22.5	21.7	21.9	21.7	20.6	19.1	18.2
	DBStd	2.40	2.01	1.73	1.78	1.74	1.51	1.39	1.02	1.07	1.14	1.64	2.03	1.84
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	78	31	4	1	0	0	0	0	0	0	3	16	23
	CDD10.0	4017	247	286	352	393	428	375	364	367	350	327	272	255
	CDD18.3	1053	19	57	95	143	169	125	106	109	101	71	38	20
	CDH23.3	8476	422	781	1085	1454	1300	646	549	569	398	462	398	413
	CDH26.7	2547	80	239	398	648	522	158	98	113	56	91	72	71
Wind	WSAvg	2.1	2.2	2.3	2.5	2.4	2.2	1.9	1.9	1.9	1.7	2.1	2.1	2.0
Precipitation	PrecAvg	785	3	5	17	39	80	150	124	129	139	66	15	8
	PrecMax	1049	12	36	40	125	181	240	254	347	304	169	72	56
	PrecMin	554	0	0	3	1	2	55	45	56	54	19	3	2
	PrecStd	137	3	8	12	32	45	53	57	80	57	44	14	10
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.2	32.3	33.3	35.0	34.4	32.2	30.5	30.6	30.0	30.8	30.4	30.0
		MCWB	14.9	15.3	16.6	18.0	19.0	19.6	19.2	19.7	20.4	18.2	18.4	18.1
	2%	DB	28.8	31.0	32.0	33.2	32.9	30.1	28.9	29.0	28.1	29.0	29.0	28.8
		MCWB	14.9	15.0	16.1	16.7	18.6	19.3	18.7	18.8	19.3	18.1	16.7	15.7
	5%	DB	27.7	29.8	30.8	32.0	31.2	28.8	27.8	27.9	27.0	27.5	27.5	27.2
		MCWB	14.4	14.8	15.6	16.1	17.8	18.7	18.4	18.3	18.8	17.6	16.4	15.0
	10%	DB	26.0	28.1	29.1	30.8	30.0	27.2	26.2	26.8	25.9	26.1	26.1	26.0
		MCWB	14.0	14.6	15.8	16.2	17.7	18.2	17.6	18.0	18.2	17.1	16.0	14.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.1	23.3	24.1	25.0	25.8	23.6	23.7	22.6	23.4	23.6	23.7	23.5
		MCDB	24.6	26.8	28.6	29.8	30.4	28.3	27.8	27.9	26.5	27.4	26.9	27.6
	2%	WB	17.5	18.8	20.0	21.3	22.3	20.9	21.0	20.3	20.7	20.5	19.6	19.3
		MCDB	23.7	24.3	26.9	27.8	28.2	26.7	26.1	26.3	25.8	25.6	25.0	23.8
	5%	WB	15.7	16.9	18.1	19.1	20.3	19.7	19.5	19.4	19.6	19.0	17.8	16.8
		MCDB	24.3	24.4	25.3	26.0	26.2	25.7	25.1	25.2	24.7	24.3	24.3	23.1
	10%	WB	14.9	15.9	17.0	17.9	19.1	19.0	18.5	18.6	18.9	18.1	16.8	15.5
		MCDB	23.6	24.4	24.7	25.5	25.0	24.4	23.7	24.0	23.5	23.2	23.2	23.0
Mean Daily Temperature Range	5% DB	MDBR	17.8	18.2	17.7	17.6	14.8	11.8	12.4	12.5	11.1	13.5	16.1	17.5
		MCDBR	19.5	19.6	19.3	19.1	16.5	13.6	13.7	14.0	12.5	15.9	17.8	19.1
		MCWBR	9.4	8.7	9.1	8.8	7.9	6.5	7.2	6.1	5.8	7.9	9.3	10.6
	5% WB	MCDBR	17.8	17.8	17.5	17.2	14.6	11.8	12.5	12.6	11.4	13.1	15.9	17.4
		MCWBR	10.6	10.7	10.5	10.5	8.9	6.6	7.6	6.2	5.9	7.8	10.0	11.7
Clear-Sky Solar Irradiance	taub	0.339	0.338	0.400	0.408	0.476	0.414	0.397	0.396	0.396	0.377	0.345	0.327	
	taud	2.444	2.449	2.259	2.270	2.107	2.327	2.401	2.383	2.378	2.434	2.478	2.509	
	Ebn at Noon	950	967	911	900	828	873	889	898	902	914	936	953	
	Edh at Noon	108	113	140	140	162	129	120	123	123	113	104	99	
All-Sky Solar Radiation	RadAvg	4.89	5.62	6.20	6.33	5.71	5.21	5.47	5.32	4.70	4.85	4.91	4.79	
	RadStd	0.31	0.31	0.33	0.25	0.38	0.37	0.41	0.38	0.39	0.33	0.32	0.23	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page