

ACAPULCO INTL, Mexico

WMO: 768056

Lat: 16.7628N

Lon: 99.7494W

Elev: 3

StdP: 101.29

Time Zone: -6.00 (MEX)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	19.2	20.8	13.8	9.8	23.5	15.0	10.6	23.7	8.2	28.9	7.6	29.0	1.0	0	0.350

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.2	33.2	26.6	33.0	26.5	32.2	26.0	27.9	32.0	27.5	31.4	27.1	30.9	4.3	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.9	22.6	31.0	26.2	21.6	30.4	26.0	21.4	30.2	89.4	32.3	87.2	31.9	85.8	31.1	29.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.0	6.9	6.0	18.0	35.0	1.7	1.5	16.8	36.1	15.8	36.9	14.8	37.7	13.5	38.8		
(5)			14.8	28.8	1.4	0.7	13.8	29.3	12.9	29.7	12.1	30.0	11.1	30.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.3	26.1	25.9	25.8	26.3	27.9	28.4	28.4	28.4	27.8	27.9	27.5	26.6	
	DBStd	1.57	1.19	1.17	1.39	1.42	1.41	1.19	1.12	1.19	1.17	1.10	1.04	1.15	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDD10.0	6299	499	445	489	488	556	553	571	569	535	554	524	515	
	CDD18.3	3258	241	212	231	238	297	303	312	311	285	296	274	257	
	CDH23.3	34591	2104	1897	2156	2383	3454	3628	3766	3675	3106	3265	2832	2327	
CDH26.7	12541	691	611	694	795	1351	1451	1516	1463	1060	1127	998	784		
Wind	WSAvg	2.5	2.2	2.4	2.6	2.7	2.7	2.7	2.6	2.6	2.6	2.4	2.2	2.1	
Precipitation	PrecAvg	1240	11	8	6	1	39	234	215	250	299	140	20	7	
	PrecMax	1753	65	127	44	12	207	441	476	552	480	417	161	31	
	PrecMin	756	0	0	0	0	0	134	46	57	137	0	0	0	
	PrecStd	265	21	28	13	3	50	92	110	129	98	104	33	10	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.1	32.8	32.9	32.2	33.2	34.0	33.9	34.1	33.2	33.2	33.2	33.0	
		MCWB	24.5	25.0	25.7	24.8	26.6	27.1	27.4	27.9	26.9	27.0	26.5	26.1	
	2%	DB	31.8	31.2	31.2	31.8	32.2	33.0	32.9	33.1	32.2	32.2	32.8	31.9	
		MCWB	24.5	24.3	24.3	24.7	25.7	26.4	26.7	27.0	26.4	26.5	26.4	25.3	
	5%	DB	30.9	30.4	30.8	31.0	32.0	32.1	32.1	32.2	31.8	31.2	31.8	31.0	
		MCWB	24.0	24.1	24.1	24.5	25.6	25.9	26.2	26.4	26.2	26.1	25.7	24.7	
	10%	DB	29.9	29.9	29.9	30.2	31.2	31.8	31.8	31.8	31.0	31.0	30.9	30.1	
		MCWB	23.8	23.9	23.9	24.3	25.3	25.9	26.1	26.2	26.1	26.0	25.4	24.6	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.6	26.6	26.6	26.6	27.8	28.2	28.1	28.7	27.7	28.0	27.9	27.1
			MCDB	31.1	31.1	31.3	30.6	32.1	32.2	32.2	33.2	32.0	31.5	32.1	31.6
2%		WB	25.7	25.6	25.8	26.0	27.0	27.5	27.5	27.7	27.1	27.2	27.0	26.3	
		MCDB	30.2	30.1	30.0	30.1	31.0	31.4	31.4	32.0	31.1	30.7	30.7	30.4	
5%		WB	25.1	25.1	25.2	25.4	26.6	26.9	27.0	27.2	26.6	26.8	26.5	25.7	
		MCDB	29.5	29.3	29.3	29.6	30.4	30.7	30.9	31.1	30.4	30.2	30.1	29.6	
10%		WB	24.5	24.5	24.6	24.9	26.1	26.5	26.6	26.6	26.2	26.4	26.1	25.2	
		MCDB	28.6	28.6	28.6	29.2	29.8	30.1	30.4	30.5	29.8	29.7	29.5	29.0	
Mean Daily Temperature Range	5% DB	MDBR	8.2	8.2	8.4	8.0	6.9	6.1	6.2	6.3	5.9	5.9	7.0	7.7	
		MCDBR	9.1	8.8	8.9	8.3	7.1	6.8	6.8	7.1	6.9	6.6	8.1	8.4	
		MCWBR	4.9	5.0	4.9	4.6	3.7	3.3	3.8	3.9	3.6	3.4	4.1	4.4	
	5% WB	MCDBR	8.0	8.0	7.9	7.7	6.6	6.3	6.5	6.7	6.3	6.1	6.9	7.6	
		MCWBR	4.7	4.7	4.7	4.5	3.7	3.4	3.8	4.0	3.5	3.5	3.8	4.2	
Clear-Sky Solar Irradiance	taub	0.407	0.406	0.429	0.484	0.595	0.479	0.442	0.444	0.437	0.424	0.400	0.388		
	taud	2.412	2.406	2.334	2.170	1.909	2.273	2.398	2.379	2.383	2.435	2.484	2.499		
	Ebn at Noon	879	899	886	833	736	818	851	856	866	870	881	889		
	Edh at Noon	113	118	130	154	198	136	120	124	122	113	104	101		
All-Sky Solar Radiation	RadAvg	5.21	6.09	6.82	7.16	6.47	5.80	6.21	5.95	5.35	5.38	5.29	5.10		
	RadStd	0.31	0.31	0.26	0.16	0.39	0.40	0.38	0.34	0.40	0.35	0.28	0.21		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (0 neighbors)	N/A	N/A	N/A	-0.60	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page