

TUXTLA GUTIERREZ, Mexico

WMO: 768430

Lat: 16.7631N

Lon: 93.1475W

Elev: 576

StdP: 94.59

Time Zone: -6.00 (MEX)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.9	14.1	8.9	7.6	21.7	10.2	8.3	21.1	14.8	20.8	13.3	19.8	4.5	0	0.314

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	13.2	36.9	22.3	35.2	22.3	34.1	22.5	25.6	31.6	25.0	31.1	24.5	30.5	3.6	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.9	20.2	29.0	23.2	19.3	27.7	22.9	18.9	27.2	82.1	31.5	79.4	31.3	77.3	30.3	29.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
13.0	10.5	9.5	DB	8.7	39.2	1.6	1.2	7.5	40.1	6.6	40.9	5.7	41.6	4.5	42.5	(4)
			WB	7.8	27.7	1.8	1.4	6.6	28.7	5.5	29.5	4.5	30.2	3.3	31.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	24.8	21.5	23.2	25.1	27.0	27.5	26.0	25.7	25.4	24.7	23.2	22.2		
		DBStd	2.78	2.47	2.75	2.75	2.42	2.20	1.73	1.52	1.38	1.55	1.91	1.97		
		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0		
		HDD18.3	12	5	3	1	0	0	0	0	0	0	0	1		
		CDD10.0	5399	357	370	468	511	542	481	487	492	461	456	396	378	(10)
		CDD18.3	2369	104	139	211	261	284	231	229	233	211	198	147	122	(11)
		CDH23.3	18095	669	1112	1867	2563	2721	1703	1690	1654	1297	1211	840	768	(12)
		CDH26.7	7207	237	488	877	1255	1261	609	602	574	414	382	251	258	(13)
(14)	Wind	WSAvg	3.2	4.0	4.1	4.2	3.9	3.3	2.3	2.4	2.4	2.3	2.9	3.4	3.3	(14)
(15)	Precipitation	PrecAvg	935	2	2	3	17	65	227	181	172	200	55	14	2	(15)
		PrecMax	1282	9	31	46	122	208	370	302	408	324	184	72	16	(16)
		PrecMin	676	0	0	0	0	4	56	40	53	61	0	0	0	(17)
		PrecStd	170	3	7	9	27	49	84	65	84	68	44	21	4	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	33.8	35.9	37.4	38.6	38.2	35.2	34.2	34.0	33.2	33.2	32.8	33.0		
		0.4% MCWB	21.3	22.1	21.8	22.7	23.1	24.1	24.4	24.2	24.5	24.4	23.0	21.5		
		2% DB	31.8	34.1	35.6	37.0	36.2	33.2	32.9	32.8	32.0	31.9	31.1	31.2		
		2% MCWB	20.9	21.1	21.3	22.1	22.9	24.0	23.8	24.1	24.3	23.9	22.4	21.1		
		5% DB	29.5	32.2	33.9	35.2	34.9	31.8	31.5	31.3	30.8	30.4	29.7	29.9		
		5% MCWB	20.2	20.9	21.2	21.9	23.0	23.7	23.7	23.9	24.0	23.5	21.9	21.0		
		10% DB	27.2	29.9	31.8	33.3	32.9	30.1	30.1	30.0	29.4	29.1	28.1	28.0		
		10% MCWB	19.6	20.5	21.0	21.9	22.8	23.3	23.4	23.7	23.6	23.1	21.3	20.6		
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	23.2	24.1	24.5	25.4	26.3	25.9	25.8	26.1	25.7	25.7	24.8	23.5		
		0.4% MCDB	30.1	32.7	32.0	33.5	33.3	31.7	31.5	31.4	31.0	30.9	30.3	29.7		
		2% WB	21.9	22.7	23.1	24.0	24.7	24.8	24.8	25.1	24.9	24.7	23.4	22.3		
		2% MCDB	29.2	30.9	31.1	32.6	32.2	30.9	30.9	30.8	30.3	30.3	28.7	28.5		
		5% WB	20.9	21.7	22.2	23.2	24.0	24.1	24.2	24.4	24.3	24.0	22.6	21.5		
		5% MCDB	27.2	29.2	30.2	31.3	31.3	30.1	30.0	29.9	29.4	29.1	27.7	27.5		
		10% WB	20.1	20.9	21.6	22.6	23.3	23.6	23.7	23.8	23.7	23.3	21.9	20.9		
		10% MCDB	25.6	27.5	29.2	30.3	30.2	28.9	28.9	28.9	28.4	27.9	26.6	26.3		
(35)	Mean Daily Temperature Range	MDBR	13.6	14.8	15.1	14.8	13.2	10.8	10.9	10.9	10.1	10.3	11.7	12.9		
		5% DB MCDBR	16.9	17.9	17.6	16.7	14.9	12.3	12.2	11.8	11.2	11.5	13.2	15.6		
		5% WB MCWBR	7.5	7.3	6.5	5.9	5.1	4.8	5.1	5.0	4.7	5.1	5.9	6.9		
		5% DB MCDBR	15.5	16.4	16.0	15.1	13.3	11.1	11.4	11.3	10.5	10.7	12.0	14.2		
		5% WB MCWBR	7.4	7.4	6.6	5.9	5.2	4.9	5.1	5.1	4.8	5.0	5.9	6.8		
(40)	Clear-Sky Solar Irradiance	taub	0.365	0.392	0.446	0.553	0.614	0.478	0.465	0.458	0.460	0.433	0.388	0.367		
		taud	2.471	2.391	2.212	1.926	1.807	2.208	2.245	2.257	2.244	2.333	2.424	2.470		
		Ebn at Noon	924	913	870	778	722	819	831	844	845	861	892	910		
		Edh at Noon	106	120	147	197	219	145	140	140	141	125	110	103		
(44)	All-Sky Solar Radiation	RadAvg	4.28	5.10	5.84	6.05	5.59	5.36	5.88	5.68	5.00	4.63	4.43	4.24		
		RadStd	0.35	0.39	0.31	0.26	0.41	0.32	0.37	0.35	0.35	0.39	0.34	0.28		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page