

COMITAN, Mexico

WMO: 768480

Lat: 16.2319N

Lon: 92.1353W

Elev: 1646

StdP: 83.05

Time Zone: -6.00 (MEX)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.9	10.1	2.1	5.4	18.8	4.2	6.2	17.4	7.4	16.5	6.1	17.0	1.2	50	0.294

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	10.3	29.1	17.1	28.1	17.1	27.1	17.1	19.9	25.4	19.4	24.9	18.9	24.3	2.2	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.1	15.9	22.7	17.6	15.4	21.9	17.2	15.0	21.1	65.0	25.5	63.0	25.0	61.3	24.2	26.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.3	5.3	4.5	DB	6.3	31.7	1.5	0.8	5.2	32.2	4.3	32.7	3.5	33.2	2.4	33.7	(4)
(5)			WB	3.5	21.9	2.0	1.4	2.1	22.9	0.9	23.7	-0.2	24.5	-1.7	25.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	19.2	16.8	17.8	19.2	21.1	21.2	20.3	19.9	20.3	20.2	19.0	17.5	17.2	(6)	
	DBStd	2.19	1.99	2.12	2.13	1.66	1.44	1.20	1.09	1.05	1.14	1.60	1.87	1.62	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	196	53	32	15	2	1	1	1	1	1	11	34	43	(9)	
	CDD10.0	3362	212	217	284	332	346	309	308	319	306	281	226	222	(10)	
	CDD18.3	515	6	16	41	83	88	60	51	62	57	33	11	7	(11)	
	CDH23.3	2304	72	154	347	551	433	148	123	171	129	80	46	50	(12)	
(13)	CDH26.7	297	4	20	61	116	69	7	5	9	3	2	1	2	(13)	
(14)	Wind	WSAvg	1.7	1.6	1.8	1.9	1.8	1.6	1.8	1.8	1.4	1.4	1.7	1.7	(14)	
(15) Precipitation	PrecAvg	1045	6	7	15	33	113	213	123	178	212	110	25	11	(15)	
	PrecMax	1459	16	30	49	93	248	365	274	376	371	215	68	53	(16)	
	PrecMin	718	0	0	0	0	33	74	25	47	65	10	0	1	(17)	
	PrecStd	200	4	8	13	22	65	68	58	87	66	51	20	10	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.4	29.0	30.1	30.8	30.0	27.6	27.3	27.7	27.1	26.8	26.4	26.7	(19)	
		MCWB	16.0	16.4	16.4	17.1	17.8	18.9	17.4	17.8	18.9	19.2	18.2	16.4	(20)	
	2%	DB	25.3	27.1	28.5	29.2	28.5	26.2	25.7	26.3	25.9	25.5	24.6	24.9	(21)	
		MCWB	15.6	15.6	16.3	17.0	17.9	18.7	17.4	17.7	18.7	18.6	17.1	16.2	(22)	
	5%	DB	23.7	25.5	27.0	28.0	27.3	25.1	24.7	25.1	24.9	24.2	23.2	23.1	(23)	
		MCWB	15.0	15.3	15.8	16.8	17.9	18.3	17.3	17.6	18.4	18.0	16.6	15.6	(24)	
	10%	DB	22.0	23.6	25.4	26.6	26.0	24.0	23.7	24.1	23.8	23.0	21.8	21.5	(25)	
		MCWB	14.6	14.9	15.6	16.6	17.5	17.9	17.1	17.4	18.1	17.5	16.3	15.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.5	18.1	18.6	19.5	20.2	20.2	19.7	20.2	20.3	20.1	19.4	17.9	(27)	
		MCDB	25.1	26.2	26.7	26.4	26.8	25.9	24.5	25.4	25.3	25.5	24.8	24.8	(28)	
	2%	WB	16.4	16.9	17.6	18.6	19.4	19.4	18.6	19.2	19.6	19.2	18.2	16.9	(29)	
		MCDB	23.3	24.6	25.3	25.5	26.0	24.7	23.7	24.1	24.5	24.2	23.1	23.4	(30)	
	5%	WB	15.7	16.2	16.9	18.1	18.8	18.8	18.0	18.4	18.9	18.5	17.3	16.0	(31)	
		MCDB	21.8	22.7	24.2	25.0	25.0	23.8	23.0	23.2	23.7	23.1	21.8	21.4	(32)	
	10%	WB	15.1	15.5	16.3	17.5	18.2	18.3	17.5	17.8	18.3	17.9	16.6	15.4	(33)	
		MCDB	20.3	21.5	23.1	24.1	23.9	22.8	22.2	22.4	22.6	21.9	20.6	20.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	10.3	11.2	12.1	12.1	10.3	8.3	8.4	8.9	8.3	8.2	8.9	9.2	(35)	
		MCDBR	13.9	15.0	14.9	13.9	12.1	9.7	9.7	10.1	9.6	10.1	11.2	12.3	(36)	
	5% WB	MCWBR	6.4	6.3	5.6	4.9	4.6	4.1	3.8	4.0	4.2	4.8	5.5	5.7	(37)	
		MCWBR	12.0	13.0	13.5	12.6	10.7	9.0	8.8	9.2	8.9	9.1	9.9	10.5	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.314	0.336	0.382	0.457	0.511	0.408	0.396	0.404	0.395	0.362	0.333	0.315	(40)	
		taud	2.572	2.494	2.335	2.120	1.996	2.357	2.395	2.351	2.367	2.490	2.533	2.572	(41)	
	Ebn at Noon		982	971	930	857	800	878	890	891	904	932	953	971	(42)	
		Edh at Noon	95	108	130	162	181	125	121	127	124	107	99	93	(43)	
(44) All-Sky Solar Radiation	RadAvg		4.47	5.21	5.86	5.99	5.35	5.18	5.70	5.65	5.02	4.58	4.49	4.41	(44)	
	RadStd		0.29	0.33	0.31	0.25	0.42	0.31	0.38	0.34	0.37	0.38	0.29	0.28	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page