

TAPACHULA INTL, Mexico

WMO: 769043

Lat: 14.794N

Lon: 92.370W

Elev: 30

StdP: 100.97

Time Zone: -6.00 (MEX)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.9	20.9	16.9	12.1	25.7	17.9	12.9	25.4	6.9	29.4	6.3	29.6	0.1	80	0.324

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	8.4	34.0	25.5	33.2	25.8	32.9	25.8	28.1	31.5	27.6	31.2	27.2	30.8	4.0	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.1	23.0	30.5	26.2	21.8	30.1	26.2	21.6	30.0	90.8	31.5	88.1	32.1	86.5	31.4	33.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.2	6.0	5.4	DB	19.2	36.0	2.1	1.9	17.7	37.4	16.5	38.5	15.3	39.6	13.8	40.9	
			WB	16.3	30.4	1.2	1.7	15.4	31.6	14.7	32.6	14.0	33.6	13.2	34.8	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.4	26.5	27.0	27.6	28.3	28.3	27.6	27.8	27.7	27.4	27.2	27.2	26.8
	DBStd	1.04	0.89	0.77	0.84	0.90	0.97	1.09	0.92	0.85	0.94	0.88	0.85	0.89
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6368	513	476	546	549	568	527	551	548	522	534	516	519
	CDD18.3	3326	254	242	288	299	309	277	292	289	272	276	266	261
	CDH23.3	33683	2442	2469	3187	3517	3431	2699	2983	2829	2439	2497	2659	2529
	CDH26.7	13006	896	940	1311	1538	1409	1002	1193	1088	861	861	951	955
Wind	WSAvg	1.5	1.5	1.7	1.8	1.8	1.6	1.5	1.5	1.5	1.4	1.3	1.2	1.3
Precipitation	PrecAvg	2139	10	8	30	80	247	336	239	302	414	355	98	18
	PrecMax	3162	80	45	103	194	504	550	436	508	767	910	321	62
	PrecMin	1550	1	1	0	0	29	136	35	122	264	51	0	0
	PrecStd	374	17	8	29	52	110	91	95	86	126	162	85	16
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.0	33.2	34.2	35.0	34.2	33.2	33.9	33.2	33.2	32.9	33.1	33.2
		MCWB	23.7	24.0	24.4	25.2	26.4	27.2	26.6	27.0	26.9	27.0	25.9	24.7
	2%	DB	32.0	32.2	33.2	34.0	33.1	32.8	33.0	32.9	32.2	32.0	32.1	32.2
		MCWB	24.1	24.1	24.6	25.1	26.5	27.0	26.9	26.9	26.4	26.6	26.0	24.9
	5%	DB	31.2	31.9	32.2	33.0	32.2	32.0	32.1	32.1	31.8	31.1	31.2	31.9
		MCWB	24.3	24.1	24.6	25.2	26.2	26.5	26.6	26.6	26.3	26.5	26.0	25.0
	10%	DB	30.8	31.0	31.8	32.1	31.9	31.1	31.8	31.2	30.9	30.8	30.9	31.0
		MCWB	24.3	24.2	24.6	25.1	26.1	26.4	26.6	26.4	26.4	26.4	25.9	25.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.5	26.2	26.8	27.6	28.6	28.7	29.5	28.2	27.7	28.2	27.9	27.1
		MCDB	30.0	29.8	30.3	31.3	31.2	30.9	31.2	31.6	31.2	31.0	30.8	30.3
	2%	WB	25.8	25.6	26.2	26.9	27.6	27.6	27.8	27.6	27.2	27.3	27.1	26.3
		MCDB	29.7	29.8	30.4	30.6	31.3	31.4	31.4	31.3	30.7	30.5	30.3	30.1
	5%	WB	25.2	25.2	25.8	26.4	27.1	27.2	27.3	27.1	26.9	27.0	26.7	25.9
		MCDB	29.3	29.5	30.3	30.6	30.9	30.8	31.0	30.8	30.4	30.2	30.1	29.9
	10%	WB	24.9	24.8	25.4	26.0	26.6	26.7	26.8	26.7	26.5	26.5	26.2	25.4
		MCDB	28.9	29.2	29.9	30.5	30.5	30.2	30.6	30.3	30.0	29.8	29.8	29.5
Mean Daily Temperature Range	5% DB	MDBR	9.1	8.9	8.7	8.4	7.7	7.4	8.0	7.9	7.4	7.3	7.9	9.0
		MCDBR	10.2	10.6	10.1	10.0	8.3	8.7	9.0	9.0	8.6	8.2	8.6	10.6
		MCWBR	5.0	4.7	4.3	3.8	3.7	4.3	4.8	4.6	4.2	4.3	4.6	5.1
	5% WB	MCDBR	8.7	8.8	8.7	8.4	8.0	8.0	8.5	8.4	7.9	7.8	8.1	9.2
		MCWBR	4.7	4.4	4.2	3.8	4.1	4.4	5.0	4.7	4.2	4.4	4.7	5.0
Clear-Sky Solar Irradiance	taub	0.395	0.420	0.485	0.584	0.616	0.482	0.490	0.479	0.474	0.434	0.412	0.396	
	taud	2.469	2.402	2.201	1.931	1.865	2.262	2.248	2.278	2.263	2.414	2.456	2.485	
	Ebn at Noon	899	891	838	755	719	814	810	828	835	866	876	889	
	Edh at Noon	108	120	150	196	206	137	139	137	139	117	108	104	
All-Sky Solar Radiation	RadAvg	5.42	5.96	6.31	6.27	5.50	5.29	5.90	5.79	5.22	5.08	5.28	5.19	
	RadStd	0.13	0.20	0.20	0.27	0.36	0.32	0.36	0.33	0.37	0.40	0.20	0.14	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page