

BERMUDA INTL, Bermuda

WMO: 780160

Lat: 32.367N

Lon: 64.677W

Elev: 13

StdP: 14.69

Time Zone: -4.00 (NAA)

Period: 94-19

WBAN: 13601

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	55.1	56.9	40.6	37.3	58.2	42.4	40.0	59.1	41.4	61.8	37.0	62.4	18.0	320	0.502

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.2	86.8	77.9	86.0	77.8	84.6	77.0	79.8	84.1	79.0	83.6	78.3	83.1	12.2	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.4	147.6	83.0	77.3	141.9	82.4	76.8	139.8	82.2	42.9	84.3	42.2	84.2	41.5	83.0	84.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 32.5	28.9	25.7	51.0	87.9	2.7	1.4	49.1	88.9	47.5	89.7	45.9	90.5	44.0	91.5		
(5)			45.5	81.3	1.8	1.6	44.2	82.5	43.2	83.4	42.1	84.3	40.8	85.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	72.2	64.8	64.3	64.4	67.4	71.5	76.9	80.9	81.5	80.0	75.9	70.6	67.2
	DBStd	7.02	3.81	3.62	3.35	2.82	2.95	2.70	1.98	2.07	2.04	2.74	3.16	3.33
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	183	50	50	52	10	1	0	0	0	0	0	2	18
	CDD50	8090	459	402	447	521	667	807	957	978	900	802	618	532
	CDD65	2799	44	32	34	82	203	357	492	513	450	337	170	85
	CDH74	19623	4	1	1	18	353	2262	5029	5610	4282	1815	230	18
	CDH80	3806	0	0	0	0	3	230	1121	1531	817	103	1	0
(14) Wind	WSAvg	13.2	15.7	15.6	15.8	13.6	12.5	11.5	11.5	10.7	11.2	12.8	13.7	14.2
(15) Precipitation	PrecAvg	58.0	4.6	4.7	4.4	3.7	4.4	3.8	4.4	6.6	6.3	6.2	4.4	4.5
	PrecMax	73.1	9.3	8.8	7.9	8.4	12.4	12.4	8.7	14.0	12.0	10.7	10.8	14.8
	PrecMin	40.1	1.7	1.5	0.7	1.2	0.9	0.2	0.1	1.5	1.7	1.7	1.7	1.4
	PrecStd	8.3	1.7	2.0	1.9	1.9	2.8	2.9	2.2	3.3	2.8	2.0	2.2	2.8
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	74.7	73.7	73.6	75.6	80.4	85.7	88.2	89.4	87.5	83.9	79.0	75.5
		MCWB	69.1	68.1	67.7	68.0	72.3	76.3	78.0	77.5	77.5	75.8	72.2	70.3
	2%	DB	73.0	71.9	71.8	73.8	78.7	84.0	86.3	87.5	85.9	82.4	77.3	74.0
		MCWB	67.8	67.1	66.8	67.6	71.8	75.8	77.8	78.1	77.1	75.2	71.8	69.2
	5%	DB	71.6	71.0	70.7	73.2	77.2	82.5	85.6	86.2	84.5	80.9	76.6	73.4
		MCWB	67.0	66.5	65.7	67.3	71.0	75.2	77.5	78.1	76.6	74.1	71.4	68.6
	10%	DB	70.1	69.7	69.7	71.7	75.6	80.9	84.4	85.4	84.0	80.2	75.3	71.9
		MCWB	65.7	65.6	64.7	66.3	70.3	74.6	76.9	77.7	76.4	73.8	70.1	67.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.5	69.7	70.1	70.9	74.7	78.3	81.0	80.9	80.1	78.3	75.4	72.5
		MCDB	72.9	72.0	72.1	73.4	77.7	81.9	84.8	85.3	83.9	81.3	77.1	74.6
	2%	WB	69.1	68.5	68.5	69.8	73.4	77.3	79.6	79.8	79.1	77.1	73.9	70.9
		MCDB	71.6	70.9	70.8	72.5	76.5	81.2	83.7	84.7	83.3	80.3	76.3	73.2
	5%	WB	68.1	67.5	67.3	68.8	72.5	76.5	78.7	79.1	78.3	76.1	72.4	69.6
		MCDB	70.7	70.0	69.8	71.8	75.7	80.5	83.0	84.2	82.7	79.5	75.4	72.2
	10%	WB	66.9	66.7	65.9	67.5	71.5	75.9	78.0	78.4	77.5	75.2	70.9	68.3
		MCDB	69.8	69.4	68.8	70.7	74.8	79.8	82.6	83.7	82.2	78.8	74.4	71.5
(35) Mean Daily Temperature Range	5% DB	MDBR	7.3	7.3	7.4	7.3	6.9	6.9	6.9	7.2	7.0	6.7	6.8	6.8
		MCDBR	7.4	7.6	7.8	7.9	7.5	7.8	7.7	7.7	7.6	7.2	7.2	7.5
	5% WB	MCWBR	6.9	7.0	7.3	6.1	4.9	4.4	4.5	4.4	4.6	4.9	5.9	6.7
		MCWBR	7.2	7.3	7.3	7.3	6.8	7.1	7.0	7.4	7.0	6.7	6.8	7.0
(40) Clear-Sky Solar Irradiance	taub		0.356	0.368	0.373	0.400	0.422	0.419	0.422	0.410	0.400	0.386	0.365	0.358
		taud	2.538	2.500	2.482	2.398	2.360	2.422	2.474	2.519	2.526	2.552	2.555	2.540
	Ebn at Noon		274	281	288	283	276	275	274	277	276	272	269	266
		Edh at Noon	27	31	33	38	40	37	35	33	32	29	26	26
(44) All-Sky Solar Radiation	RadAvg		813	1048	1432	1850	2037	2120	2144	1946	1631	1246	943	770
	RadStd		51	89	112	97	150	164	126	134	76	77	42	58

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page