

JARDINES DEL REY, Cuba

WMO: 782561

Lat: 22.461N

Lon: 78.328W

Elev: 4

StdP: 101.28

Time Zone: -5.00 (CUB)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	15.5	17.1	9.2	7.2	18.6	11.0	8.2	19.7	11.1	23.1	10.3	23.2	1.8	10	0.412

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.7	33.0	25.7	32.2	25.5	32.0	25.5	26.8	30.7	26.6	30.5	26.4	30.3	5.3	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.0	21.3	29.2	25.2	20.4	28.9	25.1	20.2	28.9	84.5	31.3	83.3	30.7	82.0	30.4	29.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.7	8.9	8.2	DB	12.8	34.4	1.5	0.7	11.8	34.8	10.9	35.2	10.1	35.6	9.0	36.1	(4)
(5)			WB	10.8	27.7	1.2	0.7	10.0	28.2	9.3	28.6	8.6	29.0	7.8	29.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	26.0	23.1	23.7	24.2	25.7	26.4	27.8	28.6	28.6	27.9	26.9	25.0	24.2	(6)	
	DBStd	2.47	2.21	2.03	1.79	1.51	1.42	1.21	0.98	1.00	1.01	1.17	1.81	2.12	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	3	2	1	0	0	0	0	0	0	0	0	0	1	(9)	
	CDD10.0	5848	406	383	440	469	507	534	578	577	537	525	451	441	(10)	
	CDD18.3	2809	149	151	182	219	249	284	319	318	287	267	201	183	(11)	
	CDH23.3	26188	680	837	1120	1822	2342	3179	3912	3882	3243	2630	1433	1108	(12)	
(13)	CDH26.7	8204	71	123	194	411	637	1165	1653	1642	1240	741	202	126	(13)	
(14)	Wind	WSAvg	4.2	4.6	4.7	5.0	4.8	4.1	3.5	4.0	3.8	3.2	3.8	4.7	4.6	(14)
(15) Precipitation	PrecAvg	1288	36	32	39	62	162	179	148	168	191	161	66	42	(15)	
	PrecMax	1630	76	117	84	118	328	362	216	249	348	480	180	203	(16)	
	PrecMin	840	8	7	14	21	60	83	86	109	111	52	8	9	(17)	
	PrecStd	175	18	24	16	21	75	65	37	32	48	87	45	34	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	29.8	30.8	31.8	32.0	32.2	33.2	33.2	33.2	33.2	32.1	30.2	29.9	(19)	
		MCWB	22.4	22.1	22.8	23.1	24.7	25.4	25.8	25.8	25.9	25.2	25.1	23.7	(20)	
	2%	DB	28.2	29.1	29.9	30.2	31.1	32.2	33.0	32.9	32.2	31.1	29.2	28.9	(21)	
		MCWB	22.8	22.6	23.0	23.7	24.7	25.5	25.8	25.9	25.8	25.5	24.6	23.9	(22)	
	5%	DB	27.2	28.1	28.8	29.9	30.2	31.8	32.2	32.1	31.9	30.8	28.8	28.0	(23)	
		MCWB	22.4	22.5	22.5	23.5	24.2	25.5	25.5	25.7	25.7	25.5	24.2	23.4	(24)	
	10%	DB	26.8	27.1	27.8	29.0	29.8	31.0	31.9	31.9	31.1	29.9	27.9	27.1	(25)	
		MCWB	22.2	22.2	22.0	23.1	24.1	25.5	25.5	25.6	25.7	25.1	23.6	22.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.4	24.5	24.7	25.5	26.3	27.2	27.0	27.2	27.2	26.7	26.1	25.6	(27)	
		MCDB	27.1	27.6	27.7	28.7	30.2	30.8	31.1	31.1	30.7	30.2	29.0	28.0	(28)	
	2%	WB	23.7	23.7	24.0	24.7	25.7	26.6	26.6	26.7	26.7	26.4	25.5	24.7	(29)	
		MCDB	26.5	26.7	27.6	28.5	29.3	30.4	30.8	30.8	30.4	29.7	28.2	27.1	(30)	
	5%	WB	23.2	23.3	23.3	24.1	25.2	26.2	26.4	26.5	26.4	26.0	24.9	24.2	(31)	
		MCDB	26.2	26.4	27.1	28.1	28.6	30.0	30.6	30.6	30.2	29.2	27.6	26.7	(32)	
	10%	WB	22.6	22.7	22.7	23.7	24.8	25.9	26.1	26.2	26.1	25.5	24.4	23.6	(33)	
		MCDB	25.6	26.0	26.5	27.7	28.2	29.7	30.3	30.3	29.9	28.8	27.1	26.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.3	6.6	6.8	6.8	6.6	6.7	6.7	6.8	7.0	5.9	5.3	5.7	(35)	
		MCDBR	7.1	8.0	8.5	7.9	7.5	7.7	7.2	7.2	7.7	6.9	5.8	6.1	(36)	
	5% WB	MCWBR	3.8	3.8	3.7	3.4	3.2	3.1	2.8	2.9	3.1	3.2	3.0	3.2	(37)	
		MCWBR	6.7	6.9	7.5	7.0	6.5	7.0	6.7	7.0	6.5	5.1	5.7	5.7	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.366	0.374	0.390	0.410	0.436	0.471	0.476	0.452	0.422	0.414	0.390	0.389	(40)	
		taud	2.560	2.534	2.480	2.415	2.390	2.313	2.286	2.381	2.482	2.493	2.512	2.505	(41)	
	Ebn at Noon		904	917	913	894	863	826	822	846	870	865	870	864	(42)	
		Edh at Noon	93	101	111	120	122	131	135	123	109	104	97	95	(43)	
(44) All-Sky Solar Radiation	RadAvg		4.02	4.97	5.74	6.44	6.24	5.98	6.49	6.16	5.53	4.73	4.17	3.81	(44)	
	RadStd		0.25	0.21	0.23	0.23	0.51	0.37	0.36	0.24	0.25	0.31	0.24	0.27	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page