

LAS AMERICAS INTL, Dominican Republic

WMO: 784850

Lat: 18.430N

Lon: 69.669W

Elev: 59

StdP: 14.66

Time Zone: -4.00 (W04)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	64.7	66.2	59.4	75.8	71.5	61.7	82.3	71.5	18.4	80.4	16.6	81.2	6.2	20	0.340

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	14.8	91.5	79.3	90.0	79.1	89.6	79.0	82.4	88.3	81.4	87.6	80.7	87.1	10.0	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.7	159.8	87.5	79.3	152.6	86.1	78.9	150.4	85.7	46.2	88.7	45.1	88.2	44.4	87.1	86.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
16.4	14.3	12.9	DB	62.1	94.1	2.3	1.5	60.5	95.2	59.1	96.1	57.8	96.9	56.1	98.0	
			WB	60.1	83.7	2.4	1.5	58.4	84.8	57.0	85.7	55.7	86.6	53.9	87.7	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	79.4	76.5	76.5	77.1	78.5	79.9	81.3	81.7	81.9	81.7	80.8	79.2	77.6
	DBStd	2.62	1.72	1.63	1.89	1.79	1.62	1.55	1.54	1.68	1.57	1.57	1.69	1.83
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	10736	821	742	841	855	926	938	982	990	952	956	876	857
	CDD65	5261	356	322	376	405	461	488	517	525	502	491	426	392
	CDH74	44795	2398	2333	2963	3325	4089	4740	5006	5017	4748	4294	3175	2707
	CDH80	15739	665	659	906	1084	1416	1791	1994	1973	1849	1558	1022	822
Wind	WSAvg	7.2	7.4	7.6	7.8	7.5	7.2	7.2	7.4	7.2	6.8	6.5	6.9	7.2
Precipitation	PrecAvg	47.2	1.5	1.7	1.6	2.8	5.7	4.4	4.1	5.7	6.3	6.0	4.1	2.6
	PrecMax	77.1	4.8	4.0	6.5	9.3	14.3	19.3	9.5	12.2	17.2	14.2	12.1	9.6
	PrecMin	29.1	0.1	0.0	0.1	0.1	0.8	0.6	1.6	2.2	1.9	0.7	0.9	0.2
	PrecStd	12.8	1.2	1.2	1.4	2.1	4.0	4.3	2.2	3.0	3.7	3.1	2.7	2.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	87.9	87.9	88.2	89.6	89.9	91.5	92.9	93.4	93.0	91.3	89.6	88.2
		MCWB	77.3	75.4	75.3	75.9	79.5	79.2	79.4	80.5	81.3	79.0	78.3	77.6
	2%	DB	86.2	86.3	87.3	87.9	88.9	89.9	91.1	91.3	91.1	89.7	88.0	87.4
		MCWB	75.9	75.3	75.7	76.5	78.9	78.9	78.8	79.7	79.6	79.2	78.2	77.1
	5%	DB	85.3	85.6	86.0	86.4	87.8	89.2	89.7	89.8	89.6	88.2	86.5	86.0
		MCWB	75.5	75.2	75.7	76.4	78.3	78.8	78.6	79.4	79.5	79.2	77.8	76.6
	10%	DB	84.1	84.2	84.6	85.8	86.3	87.8	88.2	88.6	88.1	87.5	85.8	84.5
		MCWB	75.0	74.8	75.1	76.3	77.7	78.8	78.7	79.4	79.5	79.1	77.6	76.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.9	79.2	79.2	80.7	82.8	82.8	82.1	83.7	83.5	82.4	81.1	80.4
		MCDB	85.3	84.4	85.4	86.0	87.9	88.1	88.6	91.2	90.2	87.4	86.4	86.0
	2%	WB	78.2	77.8	77.9	79.2	80.8	81.2	80.9	82.0	81.9	81.0	80.0	79.1
		MCDB	84.2	83.9	84.6	85.1	86.7	87.2	88.0	88.8	88.1	86.9	85.7	85.0
	5%	WB	77.0	76.6	76.9	78.1	79.6	80.1	80.0	80.7	80.8	80.2	79.1	77.9
		MCDB	83.3	83.2	84.1	84.3	85.6	86.5	87.2	87.6	87.2	86.3	84.9	84.0
	10%	WB	75.9	75.6	76.0	77.2	78.6	79.4	79.3	79.8	80.0	79.5	78.2	76.9
		MCDB	82.3	82.4	83.1	83.6	84.6	85.8	86.4	86.6	86.3	85.5	83.9	83.1
Mean Daily Temperature Range	5% DB	MDBR	16.5	16.9	16.8	15.6	14.4	14.3	15.0	14.8	14.7	14.1	14.3	15.8
		MCDBR	17.8	18.0	17.5	16.5	15.5	15.5	16.1	16.1	16.1	15.3	15.3	16.7
		MCWBR	9.5	9.5	8.9	7.9	7.8	7.1	6.9	7.4	7.7	7.6	7.8	8.7
	5% WB	MCDBR	16.5	16.7	16.4	14.7	14.1	14.2	15.0	15.0	14.5	14.1	14.1	15.7
		MCWBR	10.1	10.0	9.4	8.4	8.5	7.7	7.6	7.9	8.0	7.9	8.1	9.3
Clear-Sky Solar Irradiance	taub	0.369	0.382	0.391	0.415	0.438	0.506	0.496	0.474	0.424	0.393	0.389	0.388	
	taud	2.544	2.499	2.467	2.433	2.389	2.145	2.180	2.269	2.439	2.528	2.535	2.507	
	Ebn at Noon	290	292	292	283	273	253	256	263	278	285	282	280	
	Edh at Noon	31	34	36	38	39	49	48	44	36	32	31	31	
All-Sky Solar Radiation	RadAvg	1448	1682	1861	1912	1850	1853	1889	1802	1749	1567	1446	1375	
	RadStd	59	45	74	99	106	119	112	84	116	130	97	55	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	-0.49	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	-0.49	N/A	N/A	N/A	N/A

Nomenclature: See separate page