

LAS AMERICAS INTL, Dominican Republic

WMO: 784850

Lat: 18.430N

Lon: 69.669W

Elev: 18

StdP: 101.11

Time Zone: -4.00 (W04)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	18.2	19.0	15.2	10.8	22.0	16.5	11.8	21.9	8.2	26.9	7.4	27.3	2.8	20	0.340

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.2	33.1	26.3	32.2	26.1	32.0	26.1	28.0	31.3	27.5	30.9	27.0	30.6	4.5	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.1	22.8	30.8	26.3	21.8	30.1	26.1	21.5	29.8	89.6	31.5	87.1	31.2	85.4	30.6	30.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.3	6.4	5.8	DB	16.7	34.5	1.3	0.8	15.8	35.1	15.0	35.6	14.3	36.1	13.4	36.7	(4)
(5)			WB	15.6	28.7	1.3	0.9	14.7	29.4	13.9	29.9	13.1	30.3	12.2	30.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	26.3	24.7	24.7	25.1	25.8	26.6	27.4	27.6	27.7	27.6	27.1	26.2	25.4
	DBStd	1.46	0.96	0.90	1.05	1.00	0.90	0.86	0.85	0.93	0.87	0.87	0.94	1.02
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	5964	456	412	467	475	514	521	546	550	529	531	487	476
	CDD18.3	2923	198	179	209	225	256	271	287	292	279	273	237	218
	CDH23.3	24886	1332	1296	1646	1847	2272	2633	2781	2787	2638	2386	1764	1504
CDH26.7	8744	369	366	503	602	787	995	1108	1096	1027	866	568	457	
Wind	WSAvg	3.2	3.3	3.4	3.5	3.4	3.2	3.2	3.3	3.2	3.0	2.9	3.1	3.2
Precipitation	PrecAvg	1198	38	42	41	70	144	113	105	146	159	152	104	67
	PrecMax	1959	121	101	166	235	363	491	242	310	436	360	308	243
	PrecMin	739	3	1	3	3	20	15	40	55	47	19	23	5
	PrecStd	324	30	30	36	54	101	110	57	75	93	78	68	60
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.0	31.0	31.2	32.0	32.2	33.1	33.8	34.1	33.9	32.9	32.0	31.2
		MCWB	25.2	24.1	24.1	24.4	26.4	26.2	26.4	27.0	27.4	26.1	25.7	25.3
	2%	DB	30.1	30.2	30.7	31.1	31.6	32.2	32.8	33.0	32.8	32.1	31.1	30.8
		MCWB	24.4	24.1	24.3	24.7	26.1	26.0	26.0	26.5	26.4	26.2	25.7	25.1
	5%	DB	29.6	29.8	30.0	30.2	31.0	31.8	32.1	32.1	32.0	31.2	30.3	30.0
		MCWB	24.2	24.0	24.3	24.6	25.7	26.0	25.9	26.4	26.4	26.2	25.4	24.8
	10%	DB	28.9	29.0	29.2	29.9	30.2	31.0	31.2	31.4	31.2	30.8	29.9	29.2
		MCWB	23.9	23.8	24.0	24.6	25.4	26.0	26.0	26.3	26.4	26.2	25.3	24.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.6	26.2	26.2	27.1	28.2	28.2	27.8	28.7	28.6	28.0	27.3	26.9
		MCDB	29.6	29.1	29.7	30.0	31.1	31.2	31.5	32.9	32.3	30.8	30.2	30.0
	2%	WB	25.6	25.4	25.5	26.2	27.1	27.3	27.1	27.8	27.7	27.2	26.7	26.1
		MCDB	29.0	28.8	29.2	29.5	30.4	30.7	31.1	31.6	31.2	30.5	29.8	29.4
	5%	WB	25.0	24.8	25.0	25.6	26.4	26.7	26.7	27.1	27.1	26.8	26.2	25.5
		MCDB	28.5	28.5	28.9	29.1	29.8	30.3	30.7	30.9	30.7	30.1	29.4	28.9
	10%	WB	24.4	24.2	24.4	25.1	25.9	26.3	26.3	26.6	26.7	26.4	25.7	25.0
		MCDB	27.9	28.0	28.4	28.7	29.2	29.9	30.2	30.3	30.2	29.7	28.8	28.4
Mean Daily Temperature Range	5% DB	MDBR	9.1	9.4	9.3	8.7	8.0	8.0	8.3	8.2	8.2	7.9	7.9	8.8
		MCDBR	9.9	10.0	9.7	9.2	8.6	8.6	8.9	9.0	8.9	8.5	8.5	9.3
		MCWBR	5.3	5.3	4.9	4.4	4.3	4.0	3.9	4.1	4.3	4.2	4.3	4.8
	5% WB	MCDBR	9.2	9.3	9.1	8.2	7.9	7.9	8.3	8.3	8.1	7.8	7.8	8.7
		MCWBR	5.6	5.6	5.2	4.7	4.7	4.3	4.2	4.4	4.4	4.4	4.5	5.2
Clear-Sky Solar Irradiance	taub	0.369	0.382	0.391	0.415	0.438	0.506	0.496	0.474	0.424	0.393	0.389	0.388	
	taud	2.544	2.499	2.467	2.433	2.389	2.145	2.180	2.269	2.439	2.528	2.535	2.507	
	Ebn at Noon	915	919	919	892	861	797	806	830	875	897	888	883	
	Edh at Noon	97	107	114	119	122	155	150	138	115	102	98	99	
All-Sky Solar Radiation	RadAvg	4.57	5.30	5.87	6.03	5.83	5.84	5.96	5.68	5.51	4.94	4.56	4.34	
	RadStd	0.19	0.14	0.23	0.31	0.31	0.33	0.37	0.35	0.27	0.36	0.41	0.31	0.17

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	-0.27	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	-0.27	N/A	N/A	N/A	N/A

Nomenclature: See separate page