

SANTO DOMINGO, Dominican RepublicWMO: **784860**Lat: **18.4734N**Lon: **69.8705W**Elev: **14**StdP: **101.16**Time Zone: **-4.00 (W04)**Period: **96-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.9	20.7	16.7	11.9	22.5	17.7	12.7	22.8	8.2	24.3	6.4	25.1	2.6	0	0.309

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	6.8	32.7	27.2	32.2	27.1	31.7	27.0	28.4	31.4	28.0	31.2	27.6	30.9	2.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.6	23.5	30.9	27.0	22.8	30.5	26.6	22.2	30.2	91.4	31.4	89.4	31.3	87.6	31.1	31.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.3	5.3	4.4	DB	18.8	35.2	1.1	1.6	18.0	36.4	17.3	37.4	16.7	38.3	15.9	39.5	(4)
(5)			WB	16.7	29.3	1.2	0.7	15.8	29.8	15.1	30.2	14.5	30.7	13.6	31.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	26.8	25.1	25.2	25.9	26.4	27.1	27.8	28.0	28.1	27.7	26.8	25.8	(6)	
(7)		DBStd	1.48	0.94	0.99	1.07	1.04	0.92	1.05	0.93	1.04	1.03	1.01	1.05	1.14	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6146	469	426	492	491	529	533	557	561	544	550	503	491	(10)
(11)		CDD18.3	3104	211	192	233	241	271	283	298	302	294	292	253	233	(11)
(12)		CDH23.3	28603	1411	1356	1830	2017	2621	3003	3179	3212	3161	2956	2129	1728	(12)
(13)	CDH26.7	9156	316	317	504	579	817	1036	1133	1144	1174	1020	653	463	(13)	
(14)	Wind	WSAvg	2.4	2.5	2.6	2.7	2.5	2.3	2.3	2.4	2.3	2.4	2.3	2.5	2.5	(14)
(15)	Precipitation	PrecAvg	1338	66	64	52	66	176	123	146	188	177	167	124	78	(15)
(16)		PrecMax	1967	212	247	140	262	488	450	347	453	594	623	378	314	(16)
(17)		PrecMin	871	4	0	4	7	12	8	17	63	45	18	11	18	(17)
(18)		PrecStd	281	50	59	39	55	123	92	68	86	111	111	87	56	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.5	30.4	31.1	31.9	32.1	32.7	33.1	33.4	33.5	32.8	32.2	31.2	(19)
(20)			MCWB	25.1	25.0	25.4	25.8	27.3	27.2	27.1	27.2	27.6	27.2	26.4	25.8	(20)
(21)		2%	DB	29.7	29.7	30.3	31.0	31.3	32.0	32.2	32.4	32.6	32.0	31.3	30.4	(21)
(22)			MCWB	24.7	24.8	25.4	25.8	26.9	27.2	27.1	27.3	27.5	27.1	26.3	25.4	(22)
(23)		5%	DB	29.1	29.2	29.9	30.3	30.9	31.4	31.6	31.7	31.9	31.5	30.7	29.8	(23)
(24)			MCWB	24.4	24.4	25.2	25.5	26.5	26.9	26.9	27.1	27.3	26.9	26.1	25.1	(24)
(25)		10%	DB	28.5	28.6	29.3	29.7	30.3	30.8	31.1	31.2	31.3	30.9	30.1	29.2	(25)
(26)			MCWB	24.2	24.1	24.8	25.2	26.2	26.7	26.7	27.0	27.0	26.7	25.6	24.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.4	26.5	27.5	27.7	28.8	28.6	28.5	28.7	29.1	28.4	27.7	27.2	(27)
(28)			MADB	29.2	29.4	30.1	30.5	31.0	31.5	31.4	31.5	32.3	31.4	30.9	29.9	(28)
(29)		2%	WB	25.5	25.6	26.5	26.9	27.9	27.8	27.8	28.0	28.2	27.8	27.1	26.2	(29)
(30)			MADB	28.7	28.8	29.6	30.0	30.6	31.1	31.2	31.4	31.7	31.1	30.5	29.5	(30)
(31)		5%	WB	25.0	25.0	25.8	26.2	27.1	27.3	27.4	27.5	27.6	27.3	26.5	25.7	(31)
(32)			MADB	28.4	28.4	29.1	29.5	30.0	30.7	30.8	31.0	31.2	30.8	29.9	29.0	(32)
(33)		10%	WB	24.5	24.5	25.2	25.6	26.5	26.8	26.9	27.1	27.2	26.9	26.0	25.1	(33)
(34)			MADB	27.8	27.9	28.5	28.9	29.5	30.2	30.5	30.7	30.7	30.4	29.4	28.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.2	7.4	7.4	6.9	6.5	6.3	6.6	6.8	6.6	6.9	7.1	(35)	
(36)			MADB	7.9	7.9	7.8	7.5	7.1	6.8	7.2	7.1	7.4	7.3	7.6	7.6	(36)
(37)			MCWBR	4.1	4.2	4.2	3.9	3.8	3.4	3.6	3.5	3.8	3.6	3.8	3.8	(37)
(38)		5% WB	MADB	7.4	7.5	7.5	7.0	6.6	6.5	6.8	6.9	7.1	6.9	7.1	7.2	(38)
(39)			MCWBR	4.4	4.5	4.8	4.3	4.4	3.6	3.8	3.8	4.1	3.9	4.0	4.2	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.370	0.384	0.393	0.419	0.442	0.509	0.498	0.475	0.427	0.394	0.389	0.389	(40)
(41)		taud		2.541	2.495	2.461	2.421	2.376	2.132	2.173	2.262	2.428	2.522	2.534	2.503	(41)
(42)		Ebn at Noon		914	918	917	889	858	794	805	829	872	895	887	882	(42)
(43)		Edh at Noon		98	107	114	120	124	157	151	139	117	103	98	99	(43)
(44)	All-Sky Solar Radiation	RadAvg		4.58	5.29	5.86	5.99	5.79	5.86	5.99	5.73	5.55	4.95	4.56	4.34	(44)
(45)		RadStd		0.19	0.16	0.23	0.32	0.33	0.37	0.35	0.27	0.38	0.41	0.30	0.17	(45)