

LADYVILLE GOLDSON INTL, Belize

WMO: 785830

Lat: 17.539N

Lon: 88.308W

Elev: 15

StdP: 14.69

Time Zone: -6.00 (W06)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	62.9	65.3	57.7	71.2	68.4	60.0	77.3	69.2	17.7	77.4	16.4	77.6	3.7	290	0.343

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.6	91.5	80.8	90.0	80.4	89.7	80.3	82.7	88.4	82.0	87.7	81.6	87.3	9.2	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.9	160.7	86.6	80.6	158.7	86.3	79.9	155.2	85.7	46.6	89.0	45.9	88.0	45.2	88.2	86.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
16.5	15.3	14.1	DB	58.1	95.3	1.5	2.2	57.0	96.8	56.2	98.1	55.3	99.3	54.2	100.8	
			WB	57.1	84.3	1.5	1.0	56.0	85.0	55.2	85.6	54.3	86.2	53.2	86.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	80.6	75.6	77.5	79.2	81.8	83.4	83.6	83.3	83.6	83.3	81.2	78.1	76.6
	DBStd	4.02	3.56	3.49	3.36	2.68	2.14	2.18	1.86	1.83	1.91	2.65	3.07	3.57
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11180	793	770	907	954	1036	1009	1034	1043	999	967	844	824
	CDD65	5705	328	350	442	504	571	559	569	578	549	502	394	359
	CDH74	58355	2075	2757	4036	5377	6696	6724	6881	7034	6412	4922	2994	2447
	CDH80	20266	373	609	1090	1845	2622	2686	2719	2899	2550	1622	740	511
Wind	WSAvg	7.0	6.5	7.2	8.0	8.3	8.4	8.1	7.9	6.7	5.7	5.9	6.0	5.8
Precipitation	PrecAvg	76.6	5.5	2.8	2.2	1.8	4.8	10.0	8.6	8.0	10.0	10.1	8.1	6.1
	PrecMax	112.2	17.3	7.6	9.4	6.4	24.6	25.8	25.9	21.7	21.1	30.9	18.5	16.1
	PrecMin	52.1	1.1	0.1	0.2	0.0	0.0	0.5	0.5	1.9	3.8	2.6	0.3	0.6
	PrecStd	13.1	3.3	2.0	1.9	1.5	4.5	5.7	4.4	3.7	3.9	5.6	4.6	4.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	86.4	88.2	91.3	92.1	91.8	91.7	90.0	91.7	92.3	90.9	88.2	87.7
		MCWB	77.3	78.4	79.7	80.6	80.8	81.1	80.4	81.0	81.2	80.6	79.5	79.3
	2%	DB	84.6	86.1	87.9	89.6	90.1	90.0	89.7	90.0	91.0	89.5	87.1	85.9
		MCWB	76.6	77.3	78.5	79.8	80.1	80.5	80.3	80.6	81.1	80.2	78.9	78.2
	5%	DB	83.9	84.6	86.3	88.1	89.5	89.5	88.8	89.7	89.7	88.1	85.8	84.4
		MCWB	76.2	76.4	77.6	78.9	79.9	80.4	80.3	80.5	80.7	79.8	78.0	77.0
	10%	DB	82.3	83.9	85.3	87.4	88.1	88.1	88.0	88.9	88.8	87.3	84.3	82.8
		MCWB	75.3	76.0	76.9	78.5	79.6	80.3	80.2	80.5	80.6	79.5	76.8	76.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	78.9	80.1	81.0	82.8	82.8	83.3	82.6	82.8	83.5	82.6	80.9	80.2
		MCDB	84.2	86.1	88.0	89.5	89.2	89.2	87.3	88.3	89.1	87.7	86.3	85.0
	2%	WB	77.8	78.3	79.5	81.2	81.8	82.1	81.7	82.2	82.4	81.5	79.9	79.1
		MCDB	83.0	84.1	86.0	87.3	88.1	87.6	87.0	87.8	88.2	86.8	85.0	84.0
	5%	WB	77.0	77.5	78.4	80.1	81.0	81.4	81.0	81.5	81.7	80.7	79.1	78.2
		MCDB	82.1	83.0	84.3	86.0	87.2	87.0	86.7	87.3	87.5	86.2	83.9	82.8
	10%	WB	76.2	76.5	77.7	79.4	80.3	80.8	80.5	80.9	81.0	80.0	78.3	77.3
		MCDB	80.9	81.8	83.4	85.2	86.3	86.5	86.5	86.9	86.8	85.2	82.6	81.8
Mean Daily Temperature Range	5% DB	MDBR	12.3	12.1	11.9	11.5	10.3	9.4	9.7	10.6	11.3	11.2	11.8	12.1
		MCDBR	12.4	12.0	11.8	11.8	11.0	10.4	10.3	11.2	12.1	12.1	12.5	12.4
		MCWBR	6.0	5.5	5.0	4.8	4.4	4.3	4.3	4.6	5.2	5.1	5.5	6.0
	5% WB	MCDBR	11.5	11.4	11.1	11.1	10.0	9.7	9.8	10.6	11.5	10.9	11.0	11.2
		MCWBR	5.9	5.6	5.0	4.9	4.4	4.8	4.6	5.0	5.4	5.0	5.5	5.9
Clear-Sky Solar Irradiance	taub	0.373	0.383	0.411	0.477	0.511	0.472	0.503	0.470	0.437	0.411	0.388	0.386	
	taud	2.555	2.518	2.421	2.222	2.143	2.302	2.176	2.293	2.392	2.491	2.531	2.533	
	Ebn at Noon	290	292	286	266	254	261	254	265	274	280	283	282	
	Edh at Noon	31	33	38	46	50	42	48	43	38	34	31	31	
All-Sky Solar Radiation	RadAvg	1266	1545	1816	1963	1822	1655	1728	1749	1656	1409	1308	1233	
	RadStd	107	116	107	91	115	137	103	106	95	120	86	79	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page