

LADYVILLE GOLDSON INTL, Belize

WMO: 785830

Lat: 17.539N

Lon: 88.308W

Elev: 5

StdP: 101.27

Time Zone: -6.00 (W06)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	17.2	18.5	14.3	10.2	20.2	15.6	11.0	20.7	7.9	25.2	7.3	25.4	1.7	290	0.343

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.9	33.0	27.1	32.2	26.9	32.1	26.9	28.1	31.3	27.8	31.0	27.5	30.7	4.1	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.2	23.0	30.3	27.0	22.7	30.2	26.6	22.2	29.8	90.5	31.7	88.8	31.1	87.3	31.2	30.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.4	6.8	6.3	14.5	35.1	0.8	1.2	13.9	36.0	13.4	36.7	13.0	37.4	12.4	38.2		
			14.0	29.0	0.8	0.6	13.4	29.4	12.9	29.8	12.4	30.1	11.8	30.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	27.0	24.2	25.3	26.2	27.7	28.6	28.7	28.5	28.7	28.5	27.3	25.6	24.8	(6)
(7)		DBStd	2.23	1.98	1.94	1.87	1.49	1.19	1.21	1.03	1.02	1.06	1.47	1.71	1.98	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6211	441	428	504	530	576	561	574	579	555	537	469	458	(10)
(11)		CDD18.3	3169	182	194	246	280	317	311	316	321	305	279	219	199	(11)
(12)		CDH23.3	32419	1153	1532	2242	2987	3720	3736	3823	3908	3562	2734	1663	1359	(12)
(13)	CDH26.7	11259	207	338	606	1025	1457	1492	1511	1611	1417	901	411	284	(13)	
(14)	Wind	WSAvg	3.1	2.9	3.2	3.6	3.7	3.7	3.6	3.5	3.0	2.5	2.6	2.7	2.6	(14)
(15)	Precipitation	PrecAvg	1945	140	70	57	45	121	254	218	204	253	257	206	156	(15)
(16)		PrecMax	2850	440	194	240	163	626	655	658	551	536	785	471	408	(16)
(17)		PrecMin	1323	29	3	5	1	0	12	12	47	97	67	8	16	(17)
(18)		PrecStd	334	83	51	48	39	115	144	113	93	99	142	117	103	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.2	31.2	33.0	33.4	33.2	33.2	32.2	33.1	33.5	32.7	31.2	30.9	(19)
MCWB			25.2	25.8	26.5	27.0	27.1	27.3	26.9	27.2	27.3	27.0	26.4	26.3	(20)	
2%		DB	29.2	30.1	31.1	32.0	32.3	32.2	32.0	32.2	32.8	32.0	30.6	30.0	(21)	
		MCWB	24.8	25.2	25.8	26.5	26.7	27.0	26.8	27.0	27.3	26.8	26.1	25.7	(22)	
5%		DB	28.8	29.2	30.2	31.2	31.9	31.9	31.6	32.0	32.1	31.2	29.9	29.1	(23)	
		MCWB	24.6	24.6	25.3	26.1	26.6	26.9	26.8	27.0	27.1	26.6	25.5	25.0	(24)	
10%		DB	28.0	28.8	29.6	30.8	31.2	31.2	31.1	31.6	31.5	30.7	29.0	28.2	(25)	
		MCWB	24.0	24.4	24.9	25.9	26.5	26.8	26.8	26.9	27.0	26.4	24.9	24.5	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.0	26.7	27.2	28.2	28.2	28.5	28.1	28.2	28.6	28.1	27.2	26.8	(27)
MCDWB			29.0	30.1	31.1	31.9	31.8	31.8	30.7	31.3	31.7	30.9	30.1	29.4	(28)	
2%		WB	25.5	25.7	26.4	27.3	27.7	27.8	27.6	27.9	28.0	27.5	26.6	26.2	(29)	
		MCDWB	28.4	28.9	30.0	30.7	31.2	30.9	30.5	31.0	31.2	30.4	29.4	28.9	(30)	
5%		WB	25.0	25.3	25.8	26.7	27.2	27.4	27.2	27.5	27.6	27.1	26.2	25.7	(31)	
		MCDWB	27.8	28.3	29.1	30.0	30.6	30.5	30.4	30.7	30.8	30.1	28.8	28.2	(32)	
10%		WB	24.5	24.7	25.4	26.3	26.8	27.1	27.0	27.2	27.2	26.7	25.7	25.2	(33)	
		MCDWB	27.2	27.7	28.6	29.6	30.2	30.3	30.3	30.5	30.5	29.5	28.1	27.7	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.8	6.7	6.6	6.4	5.7	5.2	5.4	5.9	6.3	6.2	6.6	6.7	(35)
MCDBR			6.9	6.7	6.5	6.5	6.1	5.8	5.7	6.2	6.7	6.7	6.9	6.9	(36)	
MCWBR			3.3	3.1	2.8	2.7	2.4	2.4	2.4	2.6	2.9	2.8	3.1	3.3	(37)	
5% WB		MCDBR	6.4	6.3	6.2	6.1	5.6	5.4	5.4	5.9	6.4	6.0	6.1	6.2	(38)	
		MCWBR	3.3	3.1	2.8	2.7	2.5	2.6	2.6	2.8	3.0	2.8	3.0	3.3	(39)	
																(39)
(40)	Clear-Sky Solar Irradiance	taub	0.373	0.383	0.411	0.477	0.511	0.472	0.503	0.470	0.437	0.411	0.388	0.386	(40)	
taud		2.555	2.518	2.421	2.222	2.143	2.302	2.176	2.293	2.392	2.491	2.531	2.533	(41)		
Ebn at Noon		914	921	902	839	800	824	800	834	864	882	891	889	(42)		
Edh at Noon		97	105	119	146	157	132	150	135	121	107	99	97	(43)		
(44)	All-Sky Solar Radiation	RadAvg	3.99	4.87	5.73	6.19	5.74	5.22	5.45	5.51	5.22	4.44	4.12	3.89	(44)	
(45)		RadStd	0.34	0.37	0.34	0.29	0.36	0.43	0.33	0.34	0.30	0.38	0.27	0.25	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page