

HUEHUETENANGO, Guatemala

WMO: 786270

Lat: 15.317N

Lon: 91.467W

Elev: 6237

StdP: 11.67

Time Zone: -6.00 (W06)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	39.1	41.4	27.8	27.4	78.5	32.4	33.9	73.0	18.4	70.0	16.5	70.4	0.0	100	0.357

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	23.0	85.2	58.2	82.8	58.7	81.0	59.0	65.5	76.0	64.6	74.4	63.8	73.3	7.7	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.8	108.1	67.2	61.9	104.6	65.9	61.1	101.8	64.9	34.2	76.0	33.4	74.8	32.7	73.5	78.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years						
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max				
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
16.4	14.1	12.2	DB	33.8	88.9	2.0	1.5	32.4	90.0	31.2	90.8	30.1	91.7	28.7	92.7	
			WB	33.0	69.8	2.0	3.5	31.6	72.4	30.4	74.4	29.3	76.4	27.8	79.0	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	64.9	60.3	62.5	64.6	67.2	68.1	67.2	66.2	66.9	67.1	65.7	62.3	60.8
	DBStd	3.90	3.38	3.27	3.78	3.15	2.57	2.07	2.02	1.90	1.74	3.04	3.60	3.21
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	583	148	80	53	14	5	6	11	6	4	27	93	136
	CDD50	5449	320	351	454	515	562	516	503	524	513	487	370	334
	CDD65	555	3	11	41	79	102	72	48	65	67	49	13	5
	CDH74	5150	232	542	879	1061	698	271	276	394	238	206	159	194
	CDH80	734	19	96	207	246	104	12	7	15	5	8	6	9
(14) Wind	WSAvg	2.9	3.2	3.8	4.0	3.0	2.2	2.6	4.4	3.5	2.1	1.8	2.1	2.7
(15) Precipitation	PrecAvg	39.5	0.2	0.4	0.9	1.4	4.4	8.0	4.5	5.0	8.5	5.5	1.1	0.2
	PrecMax	60.6	1.3	3.6	2.9	4.1	9.1	16.4	11.1	13.5	13.9	14.1	4.5	0.9
	PrecMin	27.8	0.0	0.0	0.0	0.0	0.4	3.1	0.9	1.3	2.1	0.4	0.0	0.0
	PrecStd	8.9	0.4	0.7	1.0	1.4	2.2	3.6	2.1	3.1	3.0	3.5	1.3	0.3
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	82.6	86.0	88.0	87.8	85.6	81.0	80.8	82.1	80.5	80.8	80.7	80.9
		MCWB	56.1	55.9	56.7	59.0	60.3	62.9	61.0	61.0	62.9	62.9	58.8	58.1
	2%	DB	79.2	82.6	84.5	85.4	82.6	78.9	78.8	79.2	78.6	78.6	78.4	78.6
		MCWB	55.6	56.1	57.0	58.8	61.4	62.9	61.0	61.1	62.4	62.5	59.6	57.3
	5%	DB	76.9	80.4	82.3	82.7	80.7	77.1	77.1	78.3	76.9	76.6	75.5	76.5
		MCWB	55.8	56.4	57.1	59.0	61.4	62.1	60.6	61.2	62.2	62.2	59.4	57.0
	10%	DB	73.8	77.3	79.1	80.5	78.6	75.2	75.3	76.6	75.0	73.7	73.2	73.5
		MCWB	56.2	55.9	56.7	59.0	61.5	62.0	60.5	60.9	62.1	61.8	58.9	57.0
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	60.7	61.0	63.0	65.4	66.4	66.1	64.8	65.1	65.8	66.2	64.4	62.4
		MCDB	75.2	77.3	75.5	78.5	78.4	76.8	74.7	75.2	75.8	76.5	74.1	74.0
	2%	WB	59.3	59.6	61.3	63.5	64.9	64.8	63.4	63.7	64.6	64.7	62.6	60.5
		MCDB	72.4	75.4	74.3	75.8	76.0	74.4	73.3	73.5	73.6	73.6	71.7	71.7
	5%	WB	58.3	58.5	60.2	62.2	63.7	63.8	62.6	62.8	63.6	63.6	61.4	59.3
		MCDB	70.9	73.5	73.1	74.5	74.0	72.7	72.5	72.5	72.2	71.8	70.3	70.7
	10%	WB	57.2	57.7	59.1	61.1	62.8	63.0	61.8	62.1	62.8	62.7	60.4	58.3
		MCDB	69.5	72.0	71.7	72.7	72.5	71.4	70.9	71.3	71.3	70.5	68.9	69.3
(35) Mean Daily Temperature Range	5% DB	MDBR	29.0	32.0	31.9	29.7	23.0	19.0	20.8	21.5	19.2	19.5	23.6	27.9
		MCDBR	34.7	37.2	35.7	32.4	26.3	20.9	23.0	23.8	21.0	22.2	27.3	32.8
	5% WB	MCWBR	14.1	13.8	12.2	10.6	8.4	7.0	8.1	8.0	7.2	8.3	11.3	14.0
		MCWBR	28.0	31.6	30.3	27.6	22.0	18.8	20.0	20.7	19.0	19.2	22.1	27.5
(40) Clear-Sky Solar Irradiance	taub	0.317	0.334	0.391	0.466	0.521	0.416	0.416	0.402	0.402	0.372	0.339	0.321	0.321
		taud	2.548	2.490	2.297	2.081	1.955	2.315	2.310	2.351	2.341	2.456	2.515	2.542
	Ebn at Noon	311	309	293	269	251	276	277	284	285	293	301	307	307
		Edh at Noon	31	35	43	54	60	41	42	40	41	35	32	31
(44) All-Sky Solar Radiation	RadAvg	1525	1724	1879	1868	1603	1541	1706	1710	1513	1422	1466	1479	1479
	RadStd	80	99	98	73	131	98	141	112	117	126	92	86	86

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page