

HUEHUETENANGO, Guatemala

WMO: 786270

Lat: 15.317N

Lon: 91.467W

Elev: 1901

StdP: 80.48

Time Zone: -6.00 (W06)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	4.0	5.2	-2.3	3.9	25.8	0.2	4.8	22.8	8.2	21.1	7.4	21.3	0.0	100	0.357

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	12.8	29.6	14.5	28.2	14.9	27.2	15.0	18.6	24.4	18.1	23.6	17.6	22.9	3.4	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.1	15.4	19.5	16.6	14.9	18.8	16.2	14.5	18.3	61.6	24.5	59.9	23.8	58.1	23.0	26.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.3	6.3	5.4	1.0	31.6	1.1	0.8	0.2	32.2	-0.4	32.7	-1.0	33.1	-1.8	33.7		
			0.6	21.0	1.1	2.0	-0.2	22.4	-0.9	23.6	-1.5	24.7	-2.3	26.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.3	15.7	17.0	18.1	19.5	20.1	19.6	19.0	19.4	19.5	18.7	16.9	16.0
	DBStd	2.17	1.88	1.81	2.10	1.75	1.43	1.15	1.12	1.06	0.97	1.69	2.00	1.78
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	324	82	44	29	8	3	3	6	3	2	15	52	76
	CDD10.0	3027	178	195	252	286	312	287	279	291	285	271	206	186
	CDD18.3	308	2	6	23	44	57	40	27	36	37	27	7	3
	CDH23.3	2861	129	301	488	589	388	151	153	219	132	114	88	108
	CDH26.7	408	11	53	115	137	58	7	4	8	3	4	3	5
Wind	WSAvg	1.3	1.4	1.7	1.8	1.3	1.0	1.2	2.0	1.6	1.0	0.8	0.9	1.2
Precipitation	PrecAvg	1003	5	10	22	36	113	203	114	128	217	139	28	6
	PrecMax	1540	34	91	73	104	230	417	283	344	353	358	115	24
	PrecMin	705	0	0	0	0	11	80	23	32	54	11	0	0
	PrecStd	226	9	19	26	35	57	91	54	79	76	89	33	8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.1	30.0	31.1	31.0	29.8	27.2	27.1	27.8	27.0	27.1	27.0	27.2
		MCWB	13.4	13.3	13.7	15.0	15.7	17.2	16.1	16.1	17.1	17.2	14.9	14.5
	2%	DB	26.2	28.1	29.2	29.7	28.1	26.1	26.0	26.2	25.9	25.9	25.8	25.9
		MCWB	13.1	13.4	13.9	14.9	16.3	17.2	16.1	16.2	16.9	16.9	15.3	14.1
	5%	DB	25.0	26.9	27.9	28.2	27.0	25.0	25.0	25.7	25.0	24.8	24.2	24.7
		MCWB	13.2	13.5	13.9	15.0	16.3	16.7	15.9	16.2	16.8	16.8	15.2	13.9
	10%	DB	23.2	25.1	26.2	27.0	25.9	24.0	24.1	24.8	23.9	23.2	22.9	23.1
		MCWB	13.4	13.3	13.7	15.0	16.4	16.6	15.8	16.1	16.7	16.6	15.0	13.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.0	16.1	17.2	18.5	19.1	18.9	18.2	18.4	18.8	19.0	18.0	16.9
		MCDB	24.0	25.2	24.2	25.8	25.8	24.9	23.7	24.0	24.3	24.7	23.4	23.4
	2%	WB	15.1	15.3	16.3	17.5	18.3	18.2	17.4	17.6	18.1	18.1	17.0	15.8
		MCDB	22.4	24.1	23.5	24.4	24.5	23.5	22.9	23.0	23.1	23.1	22.0	22.0
	5%	WB	14.6	14.7	15.6	16.8	17.6	17.7	17.0	17.1	17.5	17.5	16.4	15.2
		MCDB	21.6	23.1	22.8	23.6	23.4	22.6	22.5	22.5	22.3	22.1	21.3	21.5
	10%	WB	14.0	14.3	15.0	16.2	17.1	17.2	16.6	16.7	17.1	17.0	15.8	14.6
		MCDB	20.9	22.2	22.1	22.6	22.5	21.9	21.6	21.9	21.8	21.4	20.5	20.7
Mean Daily Temperature Range	5% DB	MDBR	16.1	17.8	17.7	16.5	12.8	10.5	11.6	11.9	10.7	10.8	13.1	15.5
		MCDBR	19.3	20.7	19.8	18.0	14.6	11.6	12.8	13.2	11.7	12.3	15.2	18.2
		MCWBR	7.8	7.6	6.8	5.9	4.7	3.9	4.5	4.5	4.0	4.6	6.3	7.8
	5% WB	MCDBR	15.5	17.6	16.8	15.3	12.2	10.4	11.1	11.5	10.6	10.7	12.3	15.3
		MCWBR	6.7	6.9	6.1	5.3	4.3	3.8	4.2	4.1	3.9	4.3	5.4	6.9
Clear-Sky Solar Irradiance	taub		0.317	0.334	0.391	0.466	0.521	0.416	0.416	0.402	0.402	0.372	0.339	0.321
	taud		2.548	2.490	2.297	2.081	1.955	2.315	2.310	2.351	2.341	2.456	2.515	2.542
	Ebn at Noon		981	975	923	849	791	870	872	894	899	923	949	967
	Edh at Noon		98	109	136	169	189	130	131	127	128	111	101	97
All-Sky Solar Radiation	RadAvg		4.81	5.44	5.92	5.89	5.05	4.86	5.38	5.39	4.77	4.48	4.62	4.66
	RadStd		0.25	0.31	0.31	0.23	0.41	0.31	0.44	0.35	0.37	0.40	0.29	0.27

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page