

LA CEIBA GOLOSON, Honduras

WMO: 787050

Lat: 15.742N

Lon: 86.853W

Elev: 15

StdP: 101.15

Time Zone: -6.00 (W06)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	17.4	18.2	15.8	11.2	19.2	16.8	12.0	19.7	8.3	24.4	7.3	24.8	1.0	190	0.264

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	7.9	32.8	26.7	32.1	26.5	31.9	26.4	27.7	31.3	27.2	31.0	27.0	30.8	4.0	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.6	22.3	30.3	26.2	21.6	30.0	26.0	21.3	29.8	88.1	31.7	86.4	31.3	85.1	30.7	29.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.0	6.8	5.8	DB	15.0	34.3	1.6	1.5	13.9	35.4	12.9	36.3	12.0	37.1	10.8	38.2	
			WB	14.3	28.2	1.3	0.5	13.3	28.5	12.6	28.8	11.8	29.1	10.9	29.4	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	25.6	23.1	24.0	24.4	25.9	27.0	27.4	27.1	27.1	27.3	26.0	24.1	23.5
	DBStd	2.02	1.57	1.27	1.53	1.55	1.11	0.86	0.69	0.64	0.71	1.37	1.57	1.52
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	5687	405	391	445	477	528	522	531	531	518	497	423	419
	CDD18.3	2646	147	158	187	227	269	272	272	273	268	239	173	161
	CDH23.3	23359	791	1121	1547	2225	2818	2837	2789	2779	2690	1921	972	871
(14) Wind	WSAvg	1.9	1.9	1.9	2.1	2.0	2.1	2.2	2.6	2.1	1.7	1.7	1.7	1.6
	PrecAvg	2124	256	165	137	45	78	131	102	136	195	282	324	227
	PrecMax	3378	650	470	429	135	189	260	229	273	456	771	843	728
	PrecMin	1128	30	8	0	0	3	23	10	19	33	0	16	0
	PrecStd	606	186	111	115	43	52	64	55	69	104	194	206	166
	DB	29.8	30.2	31.9	32.9	33.1	33.1	32.5	33.0	33.1	32.2	31.1	30.2	
	MCWB	24.5	24.9	25.0	26.9	26.4	27.0	26.2	27.2	26.9	26.9	25.9	25.2	
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	2% DB	29.0	29.7	30.5	31.8	32.1	32.2	32.0	32.1	32.2	31.7	30.1	29.2	
	2% MCWB	24.3	24.6	25.2	26.5	26.4	26.6	26.1	26.6	26.7	26.6	25.6	24.6	
	5% DB	28.2	29.1	29.9	31.0	31.7	31.9	31.4	31.8	31.9	31.0	29.1	28.4	
	5% MCWB	23.9	24.4	25.0	26.1	26.3	26.5	26.1	26.5	26.6	26.3	24.9	24.2	
	10% DB	27.6	28.4	29.1	30.2	31.0	31.1	31.0	31.1	31.2	30.2	28.2	27.8	
	10% MCWB	23.6	24.0	24.5	25.6	26.2	26.3	26.1	26.3	26.4	25.8	24.4	23.9	
	WB	25.7	26.2	26.7	28.1	27.7	28.0	27.3	27.8	28.1	27.9	26.7	25.9	
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	MCDB	28.4	29.1	29.9	31.0	31.4	32.0	30.9	31.6	31.5	31.3	29.2	29.2	
	2% WB	24.8	25.5	26.0	27.1	27.1	27.3	26.8	27.3	27.4	27.0	26.1	25.2	
	2% MCDB	27.9	28.7	29.4	30.7	31.0	31.2	30.6	31.1	31.2	30.7	29.2	28.3	
	5% WB	24.3	24.8	25.5	26.5	26.7	26.9	26.6	26.9	27.0	26.5	25.4	24.7	
	5% MCDB	27.5	28.2	29.0	30.2	30.6	30.7	30.4	30.7	31.0	30.1	28.6	27.7	
	10% WB	23.7	24.3	24.9	26.0	26.3	26.5	26.3	26.5	26.6	26.1	24.8	24.1	
	10% MCDB	26.8	27.7	28.5	29.6	30.2	30.3	30.1	30.4	30.5	29.6	27.7	27.1	
(35) Mean Daily Temperature Range	MDBR	7.3	8.5	9.0	8.7	8.3	7.9	8.4	8.6	8.4	7.6	7.1	7.3	
	5% DB	9.0	9.4	9.9	9.0	8.7	8.5	8.9	9.2	8.9	8.8	8.7	8.9	
	5% WB	5.3	5.4	5.5	4.8	4.3	4.2	4.4	4.7	4.6	4.7	5.0	5.0	
	MCDBR	8.7	9.2	9.5	8.6	8.2	8.1	8.5	8.7	8.5	8.3	8.2	8.5	
	MCWBR	5.4	5.5	5.7	5.0	4.4	4.2	4.4	4.7	4.6	4.7	5.0	5.0	
(40) Clear-Sky Solar Irradiance	taub	0.378	0.386	0.402	0.482	0.511	0.464	0.472	0.449	0.428	0.409	0.397	0.401	
	taud	2.549	2.519	2.464	2.209	2.154	2.340	2.296	2.380	2.433	2.502	2.517	2.497	
	Ebn at Noon	915	922	912	836	800	830	825	853	875	887	888	880	
	Edh at Noon	99	106	115	149	155	127	133	124	117	107	101	102	
(44) All-Sky Solar Radiation		RadAvg	3.89	4.90	5.68	5.94	5.60	5.47	5.60	5.76	5.53	4.32	3.71	3.67
(45)		RadStd	0.47	0.44	0.45	0.26	0.33	0.33	0.25	0.28	0.26	0.54	0.39	0.38

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(47) Regional (4 neighbors)		(m)								
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page