

SOTO CANO AB, Honduras

WMO: 787210

Lat: 14.382N

Lon: 87.621W

Elev: 2061

StdP: 13.63

Time Zone: -6.00 (W06)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 11	(b) 58.8	(c) 60.6	(d) 48.5	(e) 54.4	(f) 83.1	(g) 51.4	(h) 60.8	(i) 82.7	(j) 25.2	(k) 73.5	(l) 23.4	(m) 73.9	(n) 5.6	(o) 350	(p) 0.359

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 4	(b) 24.6	(c) 96.1	(d) 70.2	(e) 94.2	(f) 69.9	(g) 92.6	(h) 70.0	(i) 80.5	(j) 84.5	(k) 78.7	(l) 83.1	(m) 76.9	(n) 82.9	(o) 10.7	(p) 190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.4	165.1	83.3	77.5	154.5	81.6	75.4	144.0	79.5	46.1	84.7	44.0	83.3	42.0	82.5	86.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.2	21.2	19.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			52.5	77.8	1.5	2.2	51.4	79.4	50.5	80.7	49.7	81.9	48.6	83.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	77.0	73.4	75.7	77.7	80.9	80.3	78.9	78.5	78.7	77.6	75.8	73.2	73.1
	DBStd	3.79	3.48	3.36	3.82	2.73	2.44	1.97	1.83	1.70	1.35	2.59	3.18	3.24
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	3	2	0	0	0	0	0	0	0	0	0	0	1
	CDD50	9853	727	719	860	927	941	867	882	889	829	799	696	717
	CDD65	4381	264	299	395	477	476	417	417	424	379	334	246	253
	CDH74	33769	1870	2685	3769	4772	4029	3123	3266	3131	2354	1893	1300	1577
	CDH80	14158	662	1207	1862	2471	1838	1258	1374	1314	835	548	314	475
Wind	WSAvg	8.7	11.1	10.0	11.1	9.1	7.4	6.0	6.9	6.4	6.1	8.6	11.7	10.8
Precipitation	PrecAvg	52.0	1.3	0.8	1.1	1.6	5.2	7.9	6.3	7.1	8.5	7.0	2.6	1.3
	PrecMax	65.1	2.7	1.6	2.9	5.4	9.1	14.4	11.3	17.0	13.9	16.8	6.7	2.5
	PrecMin	38.5	0.7	0.3	0.4	0.2	1.7	3.0	3.7	3.0	4.4	2.5	0.9	0.7
	PrecStd	6.9	0.4	0.3	0.6	1.4	2.0	2.6	2.0	3.0	2.5	3.2	1.3	0.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.3	95.1	97.1	98.6	98.5	93.5	93.3	93.6	89.9	89.7	88.1	89.7
		MCWB	68.3	68.2	69.1	69.8	71.6	75.4	70.0	71.0	74.2	72.9	72.2	71.6
	2%	DB	88.7	92.9	95.0	96.5	94.5	91.1	91.3	91.3	88.1	87.4	85.8	87.7
		MCWB	68.1	68.1	68.7	70.1	71.8	74.3	70.5	71.8	74.7	74.7	71.6	70.5
	5%	DB	86.4	90.0	92.9	94.6	92.0	89.3	89.5	89.4	87.2	85.5	83.9	85.6
		MCWB	67.7	67.2	68.3	69.6	71.9	74.2	71.0	72.3	74.8	75.4	71.6	70.0
	10%	DB	84.1	87.8	89.9	91.8	89.6	87.4	87.6	87.6	85.6	83.3	81.3	82.7
		MCWB	68.0	66.8	67.5	69.3	72.2	74.0	71.4	72.3	74.7	74.7	71.6	69.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.9	71.7	72.7	75.1	79.6	82.5	76.5	76.5	81.3	82.5	78.4	76.9
		MCDB	84.1	86.2	86.5	86.6	84.0	87.4	85.3	84.8	86.0	85.5	81.5	83.8
	2%	WB	70.6	70.4	71.5	73.6	77.1	80.0	74.7	75.2	79.4	80.4	76.0	74.7
		MCDB	82.2	83.8	84.6	85.0	84.9	85.2	83.9	84.6	84.2	83.1	81.2	81.1
	5%	WB	69.5	69.3	70.5	72.7	75.4	77.7	73.8	74.4	77.1	78.2	74.2	72.8
		MCDB	80.3	81.9	83.6	84.4	84.0	83.6	83.2	83.2	82.7	81.1	79.6	79.6
	10%	WB	68.7	68.5	69.6	71.8	74.1	75.7	73.0	73.6	75.0	75.5	72.5	71.1
		MCDB	78.7	80.5	82.5	83.9	82.9	82.6	82.1	82.0	81.9	80.3	77.8	78.1
Mean Daily Temperature Range	5% DB	MDBR	20.5	23.9	24.7	24.6	21.1	18.9	19.6	19.7	17.9	16.1	16.6	19.0
		MCDBR	25.8	28.8	28.5	27.4	24.2	21.2	22.9	22.5	19.7	19.2	20.5	24.1
		MCWBR	8.4	8.1	7.6	6.6	6.4	7.8	6.6	6.9	7.9	8.7	8.3	9.0
	5% WB	MCDBR	21.7	24.6	25.9	24.0	20.0	19.4	18.8	19.8	18.1	16.2	16.6	18.9
		MCWBR	7.6	7.4	7.2	6.1	7.3	10.4	6.6	6.8	10.6	11.7	9.2	8.8
Clear-Sky Solar Irradiance	taub	0.361	0.375	0.401	0.499	0.563	0.467	0.463	0.454	0.453	0.416	0.390	0.378	
	taud	2.507	2.469	2.385	2.083	1.932	2.256	2.251	2.286	2.287	2.417	2.467	2.479	
	Ebn at Noon	297	297	290	261	240	262	264	269	271	280	285	288	
	Edh at Noon	33	36	40	54	61	44	44	43	43	37	34	33	
All-Sky Solar Radiation	RadAvg	1430	1705	1892	1866	1685	1695	1765	1819	1693	1456	1373	1344	
	RadStd	112	112	121	104	114	91	97	80	94	132	103	99	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page