

SOTO CANO AB, Honduras

WMO: 787210

Lat: 14.382N

Lon: 87.621W

Elev: 628

StdP: 94.00

Time Zone: -6.00 (W06)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	14.9	15.9	9.1	7.8	28.4	10.8	8.7	28.2	11.2	23.0	10.5	23.3	2.5	350	0.359

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	13.7	35.6	21.2	34.6	21.0	33.6	21.1	27.0	29.2	25.9	28.4	24.9	28.3	4.8	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.4	23.6	28.5	25.3	22.1	27.5	24.1	20.6	26.4	89.3	29.3	84.5	28.5	79.9	28.1	30.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.4	9.5	8.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			11.4	25.5	0.8	1.2	10.8	26.3	10.3	27.0	9.8	27.7	9.2	28.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	25.0	23.0	24.3	25.4	27.2	26.9	26.1	25.8	25.9	25.4	24.3	22.9	22.8
	DBStd	2.10	1.93	1.87	2.12	1.52	1.35	1.09	1.02	0.94	0.75	1.44	1.77	1.80
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	2	1	0	0	0	0	0	0	0	0	0	0	1
	CDD10.0	5474	404	399	478	515	523	482	490	494	461	444	387	398
	CDD18.3	2434	147	166	219	265	264	232	232	236	211	186	137	141
	CDH23.3	18761	1039	1492	2094	2651	2238	1735	1814	1739	1308	1052	722	876
	CDH26.7	7866	368	671	1034	1373	1021	699	763	730	464	304	174	264
Wind	WSAvg	3.9	4.9	4.5	5.0	4.1	3.3	2.7	3.1	2.8	2.7	3.8	5.2	4.8
Precipitation	PrecAvg	1321	33	21	29	41	131	201	159	181	217	177	66	33
	PrecMax	1654	69	40	74	137	231	366	286	433	353	426	170	63
	PrecMin	977	18	7	10	5	44	76	95	77	113	64	24	18
	PrecStd	175	11	8	16	35	52	66	50	77	64	81	34	12
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.9	35.0	36.2	37.0	36.9	34.2	34.1	34.2	32.2	32.0	31.2	32.0
		MCWB	20.2	20.1	20.6	21.0	22.0	24.1	21.1	21.6	23.4	22.7	22.3	22.0
	2%	DB	31.5	33.8	35.0	35.8	34.7	32.8	32.9	33.0	31.2	30.8	29.9	30.9
		MCWB	20.0	20.1	20.4	21.1	22.1	23.5	21.4	22.1	23.7	23.7	22.0	21.4
	5%	DB	30.2	32.2	33.8	34.8	33.3	31.8	32.0	31.9	30.7	29.7	28.8	29.8
		MCWB	19.8	19.5	20.2	20.9	22.2	23.4	21.6	22.4	23.8	24.1	22.0	21.1
	10%	DB	28.9	31.0	32.2	33.2	32.0	30.8	30.9	30.9	29.8	28.5	27.4	28.1
		MCWB	20.0	19.3	19.7	20.7	22.3	23.3	21.9	22.4	23.7	23.7	22.0	20.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.2	22.1	22.6	23.9	26.5	28.1	24.7	24.7	27.4	28.0	25.8	25.0
		MCDB	28.9	30.1	30.3	30.3	28.9	30.8	29.6	29.4	30.0	29.7	27.5	28.8
	2%	WB	21.4	21.3	22.0	23.1	25.1	26.7	23.7	24.0	26.3	26.9	24.4	23.7
		MCDB	27.9	28.8	29.2	29.4	29.4	29.5	28.9	29.2	29.0	28.4	27.3	27.3
	5%	WB	20.9	20.7	21.4	22.6	24.1	25.4	23.2	23.5	25.1	25.7	23.4	22.6
		MCDB	26.8	27.7	28.6	29.1	28.9	28.6	28.5	28.4	28.2	27.3	26.4	26.5
	10%	WB	20.4	20.3	20.9	22.1	23.4	24.3	22.8	23.1	23.9	24.2	22.5	21.7
		MCDB	25.9	26.9	28.1	28.8	28.3	28.1	27.8	27.8	27.7	26.8	25.5	25.6
Mean Daily Temperature Range	5% DB	MDBR	11.4	13.3	13.7	13.7	11.7	10.5	10.9	11.0	9.9	8.9	9.2	10.6
		MCDBR	14.3	16.0	15.8	15.2	13.5	11.8	12.7	12.5	10.9	10.6	11.4	13.4
		MCWBR	4.7	4.5	4.2	3.7	3.5	4.4	3.7	3.8	4.4	4.8	4.6	5.0
	5% WB	MCDBR	12.1	13.7	14.4	13.3	11.1	10.8	10.4	11.0	10.1	9.0	9.2	10.5
	MCWBR	4.2	4.1	4.0	3.4	4.0	5.8	3.7	3.8	5.9	6.5	5.1	4.9	
Clear-Sky Solar Irradiance	taub		0.361	0.375	0.401	0.499	0.563	0.467	0.463	0.454	0.453	0.416	0.390	0.378
	taud		2.507	2.469	2.385	2.083	1.932	2.256	2.251	2.286	2.287	2.417	2.467	2.479
	Ebn at Noon		936	935	915	822	758	826	831	848	854	883	899	908
	Edh at Noon		104	112	125	169	193	138	139	136	136	117	107	104
All-Sky Solar Radiation	RadAvg		4.51	5.38	5.96	5.88	5.31	5.34	5.56	5.73	5.34	4.59	4.33	4.24
	RadStd		0.35	0.35	0.38	0.33	0.36	0.29	0.31	0.25	0.29	0.42	0.33	0.31

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page