

CURACAO INTL, Curaçao

WMO: 789880

Lat: 12.189N

Lon: 68.960W

Elev: 29

StdP: 14.68

Time Zone: -4.00 (W04)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	74.0	75.2	67.7	101.9	78.9	68.3	104.2	79.2	22.5	80.6	20.9	81.3	8.3	120	0.591

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	10.5	92.5	81.7	91.5	81.6	90.4	80.9	84.1	90.3	83.1	89.6	82.3	89.0	15.3	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
82.3	168.7	89.8	81.0	161.1	88.8	80.5	158.5	88.4	48.1	90.1	47.0	90.2	46.2	88.9	89.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.0	19.7	18.6	71.8	96.4	1.5	2.7	70.7	98.4	69.8	99.9	68.9	101.4	67.8	103.3		
(5)			68.3	84.6	1.6	2.2	67.1	86.2	66.1	87.5	65.2	88.7	64.0	90.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	83.4	80.9	81.2	82.0	83.2	84.2	84.6	84.4	85.4	85.6	84.5	83.0	81.7	(6)
(7)		DBStd	2.23	1.61	1.36	1.57	1.36	1.35	1.28	1.31	1.42	1.76	2.05	1.99	1.83	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD50	12191	959	873	991	996	1061	1037	1067	1096	1069	1069	991	982	(10)
(11)		CDD65	6716	494	453	526	546	596	587	602	631	619	604	541	517	(11)
(12)		CDH74	75089	4609	4215	5176	5862	6900	6956	7097	7781	7782	7303	6108	5300	(12)
(13)		CDH80	26489	1003	980	1407	1860	2542	2705	2736	3362	3517	2983	2043	1351	(13)
(14)	Wind	WSAvg	12.8	12.9	13.7	13.6	13.4	13.8	14.3	13.5	12.9	11.7	10.6	10.7	12.5	(14)
(15)	Precipitation	PrecAvg	21.6	2.0	1.0	0.6	0.7	0.8	0.9	1.3	1.5	1.7	3.4	4.4	3.5	(15)
(16)		PrecMax	46.2	6.1	5.0	4.4	4.5	4.0	4.1	4.8	8.4	7.6	14.7	13.7	15.2	(16)
(17)		PrecMin	10.6	0.1	0.0	0.0	0.0	0.0	0.0	0.2	0.0	0.0	0.4	0.1	0.2	(17)
(18)		PrecStd	8.3	1.3	1.1	0.7	0.9	1.1	0.9	0.9	1.7	1.7	3.0	3.4	3.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	88.2	88.2	89.7	90.0	91.7	91.8	91.7	93.5	94.6	93.2	91.1	89.1	(19)
(20)			MCWB	78.2	78.6	79.3	80.3	81.8	81.6	81.8	81.9	81.1	81.9	81.6	79.1	(20)
(21)		2%	DB	86.8	87.2	88.1	89.5	90.0	91.0	90.5	91.7	92.6	91.3	89.4	87.7	(21)
(22)			MCWB	77.9	78.3	79.0	79.9	81.0	81.2	80.9	81.7	81.6	81.7	80.9	79.3	(22)
(23)		5%	DB	86.0	86.1	87.5	88.2	89.5	89.7	89.7	90.8	91.3	89.9	88.1	86.3	(23)
(24)			MCWB	77.7	77.6	78.7	79.4	80.7	80.4	80.2	81.2	81.4	80.9	80.4	78.6	(24)
(25)		10%	DB	84.6	85.1	86.1	87.6	88.2	88.6	88.5	89.7	89.9	89.2	87.4	85.7	(25)
(26)			MCWB	76.9	76.8	77.8	79.1	80.0	79.8	79.7	80.4	80.8	80.6	80.0	78.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.0	81.6	82.5	83.4	84.1	83.5	83.7	84.6	84.6	85.0	83.8	81.6	(27)
(28)			MCD B	86.3	86.1	86.7	87.7	89.8	90.3	90.4	91.5	91.5	91.2	88.9	86.6	(28)
(29)		2%	WB	79.6	79.8	80.8	81.6	82.6	82.4	82.2	83.5	83.6	83.1	82.2	80.4	(29)
(30)			MCD B	85.4	85.4	86.5	87.4	89.0	89.6	89.5	90.6	90.7	89.4	87.7	85.9	(30)
(31)		5%	WB	78.4	78.5	79.5	80.2	81.5	81.5	81.2	82.3	82.4	81.9	80.9	79.6	(31)
(32)			MCD B	84.3	84.5	85.8	86.8	88.2	88.5	88.4	89.5	89.9	88.2	86.6	84.9	(32)
(33)		10%	WB	77.5	77.5	78.3	79.5	80.3	80.3	80.1	81.0	81.4	80.9	80.1	78.8	(33)
(34)			MCD B	83.0	83.3	84.7	85.8	86.9	87.1	86.9	87.9	88.5	87.1	85.5	84.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.0	9.2	9.5	9.5	9.3	9.5	9.8	10.1	10.5	9.7	8.9	8.5	(35)
(36)			MCDBR	9.6	9.8	10.4	10.2	10.2	10.4	10.5	11.1	11.3	10.3	9.6	8.9	(36)
(37)			MCWBR	5.1	5.2	5.5	5.1	5.2	5.0	5.2	5.4	5.6	5.5	5.2	4.9	(37)
(38)		5% WB	MCDBR	9.3	9.8	10.3	10.0	10.2	10.3	10.4	10.8	11.0	10.3	9.4	8.7	(38)
(39)			MCWBR	5.7	6.2	6.5	5.8	6.0	5.8	6.0	6.6	6.6	6.5	5.6	5.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.388	0.411	0.423	0.488	0.476	0.503	0.484	0.442	0.428	0.404	0.394	0.396	(40)	
(41)		taud	2.552	2.463	2.439	2.233	2.304	2.210	2.278	2.439	2.467	2.565	2.583	2.556	(41)	
(42)		Ebn at Noon	291	287	285	264	262	252	258	272	279	285	287	285	(42)	
(43)		Edh at Noon	32	36	38	46	42	46	43	37	36	32	31	31	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1657	1843	1942	1951	1925	1964	1999	2046	1961	1737	1557	1542	(44)	
(45)		RadStd	68	60	98	70	78	75	55	76	84	95	152	79	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	-0.61	-1.04	-0.95	-1.39	-1.26	N/A	N/A	N/A	N/A
(47)	Regional (2 neighbors)	N/A	N/A	-0.59	-0.43	-0.86	-0.86	N/A	N/A	N/A	N/A

Nomenclature: See separate page