

SAN ANDRES, Colombia

WMO: 800010

Lat: 12.584N

Lon: 81.711W

Elev: 6

StdP: 101.26

Time Zone: -5.00 (W05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.9	24.6	19.9	14.6	26.2	20.8	15.4	26.5	10.1	25.9	9.3	26.4	3.5	10	0.445

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.7	31.4	27.0	31.1	27.0	31.0	27.0	28.1	30.2	27.7	29.8	27.4	29.6	4.0	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.2	23.0	30.0	27.1	22.8	29.9	26.8	22.5	29.7	89.7	30.9	88.4	30.3	87.3	29.8	29.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
8.8	8.1	7.4	21.2	33.7	1.5	1.1	20.1	34.5	19.2	35.1	18.4	35.7	17.3	36.4	
			DB												
			WB	19.0	28.6	1.1	0.4	18.2	28.9	17.5	29.2	16.9	29.4	16.1	29.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	28.0	27.1	27.2	27.5	28.2	28.4	28.4	28.5	28.5	28.5	28.0	27.8	27.6
	DBStd	1.04	0.81	0.72	0.76	0.79	0.86	1.05	0.87	0.94	0.94	1.06	1.01	0.98
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6563	530	483	541	547	571	552	573	574	554	559	534	544
	CDD18.3	3521	272	249	283	297	313	302	315	316	304	301	284	286
	CDH23.3	39689	2714	2483	2891	3319	3677	3579	3784	3822	3622	3464	3199	3134
	CDH26.7	11828	465	442	604	979	1232	1231	1339	1385	1312	1130	920	789
Wind	WSAvg	3.8	4.6	4.4	4.0	3.7	3.6	4.1	4.8	3.5	2.5	2.6	3.7	4.7
Precipitation	PrecAvg	1890	81	36	26	25	137	192	176	188	229	318	324	156
	PrecMax	2718	174	93	87	126	366	616	426	635	408	638	653	392
	PrecMin	1171	12	1	2	1	2	33	41	44	130	82	97	35
	PrecStd	393	44	23	20	27	97	112	88	135	79	140	140	96
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.0	30.2	30.2	31.5	31.6	31.5	31.2	31.9	32.1	32.0	31.2	30.5
		MCWB	25.5	25.0	25.4	26.7	26.9	27.2	27.1	27.1	27.1	27.1	26.7	26.1
	2%	DB	29.2	29.5	30.0	30.9	31.0	31.0	31.0	31.1	31.2	31.1	30.5	30.1
		MCWB	25.1	24.8	25.4	26.6	27.0	27.1	27.1	27.2	27.2	27.1	26.5	26.0
	5%	DB	29.0	29.1	29.3	30.2	30.2	30.2	30.2	30.8	31.0	30.8	30.1	29.8
		MCWB	25.0	24.8	25.2	26.1	26.6	26.9	26.9	27.1	27.2	27.0	26.3	25.9
	10%	DB	28.5	28.8	29.0	29.9	30.0	30.0	30.0	30.2	30.5	30.1	29.8	29.1
		MCWB	24.9	24.8	25.1	25.9	26.5	26.8	26.8	26.9	27.0	26.7	26.2	25.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.3	26.3	27.1	27.9	28.1	28.1	28.4	28.3	28.5	28.1	27.5	27.2
		MCDB	28.3	28.6	29.2	30.4	30.2	30.2	30.3	30.3	30.6	30.4	29.6	29.1
	2%	WB	26.1	26.0	26.3	27.1	27.5	27.6	27.6	27.7	27.9	27.6	27.1	26.7
		MCDB	28.2	28.4	28.7	29.6	29.6	29.7	29.6	29.8	30.1	30.0	29.2	28.7
	5%	WB	25.7	25.6	25.9	26.7	27.1	27.2	27.2	27.4	27.5	27.2	26.7	26.3
		MCDB	28.0	28.1	28.4	29.2	29.3	29.3	29.2	29.5	29.8	29.6	28.9	28.5
	10%	WB	25.4	25.2	25.5	26.4	26.8	26.9	26.9	27.1	27.2	26.9	26.5	26.1
		MCDB	27.7	27.8	28.2	28.9	29.0	29.0	29.0	29.2	29.5	29.2	28.7	28.4
Mean Daily Temperature Range	5% DB	MDBR	3.3	3.4	3.5	3.7	3.5	3.4	3.4	3.7	4.4	4.4	3.7	3.3
		MCDBR	3.5	3.8	3.7	4.1	3.8	3.6	3.6	4.2	4.8	5.0	4.0	3.7
		MCWBR	2.2	2.2	2.3	2.2	2.2	2.2	2.2	2.4	2.6	2.8	2.4	2.2
	5% WB	MCDBR	3.3	3.3	3.4	3.7	3.5	3.4	3.4	3.7	4.3	4.5	3.8	3.3
		MCWBR	2.3	2.3	2.4	2.3	2.3	2.3	2.3	2.5	2.7	2.7	2.4	2.2
Clear-Sky Solar Irradiance	taub	0.393	0.400	0.398	0.448	0.469	0.498	0.508	0.472	0.438	0.395	0.399	0.398	
	taud	2.539	2.506	2.499	2.356	2.330	2.249	2.201	2.337	2.432	2.599	2.571	2.551	
	Ebn at Noon	910	915	919	865	833	800	794	833	869	908	897	896	
	Edh at Noon	102	109	112	128	129	138	146	129	118	98	98	99	
All-Sky Solar Radiation	RadAvg	5.07	5.92	6.51	6.56	5.71	5.09	5.41	5.56	5.19	4.61	4.25	4.64	
	RadStd	0.32	0.19	0.21	0.28	0.45	0.39	0.36	0.42	0.39	0.39	0.55	0.42	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page