

BOGOTA, Colombia

WMO: 802220

Lat: 4.702N

Lon: 74.147W

Elev: 8361

StdP: 10.77

Time Zone: -5.00 (W05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 39.0	(c) 41.3	(d) 35.6	(e) 41.8	(f) 48.5	(g) 38.8	(h) 47.5	(i) 50.0	(j) 18.7	(k) 65.4	(l) 17.0	(m) 65.7	(n) 2.0	(o) 350	(p) 0.484

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	16.0	70.8	55.6	69.7	55.5	68.3	55.3	59.4	65.7	58.6	64.9	58.1	64.3	10.0	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
57.4	96.6	61.6	56.7	94.2	61.2	55.7	90.6	60.4	30.5	66.0	29.8	65.2	29.3	64.3	75.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 17.3	(b) 15.2	(c) 13.6	(e) 33.7	(f) 74.8	(g) 3.8	(h) 3.1	(i) 31.0	(j) 77.0	(k) 28.8	(l) 78.9	(m) 26.7	(n) 80.6	(o) 23.9	(p) 82.9		
(4) 17.3	(5) 15.2	(6) 13.6	(7) 33.6	(8) 64.2	(9) 3.7	(10) 4.5	(11) 30.9	(12) 67.5	(13) 28.7	(14) 70.1	(15) 26.6	(16) 72.6	(17) 23.9	(18) 75.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	57.0	56.1	57.2	57.7	58.1	58.0	57.2	56.6	56.5	56.4	57.1	57.3	56.6		
	DBStd	2.07	2.47	2.42	2.06	1.79	1.81	1.72	1.69	1.77	2.00	1.84	1.83	2.12		
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD65	2906	277	219	226	208	218	234	262	265	259	246	232	260		
	CDD50	2570	189	201	239	242	247	216	203	200	191	219	218	205		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	3	0	2	0	0	0	0	0	0	1	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	5.7	5.6	5.7	5.5	5.2	5.3	6.2	6.6	6.5	5.9	5.4	5.1	5.5		
(15) Precipitation	PrecAvg	36.3	1.8	2.2	3.5	4.3	3.6	3.0	2.6	2.1	2.0	4.1	4.7	2.5		
	PrecMax	55.8	5.0	4.8	6.1	7.5	7.5	6.7	6.3	3.6	4.0	7.6	8.9	5.6		
	PrecMin	24.1	0.2	0.6	0.7	1.1	0.5	1.2	1.1	1.1	0.6	1.0	1.6	0.1		
	PrecStd	7.0	1.1	1.2	1.3	1.6	2.0	1.2	1.0	0.7	0.9	1.8	1.8	1.5		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	71.8	73.2	71.7	70.1	70.0	69.5	68.1	68.4	70.0	70.1	70.0	70.8		
		MCWB	55.3	54.5	55.9	56.6	56.4	56.1	54.4	54.5	54.9	55.8	56.2	54.9		
	2%	DB	69.7	70.1	69.5	68.2	68.0	67.2	66.3	66.6	68.1	68.1	68.1	68.4		
		MCWB	54.9	55.3	56.1	56.5	56.2	55.2	54.2	54.2	54.1	55.2	55.8	54.9		
	5%	DB	67.9	68.2	67.7	66.6	66.3	65.9	64.8	65.6	66.4	66.4	66.4	66.9		
		MCWB	54.9	55.2	55.7	56.3	56.1	55.1	53.9	54.0	54.1	55.0	55.8	55.0		
	10%	DB	66.1	66.3	65.9	64.8	64.7	64.4	64.0	64.2	64.7	64.7	64.7	65.6		
		MCWB	54.9	55.2	55.6	55.8	55.6	54.6	53.7	53.7	53.8	54.9	55.6	54.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.3	59.9	59.8	60.2	59.9	58.9	58.1	58.4	58.5	59.3	59.3	59.4		
		MCDB	67.1	67.5	67.1	66.0	65.4	64.6	63.5	63.2	64.8	65.8	65.2	65.8		
	2%	WB	58.1	58.4	58.4	58.7	58.5	57.5	56.5	56.6	57.0	58.0	58.3	58.1		
		MCDB	65.6	65.5	65.2	64.4	64.1	63.2	62.4	62.3	63.2	64.3	64.2	64.4		
	5%	WB	57.0	57.4	57.5	57.9	57.6	56.5	55.5	55.7	56.0	56.9	57.4	57.0		
		MCDB	64.2	64.4	63.9	63.6	63.2	62.5	62.1	62.2	62.6	62.9	63.3	63.2		
	10%	WB	56.1	56.4	56.5	56.8	56.6	55.6	54.6	54.7	55.0	56.1	56.5	56.1		
		MCDB	63.2	63.3	62.8	62.5	62.3	62.2	61.4	61.6	61.9	62.2	62.5	62.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	22.6	21.4	18.4	16.5	16.0	16.3	16.6	17.4	19.1	18.4	18.2	20.4		
		MCDBR	26.3	24.8	21.8	18.8	18.1	18.2	17.8	19.4	21.6	20.9	20.1	23.0		
		MCWBR	14.5	13.0	11.4	9.7	9.4	8.9	8.6	9.6	10.9	10.8	10.9	12.4		
	5% WB	MCDBR	23.0	21.6	19.2	17.2	16.4	16.6	16.8	17.8	19.6	18.8	18.6	20.4		
		MCWBR	13.6	12.3	10.9	9.8	9.6	9.4	9.1	10.0	11.2	10.7	10.7	12.1		
(40) Clear-Sky Solar Irradiance	taub		0.320	0.350	0.375	0.364	0.331	0.307	0.308	0.331	0.333	0.339	0.334	0.324		
	taud		2.541	2.444	2.374	2.415	2.531	2.637	2.631	2.517	2.497	2.499	2.518	2.546		
	Ebn at Noon		318	310	300	298	302	305	306	304	308	309	311	315		
	Edh at Noon		33	38	41	38	33	29	30	34	36	35	34	33		
(44) All-Sky Solar Radiation	RadAvg		1541	1515	1373	1323	1354	1362	1378	1397	1479	1443	1402	1448		
	RadStd		135	146	105	69	58	59	57	79	71	58	50	98		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.92	+2.48	+1.22	N/A	-0.52	-0.59	N/A	-333	+331
(47) Regional (1 neighbor)		+0.92	+2.48	+1.22	N/A	-0.52	-0.59	N/A	-333	+331

Nomenclature: See separate page