

BOGOTA, Colombia

WMO: 802220

Lat: 4.702N

Lon: 74.147W

Elev: 2548

StdP: 74.23

Time Zone: -5.00 (W05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	3.9	5.2	2.0	6.0	9.2	3.8	6.8	10.0	8.3	18.6	7.6	18.7	0.9	350	0.484

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	8.9	21.5	13.1	20.9	13.1	20.1	13.0	15.2	18.7	14.8	18.3	14.5	18.0	4.5	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.1	13.8	16.5	13.7	13.5	16.2	13.1	12.9	15.8	53.0	18.9	51.5	18.4	50.4	18.0	23.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.7	6.8	6.1	DB	1.0	23.8	2.1	1.7	-0.6	25.0	-1.8	26.0	-3.0	27.0	-4.5	28.3	(4)
			WB	0.9	17.9	2.1	2.5	-0.6	19.7	-1.8	21.2	-3.0	22.6	-4.5	24.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	13.9	13.4	14.0	14.3	14.5	14.4	14.0	13.6	13.5	13.9	14.0	13.7	(6)	
(7)		DBStd	1.15	1.37	1.35	1.14	0.99	1.01	0.95	0.94	0.98	1.11	1.02	1.02	1.18	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	1614	154	122	126	116	121	130	146	147	144	137	129	144	(9)
(10)		CDD10.0	1428	105	112	133	134	137	120	113	111	106	122	121	114	(10)
(11)		CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH23.3	2	0	1	0	0	0	0	0	0	1	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	2.6	2.5	2.6	2.5	2.3	2.4	2.8	2.9	2.9	2.7	2.4	2.3	2.5	(14)
(15)	Precipitation	PrecAvg	922	46	55	88	110	91	75	67	54	50	103	120	63	(15)
(16)		PrecMax	1418	128	122	154	191	190	169	159	91	101	194	227	141	(16)
(17)		PrecMin	612	4	16	19	28	12	30	27	27	14	25	40	2	(17)
(18)		PrecStd	178	28	31	32	40	50	31	26	17	23	46	46	37	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.1	22.9	22.1	21.2	21.1	20.8	20.1	20.2	21.1	21.2	21.1	21.5	(19)
MCWB			12.9	12.5	13.3	13.7	13.6	13.4	12.4	12.5	12.7	13.2	13.4	12.7	(20)	
2%		DB	20.9	21.2	20.8	20.1	20.0	19.6	19.1	19.2	20.0	20.1	20.0	20.2	(21)	
		MCWB	12.7	12.9	13.4	13.6	13.4	12.9	12.3	12.3	12.3	12.9	13.2	12.7	(22)	
5%		DB	20.0	20.1	19.8	19.2	19.1	18.8	18.2	18.7	19.1	19.1	19.1	19.4	(23)	
		MCWB	12.7	12.9	13.2	13.5	13.4	12.8	12.1	12.2	12.3	12.8	13.2	12.8	(24)	
10%		DB	19.0	19.1	18.8	18.2	18.2	18.0	17.8	17.9	18.2	18.2	18.2	18.7	(25)	
		MCWB	12.7	12.9	13.1	13.2	13.1	12.5	12.1	12.0	12.1	12.7	13.1	12.7	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.2	15.5	15.4	15.7	15.5	15.0	14.5	14.6	14.7	15.2	15.2	15.2	(27)
MCD B			19.5	19.7	19.5	18.9	18.6	18.1	17.5	17.3	18.2	18.8	18.5	18.8	(28)	
2%		WB	14.5	14.7	14.7	14.9	14.7	14.2	13.6	13.7	13.9	14.4	14.6	14.5	(29)	
		MCD B	18.7	18.6	18.4	18.0	17.8	17.3	16.9	16.8	17.3	17.9	17.9	18.0	(30)	
5%		WB	13.9	14.1	14.1	14.4	14.2	13.6	13.1	13.2	13.3	13.8	14.1	13.9	(31)	
		MCD B	17.9	18.0	17.7	17.6	17.4	17.0	16.7	16.8	17.0	17.2	17.4	17.3	(32)	
10%		WB	13.4	13.6	13.6	13.8	13.7	13.1	12.6	12.6	12.8	13.4	13.6	13.4	(33)	
		MCD B	17.3	17.4	17.1	17.0	16.8	16.8	16.3	16.5	16.6	16.8	16.9	16.9	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	12.6	11.9	10.2	9.2	8.9	9.0	9.2	9.7	10.6	10.2	10.1	11.3	(35)
MCDBR			14.6	13.8	12.1	10.4	10.1	10.1	9.9	10.8	12.0	11.6	11.2	12.8	(36)	
MCWBR			8.1	7.2	6.4	5.4	5.2	5.0	4.8	5.3	6.0	6.0	6.0	6.9	(37)	
5% WB		MCDBR	12.8	12.0	10.7	9.6	9.1	9.2	9.3	9.9	10.9	10.4	10.3	11.4	(38)	
		MCWBR	7.5	6.8	6.1	5.5	5.3	5.2	5.1	5.5	6.2	5.9	5.9	6.7	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.320	0.350	0.375	0.364	0.331	0.307	0.308	0.331	0.333	0.339	0.334	0.324	(40)	
(41)		taud	2.541	2.444	2.374	2.415	2.531	2.637	2.631	2.517	2.497	2.499	2.518	2.546	(41)	
(42)		Ebn at Noon	1002	976	946	939	951	962	965	958	972	975	980	992	(42)	
(43)		Edh at Noon	105	119	128	121	104	92	93	107	112	111	107	103	(43)	
(44)	All-Sky Solar Radiation	RadAvg	4.86	4.78	4.33	4.17	4.27	4.29	4.34	4.40	4.66	4.55	4.42	4.57	(44)	
(45)		RadStd	0.43	0.46	0.33	0.22	0.18	0.19	0.18	0.25	0.22	0.18	0.16	0.31	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.51	+1.38	+0.68	N/A	-0.29	-0.33	N/A	-185	+184	N/A	(46)
(47)	Regional (1 neighbor)	+0.51	+1.38	+0.68	N/A	-0.29	-0.33	N/A	-185	+184	N/A	(47)

Nomenclature: See separate page