

CALI, Colombia

WMO: 802590

Lat: 3.543N

Lon: 76.382W

Elev: 3162

StdP: 13.09

Time Zone: -5.00 (W05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	63.8	64.3	59.4	85.0	78.7	60.8	89.6	76.6	16.6	79.8	14.8	80.0	1.6	80	0.255

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	20.9	91.0	71.9	89.5	71.9	88.0	71.7	74.3	85.5	73.5	85.0	72.8	84.3	7.2	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.4	130.6	78.7	70.2	125.0	76.9	69.9	123.6	76.5	40.1	85.9	39.4	85.4	38.9	84.9	82.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
15.0	13.5	11.9	DB	58.4	93.8	3.8	2.1	55.6	95.3	53.4	96.5	51.3	97.7	48.5	99.2	(4)
			WB	57.2	78.3	3.2	2.0	54.9	79.7	53.0	80.9	51.2	82.0	48.9	83.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	76.0	76.1	76.6	76.4	76.1	75.9	75.8	76.2	76.7	76.4	75.5	75.2	75.6
	DBStd	2.03	2.09	2.10	2.26	2.00	1.92	1.76	1.72	1.85	2.09	2.11	1.86	1.99
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	9504	808	746	818	782	804	773	813	827	792	790	757	794
	CDD65	4029	343	326	353	332	339	323	348	362	342	325	307	329
	CDH74	26429	2296	2268	2327	2019	2053	2087	2490	2749	2444	1966	1721	2009
	CDH80	8382	741	786	773	599	587	602	830	1006	855	573	440	590
Wind	WSAvg	4.3	4.2	4.4	4.1	3.8	3.8	3.9	4.5	4.9	4.9	4.6	4.1	4.1
Precipitation	PrecAvg	37.3	2.0	2.5	3.7	5.6	4.0	2.3	1.3	1.5	2.5	4.5	4.1	2.7
	PrecMax	54.9	6.4	6.7	7.5	14.7	8.0	6.8	4.1	4.7	6.4	8.7	13.5	6.1
	PrecMin	20.3	0.0	0.0	0.6	0.8	0.7	0.2	0.0	0.0	0.1	1.5	0.9	0.1
	PrecStd	7.8	1.3	1.7	1.6	2.6	1.9	1.7	0.9	1.3	1.4	1.8	2.2	1.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.1	91.3	91.2	89.7	89.3	89.5	91.2	92.7	91.8	89.7	88.2	89.8
		MCWB	72.7	73.2	73.0	72.9	73.5	72.0	71.4	70.2	71.1	71.8	72.1	72.5
	2%	DB	88.2	89.0	88.8	87.6	87.0	87.4	88.1	89.8	89.5	87.6	86.1	87.6
		MCWB	71.8	72.2	72.3	72.4	72.7	71.8	71.4	70.6	71.0	71.5	71.8	71.8
	5%	DB	86.2	87.3	86.4	85.8	85.7	85.7	86.3	87.8	87.4	85.7	84.4	85.7
		MCWB	71.5	71.6	71.9	72.2	72.4	71.7	71.2	70.9	71.1	71.4	71.4	71.7
	10%	DB	84.3	85.3	84.4	84.0	83.8	83.9	84.6	85.9	85.5	83.6	82.6	83.9
		MCWB	71.0	71.3	71.4	71.8	72.0	71.5	71.0	70.8	71.0	70.8	71.0	71.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	73.9	74.0	74.3	74.6	75.2	74.5	74.7	74.1	73.7	73.4	73.5	73.7
		MCDB	86.6	87.2	86.6	84.7	85.9	84.1	84.7	85.7	86.1	85.0	84.6	85.5
	2%	WB	72.7	72.9	73.0	73.4	73.7	72.9	72.8	72.5	72.4	72.3	72.4	72.6
		MCDB	85.0	85.7	85.1	84.2	84.2	83.6	84.4	85.1	85.2	84.0	83.3	84.2
	5%	WB	71.9	72.2	72.3	72.6	72.8	72.1	71.9	71.7	71.7	71.6	71.7	71.9
		MCDB	84.1	84.5	84.1	83.0	82.9	82.8	83.8	84.5	84.7	83.2	82.5	83.3
	10%	WB	71.2	71.4	71.6	71.9	72.0	71.5	71.2	71.0	71.0	70.9	71.1	71.2
		MCDB	82.5	83.0	82.9	81.8	81.7	82.2	82.7	83.0	82.9	81.5	80.8	81.7
Mean Daily Temperature Range	5% DB	MDBR	18.8	19.2	18.6	17.7	17.3	18.0	19.6	20.9	20.0	18.0	17.2	17.6
		MCDBR	21.1	21.6	20.9	19.7	19.5	20.1	21.6	23.8	22.9	20.6	19.2	20.4
		MCWBR	7.1	6.9	7.0	6.8	7.1	7.1	7.2	7.5	7.3	6.8	6.8	6.9
	5% WB	MCDBR	19.5	20.0	19.4	18.4	18.1	18.5	20.0	21.1	20.8	18.9	17.8	18.6
	MCWBR	7.0	6.9	6.9	6.9	7.1	7.1	7.3	7.3	7.2	6.8	6.7	6.8	
Clear-Sky Solar Irradiance	taub	0.412	0.451	0.453	0.425	0.398	0.373	0.384	0.406	0.418	0.407	0.408	0.406	
	taud	2.401	2.280	2.289	2.378	2.466	2.553	2.507	2.424	2.381	2.435	2.430	2.434	
	Ebn at Noon	289	279	278	280	281	285	283	282	283	289	288	289	
	Edh at Noon	39	44	44	40	35	32	34	37	40	38	37	37	
All-Sky Solar Radiation	RadAvg	1332	1327	1283	1314	1284	1274	1311	1335	1364	1317	1250	1261	
	RadStd	77	90	55	47	41	42	64	68	67	48	47	83	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	+0.99	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	+0.99	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page