

BARQUISIMETO, Venezuela

WMO: 804100

Lat: 10.043N

Lon: 69.359W

Elev: 2042

StdP: 13.64

Time Zone: -4.00 (W04)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	64.7	66.2	55.1	69.6	84.2	57.0	74.7	83.4	19.0	83.1	18.2	83.1	3.7	180	0.314

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	17.4	91.4	71.7	89.9	71.9	89.3	71.9	77.0	84.9	76.0	83.9	75.2	83.0	12.2	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
75.0	141.5	80.6	73.7	135.5	78.7	73.3	133.5	78.1	42.0	85.1	40.9	83.9	40.1	83.0	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.6	18.3	16.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	77.8	76.6	77.8	78.7	78.5	78.0	77.1	76.9	77.9	78.5	78.3	78.0	77.1
	DBStd	2.03	1.66	1.90	2.11	2.46	2.15	1.79	1.71	1.81	1.86	1.87	1.79	1.77
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	10137	824	778	889	855	869	813	833	866	856	876	839	839
	CDD65	4662	359	358	424	405	404	363	368	401	406	411	389	374
	CDH74	31391	2484	2568	3207	2881	2672	2148	2087	2656	2954	2809	2528	2397
Wind	WSAvg	8.8	7.6	8.0	8.3	8.7	9.5	9.6	9.8	10.2	10.0	8.3	7.7	8.1
	PrecAvg	21.5	0.4	0.4	0.7	2.4	3.0	2.9	2.8	2.0	1.6	2.2	2.2	1.1
Precipitation	PrecMax	36.3	2.1	2.2	2.4	9.8	7.8	6.8	5.4	7.6	6.5	6.9	7.6	5.4
	PrecMin	12.7	0.0	0.0	0.0	0.0	0.4	0.3	1.1	0.3	0.1	0.5	0.0	0.0
	PrecStd	5.4	0.6	0.6	0.7	2.2	1.9	1.5	1.1	1.2	1.1	1.4	1.9	1.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.6	91.5	93.3	92.2	91.4	88.8	88.2	90.0	91.7	91.3	90.0	88.2
		MCWB	71.0	70.9	72.1	72.0	70.5	70.6	72.2	71.4	73.0	73.5	74.0	72.0
	2%	DB	87.9	89.7	91.2	90.0	89.1	86.4	86.4	88.2	89.7	89.5	88.0	87.4
		MCWB	70.3	70.9	71.1	71.5	71.5	71.5	72.0	71.7	73.2	73.5	73.2	71.3
	5%	DB	86.3	88.0	89.5	88.4	87.4	85.6	85.6	87.1	88.0	87.8	86.4	86.0
		MCWB	70.0	70.4	71.2	71.2	71.6	71.7	72.0	71.8	72.8	73.2	72.8	70.8
	10%	DB	85.0	86.3	87.6	86.6	85.5	84.0	84.0	85.7	86.4	86.0	85.1	84.4
		MCWB	69.8	70.1	70.7	71.2	72.0	71.8	72.0	71.7	72.6	73.0	72.5	70.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	75.7	75.2	75.9	75.9	76.5	77.0	77.2	76.5	77.7	77.5	77.4	76.2
		MCDB	84.3	82.7	85.5	83.7	82.7	83.4	83.8	84.0	86.5	85.9	85.4	84.2
	2%	WB	73.8	73.5	74.1	74.6	75.1	75.4	75.0	76.0	76.0	76.3	76.3	74.4
		MCDB	83.4	82.9	84.5	82.3	81.4	80.7	82.2	82.8	84.9	84.8	84.4	82.1
	5%	WB	72.6	72.6	73.1	73.8	74.2	74.0	74.1	74.0	74.9	74.8	74.9	73.4
		MCDB	82.4	82.1	83.0	81.6	80.7	80.2	80.8	81.5	83.5	83.5	82.7	80.8
	10%	WB	71.4	71.7	72.3	73.0	73.4	73.0	73.0	73.2	73.9	73.8	73.8	72.5
		MCDB	80.8	81.3	82.0	80.8	80.1	79.4	79.6	80.4	82.0	82.1	81.2	79.7
Mean Daily Temperature Range	5% DB	MDBR	19.3	19.2	19.4	17.2	15.5	14.6	15.4	16.9	17.4	17.1	16.5	16.9
		MCDBR	20.5	21.0	21.7	20.0	18.3	16.6	17.4	18.6	19.1	19.3	18.0	18.3
		MCWBR	7.4	6.8	6.5	6.2	5.2	5.8	6.2	5.9	6.4	6.8	7.1	6.2
	5% WB	MCDBR	19.4	19.0	19.0	17.0	15.4	14.6	15.6	17.0	17.8	17.7	17.1	16.7
		MCWBR	8.6	7.4	6.8	6.8	6.2	6.5	7.2	6.8	7.8	7.5	7.8	6.9
Clear-Sky Solar Irradiance	taub		0.380	0.407	0.434	0.503	0.454	0.470	0.433	0.419	0.408	0.400	0.391	0.385
	taud		2.469	2.373	2.312	2.097	2.288	2.227	2.358	2.398	2.421	2.466	2.486	2.482
	Ebn at Noon		295	289	282	260	268	260	271	279	285	288	289	290
	Edh at Noon		35	40	43	53	43	45	39	38	38	36	34	34
All-Sky Solar Radiation	RadAvg		1629	1748	1679	1496	1493	1525	1610	1695	1717	1588	1467	1504
	RadStd		79	87	178	117	95	84	65	71	78	59	81	89

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page