

BARQUISIMETO, Venezuela

WMO: 804100

Lat: 10.043N

Lon: 69.359W

Elev: 622

StdP: 94.07

Time Zone: -4.00 (W04)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	18.2	19.0	12.8	9.9	29.0	13.9	10.7	28.5	8.5	28.4	8.1	28.4	1.6	180	0.314

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	9.7	33.0	22.1	32.2	22.2	31.8	22.2	25.0	29.4	24.4	28.8	24.0	28.4	5.5	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.9	20.2	27.0	23.2	19.4	25.9	22.9	19.1	25.6	79.7	29.5	77.3	28.9	75.5	28.3	30.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.8	8.2	7.5	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	25.4	24.8	25.4	25.9	25.8	25.1	24.9	25.5	25.9	25.7	25.5	25.0		
		DBStd	1.13	0.92	1.05	1.17	1.37	1.20	0.99	0.95	1.00	1.03	1.04	0.99		
		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0		
		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0		
		CDD10.0	5632	458	432	494	475	483	452	463	481	476	487	466		
		CDD18.3	2590	199	199	236	225	224	202	204	223	226	228	216		
		CDH23.3	17439	1380	1427	1782	1601	1484	1193	1159	1476	1641	1561	1404		
		CDH26.7	6248	478	566	763	641	514	336	334	517	637	574	474		
(14)	Wind	WSAvg	3.9	3.4	3.6	3.7	3.9	4.2	4.3	4.4	4.6	4.5	3.7	3.5		
(15)	Precipitation	PrecAvg	547	10	10	17	60	75	74	70	52	41	55	57		
		PrecMax	921	54	55	61	249	197	172	136	192	164	175	192		
		PrecMin	323	0	0	0	0	9	7	27	8	3	12	1		
		PrecStd	136	14	15	17	57	47	38	28	31	29	35	47		
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.0	33.1	34.1	33.4	33.0	31.6	31.2	32.2	33.1	32.9	32.2		
			MCWB	21.7	21.6	22.3	22.2	21.4	21.5	22.3	21.9	22.8	23.1	23.4		
		2%	DB	31.1	32.0	32.9	32.2	31.7	30.2	30.2	31.2	32.0	31.9	31.1		
			MCWB	21.3	21.6	21.7	21.9	22.0	22.2	22.1	22.9	23.1	22.9	21.9		
		5%	DB	30.2	31.1	31.9	31.4	30.8	29.8	29.8	30.6	31.1	31.0	30.2		
			MCWB	21.1	21.4	21.8	21.8	22.0	22.1	22.2	22.1	22.7	22.9	22.7		
		10%	DB	29.5	30.2	30.9	30.3	29.7	28.9	28.9	29.8	30.2	30.0	29.5		
			MCWB	21.0	21.2	21.5	21.8	22.2	22.1	22.2	22.1	22.6	22.8	22.5		
		0.4%	WB	24.3	24.0	24.4	24.4	24.7	25.0	25.1	24.7	25.4	25.3	25.2		
			MCDB	29.1	28.2	29.7	28.7	28.2	28.5	28.8	28.9	30.3	30.0	29.6		
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	23.2	23.1	23.4	23.7	24.0	24.0	24.1	23.9	24.5	24.4	24.6		
			MCDB	28.6	28.3	29.2	27.9	27.5	27.1	27.9	28.2	29.4	29.3	29.1		
		5%	WB	22.6	22.5	22.8	23.2	23.5	23.3	23.4	23.3	23.8	23.8	23.8		
			MCDB	28.0	27.9	28.3	27.5	27.1	26.8	27.1	27.5	28.6	28.6	28.2		
		10%	WB	21.9	22.1	22.4	22.8	23.0	22.8	22.8	22.9	23.3	23.2	23.2		
			MCDB	27.1	27.4	27.8	27.1	26.7	26.3	26.4	26.9	27.8	27.8	27.3		
		5% DB	MDBR	10.7	10.7	10.8	9.6	8.6	8.1	8.5	9.4	9.7	9.5	9.2		
			MCDBR	11.4	11.7	12.0	11.1	10.1	9.2	9.7	10.3	10.6	10.7	10.0		
(35)	Mean Daily Temperature Range	5% WB	MCWBR	4.1	3.8	3.6	3.4	2.9	3.2	3.5	3.3	3.6	3.8	3.9		
			MCDBR	10.8	10.5	10.5	9.4	8.6	8.1	8.6	9.4	9.9	9.8	9.5		
		5% WB	MCWBR	4.8	4.1	3.8	3.8	3.4	3.6	4.0	3.8	4.3	4.2	4.3		
			MCDBR	10.8	10.5	10.5	9.4	8.6	8.1	8.6	9.4	9.9	9.8	9.5		
(40)	Clear-Sky Solar Irradiance	taub	0.380	0.407	0.434	0.503	0.454	0.470	0.433	0.419	0.408	0.400	0.391	0.385		
		taud	2.469	2.373	2.312	2.097	2.288	2.227	2.358	2.398	2.421	2.466	2.486	2.482		
		Ebn at Noon	929	912	889	819	844	819	854	879	898	907	910	915		
		Edh at Noon	111	125	135	166	134	141	124	121	120	113	108	107		
(44)	All-Sky Solar Radiation	RadAvg	5.13	5.51	5.29	4.72	4.71	4.81	5.08	5.34	5.41	5.01	4.62	4.74		
		RadStd	0.25	0.27	0.56	0.37	0.30	0.27	0.20	0.23	0.25	0.19	0.26	0.28		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page