

MAIQUETIA, Venezuela

WMO: 804150

Lat: 10.603N

Lon: 66.991W

Elev: 235

StdP: 14.57

Time Zone: -4.00 (W04)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	69.5	71.2	60.4	79.1	77.0	62.3	84.8	76.5	11.5	81.9	9.5	83.1	1.1	90	0.294

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	12.7	93.1	82.1	91.6	81.4	91.0	81.1	84.8	89.8	83.8	88.9	82.8	88.0	5.9	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
84.0	179.6	88.1	82.5	170.9	87.6	81.0	162.6	86.6	49.3	90.5	48.3	88.5	47.0	88.8	
(p)															

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.5	7.7	7.2	DB	68.0	97.8	1.8	2.8	66.7	99.8	65.7	101.5	64.6	103.1	63.3	105.1	(4)
(5)			WB	61.8	86.3	1.7	1.6	60.6	87.5	59.6	88.4	58.6	89.4	57.4	90.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	81.8	79.3	79.1	80.0	81.1	82.4	82.8	82.5	83.4	84.1	83.5	82.5	80.8
	DBStd	2.70	1.92	2.41	2.24	2.17	2.15	2.27	2.43	2.47	2.38	2.03	1.79	1.61
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11609	907	816	929	934	1004	984	1007	1035	1023	1039	975	956
	CDD65	6134	442	396	464	484	539	534	542	570	573	574	525	491
	CDH74	61586	3528	3172	3970	4597	5606	5675	5692	6394	6670	6383	5438	4461
	CDH80	21211	971	877	1127	1380	1888	2018	2025	2501	2758	2461	1881	1324
Wind	WSAvg	2.4	2.3	2.5	2.6	2.6	2.7	2.6	2.5	2.5	2.5	2.3	2.1	2.2
Precipitation	PrecAvg	19.8	1.1	0.9	0.7	1.0	1.3	1.9	2.3	2.0	1.9	1.9	2.6	1.9
	PrecMax	40.3	8.0	5.8	2.8	10.0	4.1	7.2	5.2	7.9	5.3	6.0	16.9	7.6
	PrecMin	5.6	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.0	0.2	0.1	0.0	0.0
	PrecStd	6.6	1.6	1.2	0.8	1.6	1.0	1.3	1.2	1.6	1.2	1.5	3.1	2.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.4	91.0	90.0	91.1	92.7	93.2	91.8	93.6	94.9	93.4	91.7	89.8
		MCWB	80.0	81.4	81.6	81.7	80.6	80.8	80.6	82.2	83.4	82.4	81.5	78.7
	2%	DB	87.7	87.8	88.0	89.2	89.9	91.1	90.2	91.7	93.0	91.7	90.2	88.1
		MCWB	78.7	78.7	79.0	80.2	80.6	80.6	80.1	81.5	82.3	81.7	80.8	78.6
	5%	DB	86.1	86.2	86.4	87.7	88.6	89.5	89.5	90.3	91.4	90.6	89.4	87.5
		MCWB	77.4	77.5	78.0	79.3	80.0	79.7	79.8	80.6	81.5	81.0	80.5	78.5
	10%	DB	84.6	84.6	85.7	86.2	87.6	87.9	87.9	89.4	89.8	89.4	87.9	86.1
		MCWB	76.5	76.4	77.6	78.5	79.5	79.5	79.3	80.1	80.5	80.3	79.5	77.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	82.0	83.3	84.4	84.8	83.8	83.9	84.4	85.6	86.7	85.6	84.6	82.7
		MCDB	86.8	88.0	87.3	87.7	88.5	89.3	89.7	91.5	91.6	90.8	89.7	86.9
	2%	WB	79.9	80.6	82.0	82.4	82.4	82.4	82.5	83.9	84.6	83.5	82.8	81.0
		MCDB	85.2	85.6	85.7	85.5	87.4	87.9	87.8	89.5	90.0	89.4	88.1	85.9
	5%	WB	78.8	79.0	79.7	80.8	81.2	81.3	81.2	82.5	83.4	82.3	81.6	80.0
		MCDB	84.2	84.0	84.5	85.3	86.4	86.8	86.9	87.8	88.9	88.4	87.0	85.0
	10%	WB	77.7	78.0	78.5	79.6	80.3	80.4	80.1	81.2	81.9	81.2	80.4	78.9
		MCDB	83.3	83.1	83.7	84.3	85.4	85.8	85.7	86.8	87.6	87.3	85.8	83.8
Mean Daily Temperature Range	5% DB	MDBR	12.7	12.4	11.9	11.3	11.3	11.6	11.9	12.4	12.7	12.4	12.3	12.2
		MCDBR	13.5	13.2	12.4	11.9	12.2	12.6	12.7	13.2	13.6	13.3	13.3	13.1
		MCWBR	9.8	9.6	9.1	7.9	7.3	7.5	8.0	8.1	8.9	8.9	8.9	9.2
	5% WB	MCDBR	13.1	12.8	12.0	11.6	11.9	12.2	12.3	12.7	13.2	12.9	12.8	12.5
MCWBR		10.3	10.0	9.5	8.5	7.9	8.1	8.5	8.7	9.3	9.3	9.4	9.5	
Clear-Sky Solar Irradiance	taub	0.400	0.430	0.439	0.516	0.493	0.517	0.493	0.461	0.435	0.416	0.404	0.414	
	taud	2.483	2.372	2.365	2.120	2.231	2.138	2.222	2.346	2.419	2.490	2.524	2.471	
	Ebn at Noon	288	282	280	256	258	248	255	267	277	283	285	281	
	Edh at Noon	35	40	41	52	45	49	45	41	38	35	33	35	
All-Sky Solar Radiation	RadAvg	1671	1832	1891	1808	1750	1785	1819	1871	1862	1722	1556	1549	
	RadStd	76	97	140	122	95	68	49	65	61	62	119	82	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	+1.40	N/A	N/A	+0.99	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	+1.40	N/A	N/A	+0.99	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page