

PORLAMAR, Venezuela

WMO: **804210**Lat: **10.917N**Lon: **63.967W**Elev: **79**StdP: **14.65**Time Zone: **-4.00 (W04)**Period: **94-19**WBAN: **99999**

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	71.8	73.2	62.3	84.3	86.3	64.4	90.7	85.9	25.0	85.0	23.2	84.3	6.5	90	0.542

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	14.0	94.2	79.4	93.3	79.3	91.8	79.2	84.1	90.7	83.3	89.6	82.5	88.6	12.8	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
82.5	169.7	88.9	81.2	162.3	87.4	80.8	160.4	86.9	48.2	90.8	47.3	90.3	46.6	88.9	90.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.6	22.6	20.9	DB	68.0	99.5	3.4	2.1	65.5	100.9	63.6	102.1	61.7	103.3	59.2	104.8	(4)
(5)			WB	62.4	86.0	4.3	1.5	59.3	87.1	56.8	88.0	54.4	88.8	51.3	89.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	83.2	80.7	81.3	82.3	83.2	84.2	83.9	83.6	84.3	85.2	84.9	83.4	81.7
	DBStd	2.42	2.36	2.15	2.08	1.95	1.61	1.62	1.81	1.86	1.85	1.93	2.26	2.36
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	12127	952	876	1002	996	1059	1016	1041	1063	1055	1081	1003	983
	CDD65	6652	487	456	537	546	594	566	576	598	605	616	553	518
	CDH74	70529	4388	4215	5220	5630	6544	6183	6262	6795	7150	7157	5963	5022
CDH80	26761	1368	1393	1857	2129	2573	2342	2342	2768	3099	2997	2234	1659	
Wind	WSAvg	12.4	11.8	13.0	14.7	15.2	15.1	13.9	12.0	10.1	10.3	10.7	10.9	11.5
Precipitation	PrecAvg	18.9	2.1	1.0	0.7	0.4	0.5	1.3	2.0	2.2	2.0	1.2	2.4	2.7
	PrecMax	36.5	9.1	2.9	3.1	1.4	2.2	3.4	5.8	7.1	12.0	3.9	12.9	10.7
	PrecMin	11.1	0.3	0.0	0.0	0.0	0.0	0.1	0.5	0.4	0.0	0.0	0.0	0.6
	PrecStd	6.8	1.9	0.8	0.7	0.4	0.6	0.8	1.1	1.6	2.5	1.1	2.7	2.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.8	92.8	93.3	93.6	93.6	93.5	93.4	94.8	95.3	95.2	93.5	93.3
		MCWB	77.1	76.9	76.9	79.5	79.4	79.1	78.8	78.5	78.7	81.0	79.4	78.1
	2%	DB	89.8	90.0	91.4	91.8	92.8	91.7	91.6	93.1	93.6	93.4	91.7	91.2
		MCWB	77.4	77.4	77.3	78.8	79.2	79.1	78.7	79.8	79.4	80.5	79.4	78.1
	5%	DB	88.0	88.2	89.7	91.0	91.4	91.0	90.0	91.5	92.8	91.7	91.0	89.3
		MCWB	77.7	77.1	77.6	78.6	79.5	79.0	78.7	79.4	79.6	80.1	79.3	78.0
	10%	DB	86.3	87.1	88.0	89.4	89.8	89.5	89.4	89.9	91.2	91.0	89.4	87.5
		MCWB	77.4	76.9	77.6	78.3	78.9	78.9	78.8	79.3	79.6	80.0	79.4	78.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	82.1	82.4	83.2	84.2	84.5	83.9	84.2	83.7	84.8	84.9	83.7	82.9
		MCDB	87.2	87.5	88.4	91.2	90.8	89.8	89.7	90.6	91.8	92.2	89.6	87.1
	2%	WB	80.6	80.6	81.5	82.5	82.9	82.5	82.3	82.5	83.5	83.6	82.6	81.5
		MCDB	86.3	86.4	87.1	88.5	89.2	88.1	87.6	89.5	90.2	90.6	88.6	86.1
	5%	WB	79.7	79.6	80.0	81.1	81.7	81.4	81.3	81.6	82.4	82.5	81.7	80.4
		MCDB	85.1	85.2	85.8	87.1	88.0	87.2	86.9	88.3	88.7	89.0	87.6	85.7
	10%	WB	78.8	78.7	79.0	79.9	80.6	80.5	80.4	80.7	81.4	81.4	80.8	79.6
		MCDB	84.0	84.1	84.6	85.7	87.0	86.2	86.0	87.2	87.0	87.3	86.6	84.7
Mean Daily Temperature Range	5% DB	MDBR	12.5	13.0	13.7	13.8	13.6	12.7	12.9	13.9	14.0	13.8	12.8	12.5
		MCDBR	13.8	14.2	15.0	15.0	14.7	13.9	13.9	14.8	15.2	14.6	14.1	14.3
	5% WB	MCWBR	6.3	6.2	6.2	6.5	6.8	6.0	6.2	6.2	6.2	6.4	6.3	6.0
		MCWBR	13.1	13.4	13.9	13.9	13.9	13.1	13.0	14.2	14.0	14.2	13.1	12.8
Clear-Sky Solar Irradiance	taub	0.378	0.396	0.398	0.451	0.455	0.494	0.472	0.424	0.413	0.390	0.384	0.392	
	taud	2.591	2.516	2.517	2.366	2.371	2.236	2.321	2.502	2.516	2.600	2.615	2.570	
	Ebn at Noon	295	292	292	274	267	254	261	278	284	291	291	288	
	Edh at Noon	31	35	35	40	39	44	41	35	35	31	30	31	
All-Sky Solar Radiation	RadAvg	1705	1889	2001	2017	1939	1856	1899	1969	1975	1842	1669	1598	
	RadStd	64	72	113	87	107	88	66	56	63	62	88	61	