

PORLAMAR, Venezuela

WMO: 804210

Lat: 10.917N

Lon: 63.967W

Elev: 24

StdP: 101.04

Time Zone: -4.00 (W04)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.1	22.9	16.9	12.0	30.2	18.0	13.0	29.9	11.2	29.5	10.4	29.1	2.9	90	0.542

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	7.8	34.6	26.3	34.0	26.3	33.2	26.2	29.0	32.6	28.5	32.0	28.1	31.4	5.7	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
28.0	24.2	31.6	27.3	23.2	30.8	27.1	22.9	30.5	94.3	32.7	92.2	32.4	90.5	31.6	32.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	11.0	10.1	9.4	DB	20.0	37.5	1.9	1.1	18.6	38.3	17.5	39.0	16.5	39.6	15.1	40.4
(5)				WB	16.9	30.0	2.4	0.8	15.2	30.6	13.8	31.1	12.4	31.6	10.7	32.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	28.5	27.1	27.4	28.0	28.4	29.0	28.8	28.7	29.0	29.5	29.4	28.6	27.6
(7)		DBStd	1.34	1.31	1.19	1.16	1.09	0.89	0.90	1.01	1.04	1.03	1.07	1.25	1.31
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
(10)		CDD10.0	6737	529	487	557	553	588	564	578	591	586	601	557	546
(11)		CDD18.3	3696	271	253	298	303	330	314	320	332	336	342	307	288
(12)		CDH23.3	39183	2438	2342	2900	3128	3636	3435	3479	3775	3972	3976	3313	2790
(13)		CDH26.7	14867	760	774	1032	1183	1429	1301	1301	1538	1722	1665	1241	922
(14)	Wind	WSAvg	5.6	5.3	5.8	6.6	6.8	6.2	5.3	4.5	4.6	4.8	4.9	5.1	
(15)	Precipitation	PrecAvg	481	53	25	17	11	13	34	50	55	50	30	62	69
(16)		PrecMax	928	230	73	79	35	55	87	148	181	304	99	327	273
(17)		PrecMin	282	7	0	1	1	0	3	13	9	0	0	0	16
(18)		PrecStd	172	47	21	19	9	15	21	29	40	63	27	68	57
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.2	33.8	34.1	34.2	34.2	34.1	34.1	34.9	35.2	35.1	34.2	34.1
(20)			MCWB	25.1	24.9	24.9	26.4	26.3	26.2	26.0	25.8	25.9	27.2	26.3	25.6
(21)		2%	DB	32.1	32.2	33.0	33.2	33.8	33.2	33.1	33.9	34.2	34.1	33.2	32.9
(22)			MCWB	25.2	25.2	25.1	26.0	26.2	26.2	26.0	26.5	26.4	27.0	26.3	25.6
(23)		5%	DB	31.1	31.2	32.0	32.8	33.0	32.8	32.2	33.1	33.8	33.2	32.8	31.8
(24)			MCWB	25.4	25.1	25.3	25.9	26.4	26.1	26.0	26.3	26.4	26.7	26.3	25.6
(25)		10%	DB	30.2	30.6	31.1	31.9	32.1	31.9	31.9	32.2	32.9	32.8	31.9	30.8
(26)			MCWB	25.2	25.0	25.3	25.7	26.0	26.0	26.0	26.3	26.4	26.6	26.3	25.9
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.8	28.0	28.4	29.0	29.2	28.8	29.0	28.7	29.3	29.4	28.7	28.3
(28)			MCD B	30.7	30.9	31.4	32.9	32.7	32.1	32.1	32.6	33.2	33.4	32.0	30.6
(29)		2%	WB	27.0	27.0	27.5	28.1	28.3	28.0	28.0	28.1	28.6	28.7	28.1	27.5
(30)			MCD B	30.1	30.2	30.6	31.4	31.8	31.2	30.9	31.9	32.3	32.6	31.4	30.1
(31)		5%	WB	26.5	26.4	26.7	27.3	27.6	27.5	27.4	27.5	28.0	28.1	27.6	26.9
(32)			MCD B	29.5	29.6	29.9	30.6	31.1	30.7	30.5	31.3	31.5	31.7	30.9	29.8
(33)		10%	WB	26.0	25.9	26.1	26.6	27.0	26.9	26.9	27.0	27.4	27.5	27.1	26.4
(34)			MCD B	28.9	29.0	29.2	29.8	30.6	30.1	30.0	30.7	30.6	30.7	30.3	29.3
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.0	7.2	7.6	7.7	7.6	7.1	7.2	7.7	7.8	7.7	7.1	6.9
(36)			MCD BR	7.7	7.9	8.3	8.3	8.2	7.7	7.7	8.2	8.5	8.1	7.8	7.9
(37)			MCWBR	3.5	3.4	3.5	3.6	3.8	3.3	3.5	3.5	3.4	3.6	3.5	3.3
(38)		5% WB	MCD BR	7.3	7.4	7.7	7.7	7.7	7.3	7.2	7.9	7.8	7.9	7.3	7.1
(39)			MCWBR	4.1	4.0	4.1	4.3	4.4	3.8	4.0	3.9	3.9	4.2	3.8	3.9
(40)	Clear-Sky Solar Irradiance	taub	0.378	0.396	0.398	0.451	0.455	0.494	0.472	0.424	0.413	0.390	0.384	0.392	
(41)		taud	2.591	2.516	2.517	2.366	2.371	2.236	2.321	2.502	2.516	2.600	2.615	2.570	
(42)		Ebn at Noon	930	922	921	863	843	801	822	875	894	916	917	907	
(43)		Edh at Noon	98	109	110	127	124	140	129	109	109	99	95	98	
(44)	All-Sky Solar Radiation	RadAvg	5.38	5.96	6.31	6.36	6.11	5.85	5.99	6.21	6.23	5.81	5.26	5.04	
(45)		RadStd	0.20	0.23	0.36	0.28	0.34	0.28	0.21	0.18	0.20	0.20	0.28	0.19	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page