

GUANARE, Venezuela

WMO: 804280

Lat: 9.027N

Lon: 69.755W

Elev: 185

StdP: 99.13

Time Zone: -4.00 (W04)

Period: 94-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.1	21.0	14.0	10.2	29.1	15.1	11.0	29.1	6.6	26.0	5.3	25.9	0.8	110	0.280

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	10.6	35.5	24.3	34.9	24.0	34.1	23.9	27.0	31.8	26.4	31.4	26.0	31.0	2.6	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.9	21.7	29.6	25.1	20.7	28.7	24.8	20.2	28.3	86.2	31.8	83.7	31.5	81.8	31.2	30.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
5.5	4.9	4.3	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.5	27.3	28.2	29.0	28.4	27.5	26.7	26.3	26.9	27.2	27.4	27.5	27.3
	DBStd	1.42	1.04	1.15	1.51	1.61	1.34	1.18	1.07	1.23	1.07	1.17	1.12	0.95
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6378	535	511	591	551	542	501	506	524	517	539	525	536
	CDD18.3	3336	277	277	332	301	284	251	248	266	267	281	275	278
	CDH23.3	33837	3078	3238	4107	3396	2793	2131	1933	2358	2454	2741	2771	2837
	CDH26.7	14546	1476	1585	2092	1496	1055	710	663	901	994	1144	1190	1241
Wind	WSAvg	1.8	1.9	2.1	2.1	1.9	1.7	1.7	1.5	1.6	1.5	1.5	1.6	1.7
Precipitation	PrecAvg	1402	22	10	11	85	161	281	227	179	139	146	105	33
	PrecMax	1786	103	63	62	264	304	422	390	368	180	316	268	107
	PrecMin	1065	0	0	0	0	74	149	19	102	89	0	13	0
	PrecStd	224	26	18	16	65	69	83	84	70	31	73	70	32
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.8	36.0	36.8	36.2	34.9	33.1	33.0	34.8	34.0	34.1	34.1	34.2
		MCWB	23.5	23.8	25.2	24.1	25.2	25.2	25.2	26.4	25.9	25.5	24.8	24.1
	2%	DB	34.0	34.9	35.9	35.1	33.2	32.1	32.0	33.0	33.1	33.2	33.2	33.7
		MCWB	23.2	23.6	24.7	24.0	24.9	24.9	24.8	25.5	25.5	25.3	24.7	23.9
	5%	DB	33.2	34.1	35.0	34.1	32.3	31.2	31.2	32.0	32.3	32.8	32.9	33.0
		MCWB	23.0	23.2	24.1	23.9	24.7	24.7	24.5	25.0	25.1	25.2	24.6	23.9
	10%	DB	32.7	33.2	34.1	33.0	31.6	30.6	30.4	31.1	31.8	32.0	32.1	32.1
		MCWB	22.9	23.1	23.7	23.7	24.5	24.6	24.4	24.7	25.0	24.9	24.5	23.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.7	25.9	28.2	26.8	27.1	26.9	26.6	27.3	27.1	27.1	26.6	26.2
		MCDB	32.6	33.0	35.0	31.4	31.4	30.8	30.4	31.5	32.1	31.9	31.7	31.4
	2%	WB	24.8	25.0	26.5	26.0	26.2	26.0	25.8	26.4	26.4	26.3	25.9	25.5
		MCDB	32.1	32.9	33.2	31.2	30.9	30.0	29.9	30.8	31.5	31.2	31.3	31.3
	5%	WB	24.1	24.3	25.3	25.4	25.6	25.5	25.3	25.8	25.8	25.7	25.4	25.0
		MCDB	31.3	32.0	32.3	30.4	30.3	29.5	29.4	30.2	30.8	30.7	30.9	30.8
	10%	WB	23.5	23.7	24.5	24.9	25.2	25.0	24.9	25.3	25.4	25.4	25.0	24.5
		MCDB	30.7	31.3	31.7	29.8	29.7	29.0	28.9	29.6	30.2	30.2	30.5	30.2
Mean Daily Temperature Range	5% DB	MDBR	11.8	11.0	10.6	8.6	8.1	7.7	8.2	8.6	9.1	9.3	9.5	10.1
		MCDBR	12.4	12.0	11.5	10.6	9.2	9.0	9.5	9.9	10.0	10.2	10.6	11.3
		MCWBR	4.6	4.4	4.3	3.7	4.0	4.2	4.3	4.1	4.2	4.2	3.9	4.1
	5% WB	MCDBR	11.2	10.6	10.5	8.3	8.4	8.1	8.5	9.0	9.3	9.4	9.5	9.7
		MCWBR	4.9	4.6	5.2	3.8	4.2	4.2	4.2	4.3	4.4	4.4	4.1	4.1
Clear-Sky Solar Irradiance	taub	0.402	0.439	0.481	0.577	0.490	0.503	0.470	0.442	0.436	0.421	0.409	0.411	
	taud	2.437	2.315	2.205	1.916	2.204	2.159	2.277	2.357	2.360	2.435	2.454	2.437	
	Ebn at Noon	909	884	848	760	812	791	822	859	874	889	895	892	
	Edh at Noon	115	134	151	199	146	150	134	126	127	117	112	113	
All-Sky Solar Radiation	RadAvg	5.29	5.60	5.17	4.49	4.50	4.48	4.68	4.90	5.08	4.94	4.72	4.91	
	RadStd	0.27	0.25	0.51	0.38	0.29	0.24	0.27	0.22	0.22	0.17	0.23	0.31	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page