

MERIDA, Venezuela

WMO: 804380

Lat: 8.582N

Lon: 71.161W

Elev: 5007

StdP: 12.22

Time Zone: -4.00 (W04)

Period: 94-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	57.1	58.6	42.0	47.3	70.5	44.6	52.4	68.7	17.7	75.5	16.0	75.9	6.3	90	0.297

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	18.6	84.3	66.6	82.5	66.7	80.9	66.6	72.5	79.3	71.1	78.4	70.1	77.5	8.7	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
70.1	133.9	77.4	68.4	126.1	75.0	67.9	123.8	74.2	39.9	79.7	38.5	79.1	37.5	77.9	82.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.1	14.2	12.9	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	70.0	68.3	69.2	69.8	70.3	70.7	70.3	70.2	70.9	71.3	70.0	69.8	68.9
	DBStd	2.13	1.86	2.27	2.51	2.02	1.84	1.75	2.04	1.73	1.95	1.84	1.63	2.03
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	4	1	0	2	0	0	0	0	0	0	0	0	1
	CDD50	7290	568	536	614	609	641	609	625	647	640	621	593	587
	CDD65	1821	103	117	151	160	176	160	160	182	190	156	143	123
	CDH74	6673	469	484	574	538	585	480	569	732	866	527	420	429
	CDH80	564	25	38	47	37	43	31	61	72	133	43	15	19
(14) Wind	WSAvg	6.1	6.8	6.8	6.6	6.2	5.7	5.4	5.9	6.1	6.1	5.6	5.7	6.2
(15) Precipitation	PrecAvg	68.4	1.5	1.8	2.7	7.1	8.9	5.6	4.4	5.5	8.0	10.2	7.7	3.3
	PrecMax	91.1	4.3	8.5	10.0	16.9	16.3	11.9	11.4	15.8	16.1	17.6	14.9	8.6
	PrecMin	45.2	0.0	0.0	0.2	0.4	3.6	0.2	0.0	0.3	0.9	5.2	2.4	0.6
	PrecStd	11.7	1.3	1.7	2.1	3.5	2.8	3.1	2.0	2.6	3.0	3.1	2.9	2.0
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	82.9	83.8	83.4	83.6	84.1	83.8	84.6	84.6	86.3	84.4	81.0	82.4
		MCWB	64.7	68.6	68.5	67.7	67.1	69.1	66.5	64.9	64.4	69.1	67.1	66.3
	2%	DB	80.0	80.5	80.9	80.8	80.7	80.6	81.0	82.2	83.4	80.9	79.2	79.3
		MCWB	65.3	67.0	68.0	68.1	65.8	68.0	67.2	65.4	64.8	67.4	66.9	64.5
	5%	DB	78.5	78.8	79.1	79.0	78.9	78.8	79.0	80.3	80.8	79.1	78.5	78.4
		MCWB	64.3	65.5	67.0	66.8	65.6	67.0	66.4	65.7	65.3	66.7	66.6	64.5
	10%	DB	76.9	77.1	77.4	77.3	77.3	77.0	77.2	78.6	78.9	77.2	76.9	76.8
		MCWB	63.8	64.3	65.7	66.1	65.0	66.2	65.7	65.6	64.9	66.0	66.0	64.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.4	72.6	73.0	72.8	71.4	72.9	72.5	72.8	72.4	73.7	71.9	70.5
		MCDB	78.9	80.2	80.2	79.4	77.8	78.7	79.2	79.8	80.1	80.0	77.7	78.1
	2%	WB	68.8	70.0	70.8	70.5	69.6	70.8	70.1	70.2	70.1	70.7	69.8	68.2
		MCDB	76.6	77.9	78.5	77.6	77.4	77.7	78.0	77.8	77.9	78.1	76.6	75.9
	5%	WB	67.0	68.2	69.0	69.1	68.2	69.1	68.3	68.5	68.4	69.1	68.4	66.9
		MCDB	74.7	75.4	76.4	75.8	74.7	75.9	75.4	75.4	75.7	76.3	75.1	73.6
	10%	WB	65.7	66.5	67.4	67.9	67.2	67.7	67.1	67.2	67.2	67.5	67.3	66.0
		MCDB	72.7	72.9	74.0	74.2	73.1	73.7	73.3	73.5	73.8	74.1	73.4	72.0
(35) Mean Daily Temperature Range	5% DB	MDBR	20.0	18.6	17.1	16.6	16.7	16.4	17.4	17.7	18.6	16.9	16.6	17.9
		MCDBR	21.6	20.5	19.2	18.6	18.5	18.4	19.5	19.7	20.8	19.4	18.4	19.7
		MCWBR	13.8	13.3	12.0	11.0	10.3	10.7	10.8	10.9	11.0	11.3	11.2	12.2
	5% WB	MCDBR	20.5	19.7	18.5	17.6	17.2	17.5	18.5	18.4	19.4	18.2	17.2	18.8
		MCWBR	14.6	13.6	13.0	11.3	10.4	11.3	11.7	11.7	11.7	12.0	11.4	12.5
(40) Clear-Sky Solar Irradiance	taub		0.356	0.392	0.431	0.545	0.448	0.481	0.416	0.419	0.407	0.377	0.374	0.368
	taud		2.501	2.380	2.278	1.917	2.244	2.115	2.350	2.331	2.360	2.489	2.496	2.491
	Ebn at Noon		303	295	283	249	269	257	275	279	285	296	296	297
	Edh at Noon		34	40	44	63	44	50	40	41	40	35	34	34
(44) All-Sky Solar Radiation	RadAvg		1505	1559	1401	1281	1381	1419	1452	1506	1562	1468	1367	1413
	RadStd		114	110	170	85	68	54	62	63	71	49	72	99

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page