

MERIDA, Venezuela

WMO: 804380

Lat: 8.582N

Lon: 71.161W

Elev: 1526

StdP: 84.29

Time Zone: -4.00 (W04)

Period: 94-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.0	14.8	5.5	6.8	21.4	7.0	7.5	20.4	7.9	24.2	7.2	24.4	2.8	90	0.297

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	10.3	29.0	19.2	28.0	19.3	27.1	19.2	22.5	26.3	21.7	25.8	21.1	25.3	3.9	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.2	19.1	25.2	20.2	18.0	23.9	19.9	17.7	23.4	74.9	26.5	71.7	26.2	69.4	25.5	28.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.2	6.4	5.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	21.1	20.2	20.6	21.0	21.3	21.5	21.3	21.2	21.6	21.9	21.1	21.0	20.5
	DBStd	1.18	1.03	1.26	1.40	1.12	1.02	0.97	1.13	0.96	1.08	1.02	0.91	1.13
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	2	1	0	1	0	0	0	0	0	0	0	0	1
	CDD10.0	4050	316	298	341	338	356	338	347	359	356	345	329	326
	CDD18.3	1012	57	65	84	89	98	89	89	101	106	87	79	68
	CDH23.3	3707	261	269	319	299	325	267	316	407	481	293	233	238
	CDH26.7	313	14	21	26	21	24	17	34	40	74	24	8	11
Wind	WSAvg	2.7	3.0	3.0	3.0	2.8	2.6	2.4	2.6	2.7	2.7	2.5	2.5	2.8
Precipitation	PrecAvg	1738	39	46	69	181	227	143	112	139	203	258	196	83
	PrecMax	2314	109	215	255	428	415	301	289	401	409	446	378	219
	PrecMin	1147	0	0	4	11	92	6	0	8	22	132	60	14
	PrecStd	296	32	44	53	89	71	78	51	66	76	80	73	50
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.3	28.8	28.6	28.7	28.9	28.8	29.2	29.2	30.2	29.1	27.2	28.0
		MCWB	18.2	20.3	20.3	19.9	19.5	20.6	19.2	18.3	18.0	20.6	19.5	19.1
	2%	DB	26.7	27.0	27.2	27.1	27.0	27.0	27.2	27.9	28.6	27.2	26.2	26.3
		MCWB	18.5	19.4	20.0	20.1	18.8	20.0	19.5	18.6	18.2	19.7	19.4	18.1
	5%	DB	25.8	26.0	26.2	26.1	26.1	26.0	26.1	26.8	27.1	26.1	25.8	25.8
		MCWB	17.9	18.6	19.4	19.3	18.7	19.4	19.1	18.7	18.5	19.3	19.2	18.1
	10%	DB	25.0	25.0	25.2	25.1	25.2	25.0	25.1	25.9	26.1	25.1	24.9	24.9
		MCWB	17.7	17.9	18.7	18.9	18.4	19.0	18.7	18.7	18.3	18.9	18.9	17.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.9	22.5	22.8	22.6	21.9	22.7	22.5	22.7	22.4	23.1	22.2	21.4
		MCDB	26.0	26.8	26.8	26.3	25.4	25.9	26.2	26.5	26.7	26.7	25.4	25.6
	2%	WB	20.4	21.1	21.6	21.4	20.9	21.5	21.2	21.2	21.2	21.5	21.0	20.1
		MCDB	24.8	25.5	25.8	25.3	25.2	25.4	25.6	25.4	25.5	25.6	24.8	24.4
	5%	WB	19.5	20.1	20.5	20.6	20.1	20.6	20.2	20.3	20.2	20.6	20.2	19.4
		MCDB	23.7	24.1	24.7	24.4	23.7	24.4	24.1	24.1	24.3	24.6	24.0	23.1
	10%	WB	18.7	19.2	19.7	19.9	19.6	19.8	19.5	19.6	19.6	19.7	19.6	18.9
		MCDB	22.6	22.7	23.4	23.5	22.8	23.2	23.0	23.1	23.2	23.4	23.0	22.2
Mean Daily Temperature Range	5% DB	MDBR	11.1	10.3	9.5	9.2	9.3	9.1	9.7	9.9	10.3	9.4	9.2	10.0
		MCDBR	12.0	11.4	10.7	10.3	10.3	10.2	10.9	11.0	11.6	10.8	10.2	11.0
		MCWBR	7.7	7.4	6.7	6.1	5.7	5.9	6.0	6.0	6.1	6.3	6.2	6.8
	5% WB	MCDBR	11.4	11.0	10.3	9.8	9.5	9.7	10.3	10.2	10.8	10.1	9.6	10.4
		MCWBR	8.1	7.6	7.2	6.3	5.8	6.3	6.5	6.5	6.5	6.7	6.3	7.0
Clear-Sky Solar Irradiance	taub		0.356	0.392	0.431	0.545	0.448	0.481	0.416	0.419	0.407	0.377	0.374	0.368
	taud		2.501	2.380	2.278	1.917	2.244	2.115	2.350	2.331	2.360	2.489	2.496	2.491
	Ebn at Noon		956	929	893	785	847	809	868	878	900	932	932	936
	Edh at Noon		108	125	140	199	140	157	125	130	127	111	108	107
All-Sky Solar Radiation	RadAvg		4.74	4.92	4.42	4.04	4.35	4.47	4.58	4.75	4.92	4.63	4.31	4.45
	RadStd		0.36	0.35	0.54	0.27	0.21	0.17	0.19	0.20	0.22	0.15	0.23	0.31

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page