

SAN ANTONIO DEL TACHIRA, Venezuela

WMO: 804470

Lat: 7.841N

Lon: 72.440W

Elev: 1312

StdP: 14.01

Time Zone: -4.00 (W04)

Period: 90-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	67.8	69.4	55.0	67.6	81.9	56.9	72.5	81.5	24.0	87.3	21.3	88.1	1.1	180	0.300

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	17.7	95.4	74.3	94.6	74.1	93.2	73.8	78.7	88.4	77.6	87.6	76.9	87.0	12.5	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
76.6	145.8	81.4	75.3	139.3	80.7	74.4	134.9	79.9	43.3	88.8	42.1	87.5	41.3	87.2	88.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
26.5	23.2	21.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	81.3	79.2	79.9	80.1	81.4	82.1	82.2	81.9	83.1	83.4	82.4	80.9	79.5
	DBStd	2.94	2.60	2.86	3.50	3.00	2.68	2.58	2.37	2.33	2.18	2.57	2.22	2.16
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11436	904	837	932	941	996	965	989	1025	1001	1005	926	915
	CDD65	5961	439	417	467	491	531	515	524	560	551	540	476	450
	CDH74	57086	3561	3686	4108	4663	5406	5350	5320	5981	5942	5379	4106	3584
	CDH80	22430	1386	1456	1596	1880	2087	1898	1871	2419	2604	2295	1618	1320
Wind	WSAvg	7.3	4.3	4.6	4.5	4.7	8.2	12.2	12.7	11.4	9.7	6.5	4.2	4.6
Precipitation	PrecAvg	28.7	1.5	1.5	1.8	3.8	3.0	1.3	1.1	1.2	1.9	4.1	4.4	3.0
	PrecMax	46.0	8.0	6.7	7.1	15.1	10.0	7.4	4.9	8.1	7.6	9.6	11.1	11.1
	PrecMin	15.3	0.0	0.0	0.0	0.2	0.2	0.1	0.0	0.2	0.3	0.9	0.3	0.1
	PrecStd	7.4	1.9	1.4	1.6	3.2	2.6	1.3	0.8	1.2	1.5	2.4	3.0	2.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	93.5	95.0	96.7	96.8	95.4	94.7	94.9	96.6	97.1	96.7	94.6	93.2
		MCWB	72.3	72.9	75.5	76.4	74.3	73.5	73.6	74.5	74.2	74.2	74.9	73.7
	2%	DB	91.4	93.0	93.1	93.5	93.4	92.3	92.0	93.9	95.1	94.1	91.9	91.2
		MCWB	73.0	73.0	74.5	74.9	74.2	73.3	72.8	73.6	74.0	74.0	74.7	73.7
	5%	DB	89.6	90.8	90.9	91.4	91.6	91.0	90.4	91.8	93.2	92.8	90.3	89.4
		MCWB	72.9	72.9	74.0	74.3	73.6	72.9	72.6	73.2	73.7	74.0	74.4	73.5
	10%	DB	87.8	88.1	88.1	89.4	89.5	89.2	88.9	90.0	91.4	90.8	88.4	87.6
		MCWB	72.7	72.8	73.3	73.8	73.1	72.4	72.1	72.6	73.1	73.5	73.8	73.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	77.3	76.9	78.9	79.9	79.1	78.0	77.8	78.1	78.5	78.8	78.9	78.2
		MCDB	87.7	89.3	88.6	90.2	88.5	86.4	87.7	90.0	89.0	89.3	89.1	87.3
	2%	WB	75.5	75.4	77.1	78.0	77.4	76.1	75.5	76.3	76.7	77.0	77.2	76.9
		MCDB	86.3	86.5	87.4	87.8	85.8	86.3	86.4	88.6	88.6	88.2	87.4	86.7
	5%	WB	74.5	74.5	75.8	76.8	76.4	74.7	74.1	74.9	75.4	76.0	76.2	75.7
		MCDB	84.9	84.9	85.3	86.1	84.5	85.7	85.6	86.6	87.0	86.5	85.6	84.4
	10%	WB	73.6	73.7	74.7	75.6	75.2	73.6	73.1	73.9	74.4	75.0	75.2	74.7
		MCDB	83.6	83.6	83.6	83.8	83.8	84.9	84.9	85.8	86.2	85.0	83.8	82.7
Mean Daily Temperature Range	5% DB	MDBR	17.6	16.9	16.0	16.2	15.8	14.3	14.4	15.9	17.7	17.7	17.2	16.6
		MCDBR	20.3	20.7	19.3	18.9	18.6	16.9	17.1	18.2	19.8	19.6	19.5	19.5
		MCWBR	9.0	8.5	7.6	8.2	8.1	7.4	6.9	7.5	8.0	7.9	8.0	8.6
	5% WB	MCDBR	18.5	18.0	17.1	17.6	17.1	15.4	15.5	17.3	18.6	18.1	18.4	17.4
		MCWBR	8.9	8.1	7.9	8.7	8.7	8.1	7.7	8.3	8.7	8.1	8.4	8.2
Clear-Sky Solar Irradiance	taub		0.430	0.472	0.532	0.566	0.468	0.446	0.444	0.462	0.440	0.473	0.425	0.443
	taud		2.341	2.206	2.038	1.952	2.266	2.337	2.337	2.275	2.335	2.249	2.395	2.326
	Ebn at Noon		280	272	256	244	263	266	267	267	276	268	280	273
	Edh at Noon		40	47	57	61	43	40	40	43	42	45	38	40
All-Sky Solar Radiation	RadAvg		1401	1427	1274	1256	1398	1420	1456	1558	1589	1503	1349	1334
	RadStd		148	148	172	97	58	62	61	65	63	56	69	105

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page